

TA7
C6

CER-84/85-43

COPY 2

WIND-TUNNEL STUDY OF
LAKEWAY CENTER COMPLEX, METAIRIE, LOUISIANA

by

J. A. Peterka* and J. E. Cermak*



FLUID MECHANICS AND
WIND ENGINEERING PROGRAM

COLLEGE OF ENGINEERING

COLORADO STATE UNIVERSITY
FORT COLLINS, COLORADO

CER84-85 JAP-DEC43

WIND-TUNNEL STUDY OF
LAKEWAY CENTER COMPLEX, METAIRIE, LOUISIANA

by

J. A. Peterka* and J. E. Cermak*

for

N-Y Associates, Inc.
2700 Lake Villa Drive
Metairie, Louisiana 70002

Fluid Mechanics and Wind Engineering Program
Fluid Dynamics and Diffusion Laboratory
Department of Civil Engineering
Colorado State University
Fort Collins, Colorado 80523

CSU Project 2-96010

April 1985

*Professor, Fluid Mechanics and
Wind Engineering Program

TABLE OF CONTENTS

<u>Chapter</u>		<u>Page</u>
	LIST OF FIGURES	ii
	LIST OF TABLES	iii
	LIST OF SYMBOLS	iv
1	INTRODUCTION	1
	1.1 General	1
	1.2 The Wind-Tunnel Test	3
2	EXPERIMENTAL CONFIGURATION	5
	2.1 Wind Tunnel	5
	2.2 Model	5
3	INSTRUMENTATION AND DATA ACQUISITION	8
	3.1 Flow Visualization	8
	3.2 Pressures	8
	3.3 Velocity	10
4	RESULTS	12
	4.1 Flow Visualization	12
	4.2 Velocity	12
	4.3 Pressures	15
	4.4 Forces and Moments	19
5	DISCUSSION	21
	5.1 Flow Visualization	21
	5.2 Pedestrian Winds	22
	5.3 Wind Loads	23
	REFERENCES	25
	FIGURES	26
	TABLES	159
	APPENDIX A (Bound Separately)	

LIST OF FIGURES

<u>Figure</u>		<u>Page</u>
1	Fluid Dynamics and Diffusion Laboratory	27
2	Wind-Tunnel Configuration	28
3	Pressure Tap Locations	29
4	Building Location and Pedestrian Wind Velocity Measuring Positions	55
5	Completed Model in Wind Tunnel	56
6	Data Sampling Time Verification	58
7	Mean Velocity and Turbulence Profiles Approaching the Model	59
8	Mean Velocities and Turbulence Intensities at Pedestrian Locations	62
9	Wind Velocity Probabilities for Pedestrian Locations	87
10	Peak Pressure Distribution on the Building for Cladding Loads	97
11	Peak Cladding Pressure Zones	145
12	Coordinate System for Forces and Moments	150
13	Load, Shear, and Moment Diagrams for Selected Wind Directions	153

LIST OF TABLES

<u>Table</u>		<u>Page</u>
1	Data Configurations	160
2	Pedestrian Wind Velocities and Turbulence Intensities	161
3	Annual Percentage Frequencies of Wind Direction and Speed	176
4	Summary of Wind Effects on People	177
5	Calculation of Reference Pressure	178
6	Maximum Pressure Coefficients and Loads in PSF	181
7	Loads, Shears, and Moments for Each Wind Direction . .	197

LIST OF SYMBOLS

<u>Symbol</u>	<u>Definition</u>
U	Local mean velocity
D	Characteristic dimension (building height, width, etc.)
ν, ρ	Kinematic viscosity and density of approach flow
$\frac{UD}{\nu}$	Reynolds number
E	Mean voltage
A, B, n	Constants
U_{rms}	Root-mean-square of fluctuating velocity
E_{rms}	Root-mean-square of fluctuating voltage
U_{∞}	Reference mean velocity outside the boundary layer
X, Y	Horizontal coordinates
Z	Height above surface
δ	Height of boundary layer
T_u	Turbulence intensity $\frac{U_{rms}}{U_{\infty}}$ or $\frac{U_{rms}}{U}$
$C_{p_{mean}}$	Mean pressure coefficient, $\frac{(p-p_{\infty})_{mean}}{0.5 \rho U_{\infty}^2}$
$C_{p_{rms}}$	Root-mean-square pressure coefficient, $\frac{((p-p_{\infty})-(p-p_{\infty})_{mean})_{rms}}{0.5 \rho U_{\infty}^2}$
$C_{p_{max}}$	Peak maximum pressure coefficient, $\frac{(p-p_{\infty})_{max}}{0.5 \rho U_{\infty}^2}$
$C_{p_{min}}$	Peak minimum pressure coefficient, $\frac{(p-p_{\infty})_{min}}{0.5 \rho U_{\infty}^2}$
$()_{min}$	Minimum value during data record
$()_{max}$	Maximum value during data record

<u>Symbol</u>	<u>Definition</u>
p	Fluctuating pressure at a pressure tap on the structure
p_{∞}	Static pressure in the wind tunnel above the model
F_x, F_y	Forces in X, Y direction
A_R	Reference Area
CF_X	Force coefficient, X direction, $\frac{F_x}{A_R 0.5 \rho U_{\infty}^2}$
CF_Y	Force coefficient, Y direction, $\frac{F_y}{A_R 0.5 \rho U_{\infty}^2}$

1. INTRODUCTION

1.1 General

A significant characteristic of modern building design is lighter cladding and more flexible frames. These features produce an increased vulnerability of glass and cladding to wind damage and result in larger deflections of the building frame. In addition, increased use of pedestrian plazas at the base of the buildings has brought about a need to consider the effects of wind and gustiness in the design of these areas.

The building geometry itself may increase or decrease wind loading on the structure. Wind forces may be modified by nearby structures which can produce beneficial shielding or adverse increases in loading. Overestimating loads results in uneconomical design; underestimating may result in cladding or window failures. Tall structures have historically produced unpleasant wind and turbulence conditions at their bases. The intensity and frequency of objectionable winds in pedestrian areas is influenced both by the structure shape and by the shape and position of adjacent structures.

Techniques have been developed for wind-tunnel modeling of proposed structures which allow the prediction of wind pressures on cladding and windows, overall structural loading, and also wind velocities and gusts in pedestrian areas adjacent to the building. Information on sidewalk-level gustiness allows plaza areas to be protected by design changes before the structure is constructed. Accurate knowledge of the intensity and distribution of the pressures on the structure permits adequate but economical selection of cladding strength to meet selected maximum design winds and overall wind loads for the design of the frame for flexural control.

In the Three Lakeway Center complex, the One Lakeway Center and Two Lakeway Center buildings already exist with Three Lakeway Center about to be constructed. The wind-tunnel test reported herein tested all three buildings for wind load in the final configuration and tested pedestrian wind speeds in the current configuration and with the addition of the Three Lakeway building.

Modeling of the aerodynamic loading on a structure requires special consideration of flow conditions in order to guarantee similitude between model and prototype. A detailed discussion of the similarity requirements and their wind-tunnel implementation can be found in references (1), (2), and (3). In general, the requirements are that the model and prototype be geometrically similar, that the approach mean velocity at the building site have a vertical profile shape similar to the full-scale flow, that the turbulence characteristics of the flows be similar, and that the Reynolds number for the model and prototype be equal.

These criteria are satisfied by constructing a scale model of the structure and its surroundings and performing the wind tests in a wind tunnel specifically designed to model atmospheric boundary-layer flows. Reynolds number similarity requires that the quantity UD/ν be similar for model and prototype. Since ν , the kinematic viscosity of air, is identical for both, Reynolds numbers cannot be made precisely equal with reasonable wind velocities. To accomplish this the air velocity in the wind tunnel would have to be as large as the model scale factor times the prototype wind velocity, a velocity which would introduce unacceptable compressibility effects. However, for sufficiently high Reynolds numbers ($>2 \times 10^4$) the pressure coefficient at any location on the

structure will be essentially constant for a large range of Reynolds numbers. Typical values encountered are 10^7 - 10^8 for the full-scale and 10^5 - 10^6 for the wind-tunnel model. In this range acceptable flow similarity is achieved without precise Reynolds number equality.

1.2 The Wind-Tunnel Test

The wind-engineering study is performed on a building or building group modeled at scales ranging from 1:150 to 1:400. The building model is constructed of clear plastic fastened together with screws. The structure is modeled in detail to provide accurate flow patterns in the wind passing over the building surfaces. The building under test is often located in a surrounding where nearby buildings or terrain may provide beneficial shielding or adverse wind loading. To achieve similarity in wind effects the area surrounding the test building is also modeled. A flow visualization study is first made (smoke is used to make the air currents visible) to define overall flow patterns and identify regions where local flow features might cause difficulties in building curtain-wall design or produce pedestrian discomfort.

The test model, equipped with pressure taps (200 to 600 or more), is exposed to an appropriately modeled atmospheric wind in the wind tunnel and the fluctuating pressure at each tap measured electronically. The model, and the modeled area, are rotated 10 or 15 degrees and another set of data recorded for each pressure tap. Normally, 24 or 36 sets of data (360 degrees of turning) are taken; however, when flow visualization or recorded data indicate high pressure regions of small azimuthal extent, data is obtained in smaller azimuthal steps.

Data are recorded, analyzed and processed by an on-line computerized data-acquisition system. Pressure coefficients of several

types are calculated by the computer for each reading on each piezometer tap and are printed in tabular form as computer readout. Using wind data applicable to the building site, representative wind velocities are selected for combination with measured pressures on the building model. Integration of test data with wind data results in prediction of peak local wind pressures for design of glass or cladding and may include overall forces and moments on the structure (by floor if desired) for design of the structural frame. Pressure contours are drawn on the developed building surfaces showing the intensity and distribution of peak wind loads on the building. These results may be used to divide the building into zones where lighter or heavier cladding or glass may be desirable.

Based on the visualization (smoke) tests and on a knowledge of heavy pedestrian use areas, a dozen or more locations may be chosen at the base of the building where wind velocities can be measured to determine the relative comfort or discomfort of pedestrians in plaza areas, near building entrances, near building corners, or on sidewalks. Usually a reference pedestrian position is also tested to determine whether the wind environment in the building area is better or worse than the environment a block or so away in an undisturbed area.

The following pages discuss in greater detail the procedures followed and the equipment and data collecting and processing methods used. In addition, the data presentation format is explained and the implications of the data are discussed.

2. EXPERIMENTAL CONFIGURATION

2.1 Wind Tunnel

Wind-engineering studies are performed in the Fluid Dynamics and Diffusion Laboratory at Colorado State University (Figure 1). Three large wind tunnels are available for wind loading studies depending on the detailed requirements of the study. The wind tunnel used for this investigation is shown in Figure 2. All tunnels have a flexible roof adjustable in height to maintain a zero pressure gradient along the test section. The mean velocity can be adjusted continuously in each tunnel to the maximum velocity available.

2.2 Model

In order to obtain an accurate assessment of local pressures using piezometer taps, models are constructed to the largest scale that does not produce significant blockage in the wind-tunnel test section. The models are constructed of 1/2-in. thick Lucite plastic and fastened together with metal screws. Significant variations in the building surface, such as mullions, are machined into the plastic surface. Piezometer taps (1/16 in. diameter) are drilled normal to the exterior vertical surfaces in rows at several or more elevations between the bottom and top of the building. Similarly, taps are placed in the roof and on any sloping, protruding, or otherwise distinctive features of the building that might need investigation.

Pressure tap locations are chosen so that the entire surface of the building can be investigated for pressure loading and at the same time permit critical examination of areas where experience has shown that maximum wind effects may be expected to occur. Locations of the pressure taps for this study are shown in Figure 3. Dimensions are

given both for full-scale building (in ft) and for model (in in.). The pressure tap numbers are shown adjacent to the taps.

The pressure tests are sometimes made in two stages. In the first stage measurements are made on the initial distribution of pressure taps. If it becomes apparent from the data that the loading on the building is being influenced by some unsuspected geometry of the building or adjacent structures, additional pressure taps are installed in the critical areas. The locations of the taps are selected so that the maximum loading can be detected and the area over which this loading is acting can be defined. Any added taps are also shown in Figure 3.

A circular area 750 to 2000 ft in radius depending on model scale and characteristics of the surrounding buildings and terrain is modeled in detail. Structures within the modeled region are made from styrofoam and cut to the individual building geometries. They are mounted on the turntable in their proper locations. Significant terrain features are included as needed. The model is mounted on a turntable (Figure 2) near the downwind end of the test section. Any buildings or terrain features which do not fit on the turntable are placed on removable pieces which are placed upwind of the turntable for appropriate wind directions. A plan view of the building and its surroundings is shown in Figure 4. The turntable is calibrated to indicate azimuthal orientation to 0.1 degree.

The region upstream from the modeled area is covered with a randomized roughness constructed using various sized cubes placed on the floor of the wind tunnel. Different roughness sizes may be used for different wind directions. Spires are installed at the test-section entrance to provide a thicker boundary layer than would otherwise be

available. The thicker boundary layer permits a somewhat larger scale model than would otherwise be possible. The spires are approximately triangularly shaped pieces of 1/2-in. thick plywood 6 in. wide at the base and 1 in. wide at the top, extending from the floor to the top of the test section. They are placed so that the broad side intercepts the flow. A barrier approximately 8 in. high is placed on the test-section floor downstream of the spires to aid in development of the boundary-layer flow.

The distribution of the roughness cubes and the spires in the roughened area was designed to provide a boundary-layer thickness of approximately 4 ft, a velocity profile power-law exponent similar to that expected to occur in the region approaching the modeled area for each wind direction (a number of wind directions may have the same approach roughness). A photograph of the completed model in the wind tunnel is shown in Figure 5. The wind-tunnel ceiling is adjusted after placement of the model to obtain a zero pressure gradient along the test section.

3. INSTRUMENTATION AND DATA ACQUISITION

3.1 Flow Visualization

Making the air flow visible in the vicinity of the model is helpful (a) in understanding and interpreting mean and fluctuating pressures, (b) in defining zones of separated flow and reattachment and zones of vortex formation where pressure coefficients may be expected to be high and (c) in indicating areas where pedestrian discomfort may be a problem. Titanium tetrachloride smoke is released from sources on and near the model to make the flow lines visible to the eye and to make it possible to obtain motion picture records of the tests. Conclusions obtained from these smoke studies are discussed in Sections 4.1 and 5.1.

3.2 Pressures

Mean and fluctuating pressures are measured at each of the pressure taps on the model structure. Data are obtained for 24 or 36 wind directions, rotating the entire model assembly at a complete circle. Seventy-six pieces of 1/16 in. I.D. plastic tubing are used to connect 76 pressure ports at a time to an 80 tap pressure switch mounted inside the model. The switch was designed and fabricated in the Fluid Dynamics and Diffusion Laboratory to minimize the attenuation of pressure fluctuations across the switch. Each of the 76 measurement ports is directed in turn by the switch to one of four pressure transducers mounted close to the switch. The four pressure input taps not used for transmitting building surface pressures are connected to a common tube leading outside the wind tunnel. This arrangement provides both a means of performing in-place calibration of the transducers and, by connecting this tube to a pitot tube mounted inside the wind tunnel, a means of automatically monitoring the tunnel speed. The switch is operated by

means of a shaft projecting through the floor of the wind tunnel. A computer-controlled stepping motor steps the switch into each of the 20 required positions. The computer keeps track of switch position but a digital readout of position is provided at the wind tunnel.

The pressure transducers used are setra differential transducers (Model 237) with a 0.10 psid range. Reference pressures are obtained by connecting the reference sides of the four transducers, using plastic tubing, to the static side of a pitot-static tube mounted in the wind tunnel free stream above the model building. In this way the transducer measures the instantaneous difference between the local pressures on the surface of the building and the static pressure in the free stream above the model.

Output from the pressure transducers is fed to an on-line data acquisition system consisting of a Hewlett-Packard 21 MX computer, disk unit, card reader, printer, Digi-Data digital tape drive and a Preston Scientific analog-to-digital converter. The data are processed immediately into pressure coefficient form as described in Section 4.3 and stored for printout or further analysis.

All four transducers are recorded simultaneously for 16 seconds at a 250 sample-per-second rate. The results of an experiment to determine the length of record required to obtain stable mean and rms (root-mean-square) pressures and to determine the overall accuracy of the pressure data acquisition system is shown in Figure 6. A typical pressure port record was integrated for a number of different time periods to obtain the data shown. Examination of a large number of pressure taps showed that the overall accuracy for a 16-second period is, in pressure coefficient form, 0.03 for mean pressures, 0.1 for peak pressures, and 0.01 for rms pressures. Pressure coefficients are defined in Section 4.3.

3.3 Velocity

Mean velocity and turbulence intensity profiles are measured upstream of the model to determine that an approach boundary-layer flow appropriate to the site has been established. Tests are made at one wind velocity in the tunnel. This velocity is well above that required to produce Reynolds number similarity between the model and the prototype as discussed in Section 1.1.

In addition, mean velocity and turbulence intensity measurements are made 5 to 7 ft (prototype) above the surface at a dozen or more locations on and near the building for 16 wind directions. The measurement locations are shown on Figure 4. The surface measurements are indicative of the wind environment to which a pedestrian at the measurement location would be subjected. The locations are chosen to determine the degree of pedestrian comfort or discomfort at the building corners where relatively severe conditions frequently are found, near building entrances and on adjacent sidewalks where pedestrian traffic is heavy, and in open plaza areas. In most studies a reference pedestrian position, located about a block away, is also tested. These data are helpful in evaluating the degree of pedestrian comfort or discomfort in the proposed plaza area in terms of the undisturbed environment in the immediate vicinity.

Measurements are made with a single hot-wire anemometer mounted with its axis vertical. The instrumentation used is a Thermo Systems constant temperature anemometer (Model 1050) with a 0.001 in. diameter platinum film sensing element 0.020 in. long. Output is directed to the on-line data acquisition system for analysis.

Calibration of the hot-wire anemometer is performed by comparing output with the pitot-static tube in the wind tunnel. The calibration

data are fit to a variable exponent King's Law relationship of the form

$$E^2 = A + BU^n$$

where E is the hot-wire output voltage, U the velocity and A , B , and n are coefficients selected to fit the data. The above relationship was used to determine the mean velocity at measurement points using the measured mean voltage. The fluctuating velocity in the form U_{rms} (root-mean-square velocity) was obtained from

$$U_{rms} = \frac{2 E E_{rms}}{B n U^{n-1}}$$

where E_{rms} is the root-mean-square voltage output from the anemometer. For interpretation all turbulence measurements for pedestrian winds were divided by the mean velocity outside the boundary-layer U_{∞} . Turbulence intensity in velocity profile measurements used the local mean velocity.

4. RESULTS

4.1 Flow Visualization

A film is included as part of this report showing the characteristics of flow about the structure using smoke to make the flow visible. A listing of the contents of the film is shown in Table 1. Several features can be noted from the visualization. As with all large structures, wind approaching the building is deflected down to the plaza level, up over the structure and around the sides. A description of the smoke test results emphasizing flow patterns of concern relative to possible high-wind load areas and pedestrian comfort is given in Section 5.1.

4.2 Velocity

Velocity and turbulence profiles are shown in Figure 7. Profiles were taken upstream from the model which are characteristic of the boundary layer approaching the model and sometimes at the building site with building removed. The boundary-layer thickness, δ , is shown in Figure 7. The corresponding prototype value of δ for this study is also shown in the figure. This value was established as a reasonable height for this study. The mean velocity profile approaching the modeled area has the form

$$\frac{U}{U_{\infty}} = \left(\frac{z}{\delta}\right)^n .$$

The exponent n for the approach flow established for this study is shown in Figure 7.

Profiles of longitudinal turbulence intensity in the flow approaching the modeled area are shown in Figure 7. The turbulence intensities are appropriate for the approach mean velocity profile selected. For the velocity profiles, turbulence intensity is defined

as the root-mean-square about the mean of the longitudinal velocity fluctuations divided by the local mean velocity U ,

$$Tu = \frac{U_{rms}}{U} .$$

Velocity data obtained at each of the pedestrian measurement locations shown in Figure 4 are listed in Table 2 as mean velocity U/U_∞ , turbulence intensity U_{rms}/U_∞ , and largest effective gust

$$U_{pk} = \frac{U + 3U_{rms}}{U_\infty} .$$

These data are plotted in polar form in Figure 8. Measurements were taken 5 to 7 ft above the ground surface. An analysis of these wind data is given in Section 5.2.

To enable a quantitative assessment of the wind environment, the wind-tunnel data were combined with wind frequency and direction information obtained at the local airport. Table 3 shows wind frequency by direction and magnitude obtained from summaries published by the National Weather Service. These data, usually obtained at an elevation of about 30-40 ft, were converted to velocities at the reference velocity height for the wind-tunnel measurements and combined with the wind-tunnel data to obtain cumulative probability distributions (percent time a given velocity is exceeded) for wind velocity at each measuring location. The percentage times were summed by wind direction to obtain a percent time exceeded at each measuring position independent of wind direction (but accounting for the fact that the wind blows from different directions with varying frequency). These results are plotted in Figure 9.

Interpretation of Figure 9 is aided by a description of the effects of wind of various magnitudes on people. The earliest quantitative description of wind effects was established by Sir Francis Beaufort in 1806 for use at sea and is still in use today. Several recent investigators have added to the knowledge of wind effects on pedestrians. These investigations along with suggested criteria for acceptance have been summarized by Penwarden and Wise (4) and Melbourne (5). The Beaufort scale (from ref. 4), based on mean velocity only, is reproduced as Table 4 including qualitative descriptions of wind effects. Table 4 suggests that mean wind speeds below 12 mph are of minor concern and that mean speeds above 24 mph are definitely inconvenient. Quantitative criteria for acceptance from reference 5 are superimposed as dashed lines on Figure 9. The peak gust curves shown in Figure 9 are the percent of time during which a short gust of the stated magnitude could occur (say about one of these gusts per hour).

The overall indications of pedestrian wind comfort are best described by Figure 9, in particular the percent time exceeded plots which show the effective gust (mean plus 3σ). The mean velocity percent time exceeded plots are useful, but may present too severe a comparison to acceptance criteria because of conservative assumptions about anticipated turbulence intensities which were incorporated into the acceptance criteria. Implications of the data plotted in Figure 9 are presented in Section 5.2.

Because some pedestrian wind measuring positions are purposely chosen at sites where the smoke tests showed large velocities of small spacial extent, the general wind environment about the structure may be less severe than one might infer from a strict analysis of Table 2 and Figure 9.

4.3 Pressures

For each of the pressure taps examined at each wind direction, the data record is analyzed to obtain four separate pressure coefficients. The first is the mean pressure coefficient

$$C_{p_{\text{mean}}} = \frac{(p-p_{\infty})_{\text{mean}}}{0.5 \rho U_{\infty}^2}$$

where the symbols are as defined in the List of Symbols. It represents the mean of the instantaneous pressure difference between the building pressure tap and the static pressure in the wind tunnel above the building model, nondimensionalized by the dynamic pressure

$$0.5 \rho U_{\infty}^2$$

at the reference velocity position. This relationship produces a dimensionless coefficient which indicates that the mean pressure difference between building and ambient wind at a given point on the structure is some fraction less or some fraction greater than the undisturbed wind dynamic pressure near the upper edge of the boundary layer. Using the measured coefficient, prototype mean pressure values for any wind velocity may be calculated.

The magnitude of the fluctuating pressure is obtained by the rms pressure coefficient

$$C_{p_{\text{rms}}} = \frac{\left((p-p_{\infty}) - (p-p_{\infty})_{\text{mean}} \right)_{\text{rms}}}{0.5 \rho U_{\infty}^2}$$

in which the numerator is the root-mean-square of the instantaneous pressure difference about the mean.

If the pressure fluctuations followed a Gaussian probability distribution, no additional data would be required to predict the

frequency with which any given pressure level would be observed. However, the pressure fluctuations do not, in general, follow a Gaussian probability distribution so that additional information is required to show the extreme values of pressure expected. The peak maximum and peak minimum pressure coefficients are used to determine these values:

$$C_{p_{\max}} = \frac{(p-p_{\infty})_{\max}}{0.5 \rho U_{\infty}^2}$$

$$C_{p_{\min}} = \frac{(p-p_{\infty})_{\min}}{0.5 \rho U_{\infty}^2}$$

The values of $p-p_{\infty}$ which were digitized at 250 samples per second for 16 seconds, representing about one hour of time in the full-scale, are examined individually by the computer to obtain the most positive and most negative values during the 16-second period. These are converted to $C_{p_{\max}}$ and $C_{p_{\min}}$ by nondimensionalizing with the free stream dynamic pressure.

The four pressure coefficients are calculated by the on-line data acquisition system computer and tabulated along with the approach wind azimuth in degrees from true north. The list of coefficients is included as Appendix A. The pressure tap code numbers used in the appendix are explained in Figure 3.

To determine the largest peak loads acting at any point on the structure for cladding design purposes, the pressure coefficients for all wind directions were searched to obtain, at each pressure tap, the largest peak positive and peak negative pressure coefficients. Table 6 lists the larger values and associated wind directions. Included in Section 5.3 is an analysis of the coefficients of Table 6 including the maximum values obtained and where they occurred on the building.

The pressure coefficients of Table 6 can be converted to full-scale loads by multiplication by a suitable reference pressure selected for the field site. This reference pressure is represented in the equations for pressure coefficients by the $0.5 \rho U_{\infty}^2$ denominator. This value is the dynamic pressure associated with an hourly mean wind at the reference velocity measurement position at the edge of the boundary layer. In general, the method of arriving at a design reference pressure for a particular site involves selection of a design wind velocity, translation of the velocity to an hourly mean wind at the reference velocity location and conversion to a reference pressure. Selection of the design velocity can be made from statistical analysis of extreme wind data or selected from wind maps contained in the proposed wind loading code ANSI A58.1 of the American National Standards Institute (6). The calculation of reference pressure for this study is shown in Table 5. The factor used in Table 5 to reduce gust winds to hourly mean winds is given in reference (7).

The reference pressure associated with the design hourly mean velocity at the reference velocity location can be used directly with the peak-pressure coefficients to obtain peak local design wind loads for cladding design. Local, instantaneous peak loads on the full-scale building suitable for cladding design were computed by multiplying the reference pressure of Table 5 by the peak coefficients of Table 6 and are listed as peak pressures in that table. The maximum psf loads given at each tap location are the largest peak positive and peak negative values found in the tests. For ease in visualizing the loads on the structure, contours of equal peak pressures for cladding load shown in Table 6 have been plotted on developed elevation views of the structure,

Figure 10. If a data point which is taken in the basic model configuration is retaken in a resolution configuration, the data are averaged in preparing Figure 10. For control of water infiltration from outside to inside, the largest positive (inward acting) pressure at each tap location is tabulated in Table 6.

For glass design pressures, a glass load factor is used to account for the different duration between measured peak pressures and the one minute loading commonly used in glass design charts. The design pressure used for glass is normally less than the peak pressures used for cladding design because of the static fatigue property of glass which can withstand higher pressures for short duration loads than for long duration loads. Recent research (8) indicates that the period of application of the peak pressures reported herein is about 5-10 seconds or less. If a glass design is based on these peak-pressure values, then a glass strength associated with this duration load should be used. Because glass design charts are normally based on some alternate load duration--usually one minute--then some reduction in peak loads should be made. An estimate of a load reduction factor can be obtained from an empirical relation of glass strength as a function of load duration. Current glass selection charts showing glass strength as a function of load duration (9) and older references (10) indicate the following load reduction factors:

	ref. 9	ref. 10
annealed float	0.80	0.81
heat strengthened	0.94	
tempered	0.97	0.98

Loadings appropriate for glass design can be computed by multiplying the peak-pressure loads of Table 6 by these load factors.

4.4 Forces and Moments

Force coefficients in the horizontal X and Y directions and moment coefficients about the X, Y, and Z axes with the origin at ground level at the base of the building with Z axis vertical may be computed for all wind directions tested by integration of mean pressures on the building. Overall forces and moments acting on the full-scale building due to wind loading which are useful in designing the structural framing of the proposed building may be obtained from use of these coefficients.

Force coefficients were computed for each floor for each wind direction using the equations shown below.

$$CF_X = \frac{F_X}{A_R 0.5 \rho U_\infty^2} \quad CF_Y = \frac{F_Y}{A_R 0.5 \rho U_\infty^2}$$

Terms and symbols used in the equations are defined in the List of Symbols and the axes are defined for the building in Figure 12. Force coefficients CF_X and CF_Y were computed for the horizontal forces acting along the X and Y axes using the mean pressure coefficient at each pressure tap. A_R represents a constant reference area for nondimensionalization of the forces and moments.

The total forces acting on the full-scale building for each floor and wind direction were computed by multiplying the above coefficients by the appropriate full-scale reference area, by the reference pressure of Table 5, and by a gust load factor selected for an appropriate wind gust duration. The gust load factor, shown in Table 5, was selected to increase the loads from an hourly mean load to that of a gust whose duration would be sufficient for its effect to be fully felt by the structure. A table of gust load factors for various gust durations is

incorporated in Table 5 so that force and moment data of Table 7 may be adjusted to a different load duration if desired.

The forces obtained at each floor were used to obtain load, shear, and moment diagrams for the building for each wind direction. The shear diagram, in kips, was obtained by algebraic sum of all forces in each coordinate direction acting above the floor of interest. The load diagram, in psf, was obtained by dividing the shear values by their contributing areas (listed in Table 7). The moment diagram, in 1000 ft-kips, was obtained by integration of the shear values so that the moment due to forces acting above the floor level of interest was calculated. The sign of the moment was established by the right-hand rule about an X' , Y' axis through the floor of interest. Moments about the Z axis were calculated by considering the displacement of forces in the X and Y directions from the Z axis shown in Figure 12. Eccentricities were computed such that the product of the Y force and X eccentricity minus the product of the X force and Y eccentricity equaled the Z moment. Load, shear, and moment diagrams are shown in Figure 13 for several wind directions.

5. DISCUSSION

5.1 Flow Visualization

Flow patterns identified with smoke showed that largest pressures would most likely be found near corners of the tower. These pressures are due to flow separation and vortex formation phenomena. Flow separation occurs when the wind is unable to turn a sharp corner on the building and separates from the surface. Elevated negative (outward acting) pressures are often found under the separated flow near the point of separation. High velocity and large curvature in the separated flow contribute to the local elevated pressures. Flow visualization showed high velocity flow separation at the building corners of both the towers and low-rise structures. Elevated pressures may thus be found anywhere along complex corners.

Vortex formation can occur when flow separation occurs at a building corner where the separated flow can take on a three-dimensional character. The separated wind flow can sometimes roll up into a tornado-like shape called a vortex at these locations. Very high negative pressures can often be found on the building surface under a vortex flow. Vortices were observed at the point where the tower corners on Three Lakeway Center (3LC) intersected the low-rise roof, at low-rise corners of 3LC near the stairwells, and at other three-dimensional corners of the project.

Winds in pedestrian areas at ground level were largest near corners of the new and existing towers. These winds were due to the downward deflection of higher velocity winds from near the tops of the towers. Wind speeds in the covered entry areas at the base of the new tower were low. The 3LC building appeared to increase winds only in areas near the

tower base. Winds on the 3LC low-rise roof were quite strong near corners of the tower.

5.2 Pedestrian Winds

Figure 4 shows the 29 locations selected for investigation of pedestrian wind comfort. Locations 1-16, 19, 20, 24 and 26 were measured without the 3LC building in place. All 29 locations were measured with the 3LC in place. Location 29 was positioned under a building overhang. Locations 15 and 20 were located on top of a garage deck.

Table 2 and Figure 8 show that the large mean velocities (as a percentage of the mean velocity U_{∞} at a height of 900 ft) were measured at several locations both with and without 3LC in place. Values above 70 percent of U_{∞} are quite large. These velocities can be compared to 40 to 45 percent which might be found in an open-country environment. The largest gust velocities, represented by the mean plus 3 rms as discussed in Section 4.2, were 130 to 150 percent of U_{∞} . Values above about 120 percent are rather large in comparison to values of 80 to 90 percent in an open-country environment.

Velocity data of Table 2 integrated with local wind data listed in Table 3 are shown in Figure 9. As pointed out in Section 4.2, the most important comparison with acceptance criteria is in the gust graph on the right in each page. Based on the data of this figure, the windiest pedestrian locations for gust winds should be 22 on the 3LC low-rise roof which exceeds the acceptable limit about three percent of the time. Gust winds for all other locations were within the acceptable level. Addition of 3LC caused gust wind speeds to decrease at locations 3, 6, 7, 9 and 11 in the current complex, to remain at about the same level at

locations 1, 2, 4, 5 and 8 in the current complex, to increase at locations 10, 15 (small increase), 12, 13, 14 (significant increase) in the current complex, and to increase at locations 16, 19, 24 and 26 about the 3LC building. The increases at locations 12, 13 and 14 brought fairly low winds up to levels typically seen at other project locations. Winds about the 3LC will be larger than existed on the flat land there before construction, but will not be significantly different from those in the existing Lakeway complex.

The overall conclusions obtained from the pedestrian wind analysis are that Three Lakeway Center 1) will decrease wind speeds in some areas of the existing complex, particularly between One and Two Lakeway Center; 2) will increase winds significantly only at locations 12, 13 and 14, which will become about as windy as other locations in the existing complex; and 3) will not induce winds about its base to levels significantly higher than those currently existing about One and Two Lakeway Center.

5.3 Wind Loads

Table 6 shows the largest peak pressure coefficients and corresponding loads measured on the building complex for each pressure tap location. Data configurations are identified in Table 1. Data identified as Configuration A in Table 6 and Appendix A represent data obtained at all pressure tap locations on all three Lakeway Center buildings for 36 wind directions. Configuration B represents data obtained at selected taps at 2-degree azimuthal increments near azimuths where large pressure peaks were observed in Configuration A to ensure that the largest peaks were obtained. Configuration D measured limited data on 3LC on taps added after the initial data was obtained.

The largest peak pressure obtained on the 3LC tower was -142 psf at tap 3681 on a corner of the low-rise. This location was observed in flow visualization to have a vortex present which might be expected to cause elevated pressures. The largest peak pressures on the One and Two Lakeway buildings were -96 and -118 psf respectively.

Figure 10 shows the distribution of peak negative and peak positive pressures over the surface of the Lakeway Center complex. Most of the area of the three buildings had peak negative pressures less than -60 psf with higher pressures restricted to limited areas. Typical peak positive pressures were less than +30 psf.

The wind pressures shown in Table 6 and Figure 10 represent external pressures. Internal pressures on buildings are controlled by the air handling system in combination with infiltration through the curtainwall and any openings in the curtainwall associated with operable doors or windows which are left open during a wind storm. Figure 11 shows pressure zones which are rectangular pressure areas which account for both internal and external pressures. Internal pressures were assumed to be controlled primarily by infiltration and the air handling system. Values of ± 5 psf were allotted for internal pressures.

Figure 13 shows frame pressure, shear and moment distributions plotted from Table 7 for the largest base shears in the x and y coordinate directions on each tower. The coordinate systems are shown in Figure 12. For wind direction 190 where the x shear reached its maximum, the y shear remained at a similar magnitude. As shown on the summary page of Table 7, the torsional moments were moderate but tended to be largest simultaneously with large base shears.

REFERENCES

1. Cermak, J. E., "Laboratory Simulation of the Atmospheric Boundary Layer," AIAA Jl., Vol. 9, September 1971.
2. Cermak, J. E., "Applications of Fluid Mechanics to Wind Engineering," A Freeman Scholar Lecture, ASME Jl. of Fluids Engineering, Vol. 97, No. 1, March 1975.
3. Cermak, J. E., "Aerodynamics of Buildings," Annual Review of Fluid Mechanics, Vol. 8, 1976, pp. 75-106.
4. Penwarden, A. D., and Wise, A. F. E., "Wind Environment Around Buildings," Building Research Establishment Report, HMSO, 1975.
5. Melbourne, W. H., "Criteria for Environmental Wind Conditions," Jl. Industrial Aerodynamics, Vol. 3, pp. 241-247, 1978.
6. American National Standards Institute, "American National Standard Building Code Requirements for Minimum Design Loads in Buildings and Other Structures," ANSI Standard A58.1, 1982.
7. Hollister, S. C., "The Engineering Interpretation of Weather Bureau Records for Wind Loading on Structures," Building Science Series 30--Wind Loads on Buildings and Structures, National Bureau of Standards, pp. 151-164, 1970.
8. Peterka, J. A., and Cermak, J. E., "Peak-Pressure Duration in Separated Regions on a Structure," U.S.-Japan Research Seminar on Wind Effects on Structures, Kyoto, Japan, 9-13 September 1974; Report CEP74-75JAP-JEC8, Fluid Mechanics Program, Colorado State University, September 1974.
9. PPG Glass Thickness Recommendations to Meet Architects' Specified 1-Minute Wind Load, Pittsburgh Plate Glass Industries, April 1979.
10. Shand, E. B., "Glass Engineering Handbook," Second Edition, McGraw-Hill, New York, P. 51, 1958.

FIGURES







Figure 1. FLUID DYNAMICS AND DIFFUSION LABORATORY
COLORADO STATE UNIVERSITY



PLAN




All Dimensions in m

ELEVATION

INDUSTRIAL AERODYNAMICS WIND TUNNEL

Figure 2. Wind-Tunnel Configuration


NOTE: Taps are located 2.5 (.10) or 7.5 (.30) from the edge or on the centerline of the surface unless noted.



ONE LAKEWAY CENTER

Figure 3b. Pressure Tap Locations


Note: Darkened taps are dimensioned and numbered on another view.



EAST

ONE LAKEWAY CENTER


Figure 3c. Pressure Tap Locations



SOUTHEAST


ONE LAKEWAY CENTER

Figure 3d. Pressure Tap Locations



ONE LAKEWAY CENTER


Figure 3e. Pressure Tap Locations



WEST

ONE LAKEWAY CENTER

Figure 3f. Pressure Tap Locations



ROOF

NORTH




Total taps = 357

Model scale = 1/300

Dimensions are in full scale feet and (model inches).

TWO LAKEWAY CENTER

Figure 3g. Pressure Tap Locations




Note :

Parapet is 2.5 (.10) wide.

Taps are 2.5 (.10) from edges or on centerline
of surface unless noted.

TWO LAKEWAY CENTER


Figure 3h. Pressure Tap Locations



SOFFIT

TWO LAKEWAY CENTER

Figure 3i. Pressure Tap Locations



Note :


All dimensions are true length.

Darkened taps are identified and located in another view.

Taps are located 2.5(.10) or 7.5(.30) from edges or on the centerline of the surface unless noted.

TWO LAKEWAY CENTER


Figure 3j. Pressure Tap Locations



EAST

TWO LAKEWAY CENTER


Figure 3k. Pressure Tap Locations



SOUTH

TWO LAKEWAY CENTER


Figure 3l. Pressure Tap Locations



WEST

TWO LAKEWAY CENTER

Figure 3m. Pressure Tap Locations




Total Taps = 569
 Model scale = 1/300
 Dimensions in full scale feet and
 (model inches)

TOWER ROOF

Note : Angles are 45°

THREE LAKEWAY CENTER

Figure 3n. Pressure Tap Locations



NORTH TOWER


Note: All taps are located 2.5(.10) or 7.5 (.30) from nearest edge or on the centerline of the surface unless noted.

THREE LAKEWAY CENTER

Figure 30. Pressure Tap Locations

THREE LAKEWAY CENTER


Figure 3p. Pressure Tap Locations



NORTHWEST TOWER

THREE LAKEWAY CENTER


Figure 3q. Pressure Tap Locations



SOUTHWEST TOWER


THREE LAKEWAY CENTER

Figure 3r. Pressure Tap Locations



SOUTH TOWER
THREE LAKEWAY CENTER


Figure 3s. Pressure Tap Locations



SOUTHEAST TOWER

THREE LAKEWAY CENTER

Figure 3t. Pressure Tap Locations



NORTHEAST TOWER

THREE LAKEWAY CENTER


Figure 3u. Pressure Tap Locations



Peripheral taps are bilaterally symmetrical with respect to NS and EW axis.

THREE LAKEWAY CENTER


Figure 3v. Pressure Tap Locations



NORTH LOWRISE

THREE LAKEWAY CENTER


Figure 3w. Pressure Tap Locations



EAST LOWRISE


THREE LAKEWAY CENTER

Figure 3x. Pressure Tap Locations



SOUTH LOWRISE
THREE LAKEWAY CENTER

Figure 3y. Pressure Tap Locations



THREE LAKEWAY CENTER

Figure 3z. Pressure Tap Locations




Figure 4. Building Location and Pedestrian Wind Velocity Measuring Positions





Figure 5a. Completed Model in Wind Tunnel




Figure 5b. Completed Model in Wind Tunnel




Figure 6. Data Sampling Time Verification




Figure 7a. Mean Velocity and Turbulence Profiles Approaching the Model





Figure 7b. Mean Velocity and Turbulence Profiles Approaching the Model





Figure 7c. Mean Velocity and Turbulence Profiles Approaching the Model

THREE LAKEWAY CENTER IN PLACE - CONFIGURATION A





Figure 8a. Mean Velocities and Turbulence Intensities at Pedestrian Locations 1 and 2

THREE LAKEWAY CENTER IN PLACE - CONFIGURATION A




Figure 8b. Mean Velocities and Turbulence Intensities at Pedestrian Locations 3 and 4

THREE LAKEWAY CENTER IN PLACE - CONFIGURATION A




Figure 8c. Mean Velocities and Turbulence Intensities at Pedestrian Locations 5 and 6

THREE LAKEWAY CENTER IN PLACE - CONFIGURATION A




Figure 8d. Mean Velocities and Turbulence Intensities at Pedestrian Locations 7 and 8

THREE LAKEWAY CENTER IN PLACE - CONFIGURATION A





Figure 8e. Mean Velocities and Turbulence Intensities at Pedestrian Locations 9 and 10

THREE LAKEWAY CENTER IN PLACE - CONFIGURATION A





Figure 8f. Mean Velocities and Turbulence Intensities at Pedestrian Locations 11 and 12

THREE LAKEWAY CENTER IN PLACE - CONFIGURATION A

$$\frac{U_{mean}}{U_{inf}}$$


Location 13

$$\frac{U_{mean} + 3*U_{rms}}{U_{inf}}$$

.25/Div

$$\frac{U_{rms}}{U_{inf}}$$

.05/Div



$$\frac{U_{mean}}{U_{inf}}$$

Location 14

$$\frac{U_{mean} + 3*U_{rms}}{U_{inf}}$$

.25/Div

$$\frac{U_{rms}}{U_{inf}}$$

.05/Div




Figure 8g. Mean Velocities and Turbulence Intensities at Pedestrian Locations 13 and 14

THREE LAKEWAY CENTER IN PLACE - CONFIGURATION A




Figure 8h. Mean Velocities and Turbulence Intensities at Pedestrian Locations 15 and 16

THREE LAKEWAY CENTER IN PLACE - CONFIGURATION A




Figure 8i. Mean Velocities and Turbulence Intensities at Pedestrian Locations 17 and 18

THREE LAKEWAY CENTER IN PLACE - CONFIGURATION A




Figure 8j. Mean Velocities and Turbulence Intensities at Pedestrian Locations 19 and 20

THREE LAKEWAY CENTER IN PLACE - CONFIGURATION A





Figure 8k. Mean Velocities and Turbulence Intensities at Pedestrian Locations 21 and 22

THREE LAKEWAY CENTER IN PLACE - CONFIGURATION A




Figure 81. Mean Velocities and Turbulence Intensities at Pedestrian Locations 23 and 24

THREE LAKEWAY CENTER IN PLACE - CONFIGURATION A




Figure 8m. Mean Velocities and Turbulence Intensities at Pedestrian Locations 25 and 26

THREE LAKEWAY CENTER IN PLACE - CONFIGURATION A






Figure 8n. Mean Velocities and Turbulence Intensities at Pedestrian Locations 27 and 28

THREE LAKEWAY CENTER IN PLACE - CONFIGURATION A




THREE LAKEWAY CENTER NOT IN PLACE - CONFIGURATION D

Figure 8a. Mean Velocities and Turbulence Intensities at Pedestrian Locations 1 and 2


THREE LAKEWAY CENTER NOT IN PLACE - CONFIGURATION D

Figure 8b. Mean Velocities and Turbulence Intensities at Pedestrian Locations 3 and 4


THREE LAKEWAY CENTER NOT IN PLACE - CONFIGURATION D

Figure 8c. Mean Velocities and Turbulence Intensities at Pedestrian Locations 5 and 6


THREE LAKEWAY CENTER NOT IN PLACE - CONFIGURATION D

Figure 8d. Mean Velocities and Turbulence Intensities at Pedestrian Locations 7 and 8



THREE LAKEWAY CENTER NOT IN PLACE - CONFIGURATION D

Figure 8e. Mean Velocities and Turbulence Intensities at Pedestrian Locations 9 and 10



THREE LAKEWAY CENTER NOT IN PLACE - CONFIGURATION D

Figure 8f. Mean Velocities and Turbulence Intensities at Pedestrian Locations 11 and 12


THREE LAKEWAY CENTER NOT IN PLACE - CONFIGURATION D

Figure 8g. Mean Velocities and Turbulence Intensities at Pedestrian Locations 13 and 14


THREE LAKEWAY CENTER NOT IN PLACE - CONFIGURATION D

Figure 8h. Mean Velocities and Turbulence Intensities at Pedestrian Locations 15 and 16


THREE LAKEWAY CENTER NOT IN PLACE - CONFIGURATION D

Figure 8i. Mean Velocities and Turbulence Intensities at Pedestrian Locations 19 and 20


THREE LAKEWAY CENTER NOT IN PLACE - CONFIGURATION D

Figure 8j. Mean Velocities and Turbulence Intensities at Pedestrian Locations 24 and 26





Figure 9a. Wind Velocity Probabilities for Pedestrian Locations





Figure 9b. Wind Velocity Probabilities for Pedestrian Locations





Figure 9c. Wind Velocity Probabilities for Pedestrian Locations





Figure 9d. Wind Velocity Probabilities for Pedestrian Locations





Figure 9e. Wind Velocity Probabilities for Pedestrian Locations





Figure 9f. Wind Velocity Probabilities for Pedestrian Locations





Figure 9g. Wind Velocity Probabilities for Pedestrian Locations





Figure 9h. Wind Velocity Probabilities for Pedestrian Locations





Figure 9i. Wind Velocity Probabilities for Pedestrian Locations





Figure 9j. Wind Velocity Probabilities for Pedestrian Locations




Figure 10a. Peak Pressure Distribution on the Building for Cladding Loads

ONE LAKEWAY CENTER
 NORTH ELEVATION
 PEAK NEGATIVE LOADS (PSF)
 FOR 50 YEAR RECURRENCE WIND
 WITH WIND DIRECTIONALITY
 REFERENCE PRESSURE = 38 PSF




Figure 10b. Peak Pressure Distribution on the Building
 for Cladding Loads

ONE LAKEWAY CENTER
EAST ELEVATION
PEAK NEGATIVE LOADS (PSF)
FOR 50 YEAR RECURRENCE WIND
WITH WIND DIRECTIONALITY
REFERENCE PRESSURE = 38 PSF




Figure 10c. Peak Pressure Distribution on the Building
for Cladding Loads

ONE LAKEWAY CENTER
SOUTH-EAST ELEVATION
PEAK NEGATIVE LOADS (PSF)
FOR 50 YEAR RECURRENCE WIND
WITH WIND DIRECTIONALITY
REFERENCE PRESSURE = 38 PSF




Figure 10d. Peak Pressure Distribution on the Building
for Cladding Loads

ONE LAKEWAY CENTER
 SOUTH ELEVATION
 PEAK NEGATIVE LOADS (PSF)
 FOR 50 YEAR RECURRENCE WIND
 WITH WIND DIRECTIONALITY
 REFERENCE PRESSURE = 38 PSF




Figure 10e. Peak Pressure Distribution on the Building
 for Cladding Loads

ONE LAKEWAY CENTER
 WEST ELEVATION
 PEAK NEGATIVE LOADS (PSF)
 FOR 50 YEAR RECURRENCE WIND
 WITH WIND DIRECTIONALITY
 REFERENCE PRESSURE = 38 PSF




Figure 10f. Peak Pressure Distribution on the Building
 for Cladding Loads




Figure 10g. Peak Pressure Distribution on the Building for Cladding Loads

ONE LAKEWAY CENTER
NORTH ELEVATION
PEAK POSITIVE LOADS (PSF)
FOR 50 YEAR RECURRENCE WIND
WITH WIND DIRECTIONALITY
REFERENCE PRESSURE = 38 PSF




Figure 10h. Peak Pressure Distribution on the Building
for Cladding Loads

ONE LAKEWAY CENTER
EAST ELEVATION
PEAK POSITIVE LOADS (PSF)
FOR 50 YEAR RECURRENCE WIND
WITH WIND DIRECTIONALITY
REFERENCE PRESSURE = 38 PSF




Figure 10i. Peak Pressure Distribution on the Building
for Cladding Loads

ONE LAKEWAY CENTER
SOUTH-EAST ELEVATION
PEAK POSITIVE LOADS (PSF)
FOR 50 YEAR RECURRENCE WIND
WITH WIND DIRECTIONALITY
REFERENCE PRESSURE = 38 PSF




Figure 10j. Peak Pressure Distribution on the Building
for Cladding Loads

ONE LAKEWAY CENTER
SOUTH ELEVATION
PEAK POSITIVE LOADS (PSF)
FOR 50 YEAR RECURRENCE WIND
WITH WIND DIRECTIONALITY
REFERENCE PRESSURE = 38 PSF




Figure 10k. Peak Pressure Distribution on the Building
for Cladding Loads

ONE LAKEWAY CENTER
WEST ELEVATION
PEAK POSITIVE LOADS (PSF)
FOR 50 YEAR RECURRENCE WIND
WITH WIND DIRECTIONALITY
REFERENCE PRESSURE = 38 PSF






Figure 102. Peak Pressure Distribution on the Building
for Cladding Loads




Roof Peak Negative Cladding Loads (PSF) for 50 Year Recurrence Wind with Wind Directionality
Reference Pressure = 38 PSF

Figure 10m. Peak Pressure Distribution on the Building
for Cladding Loads




Soffit
 Two Lakeway Center
 Peak Negative Cladding Loads (PSF) for 50 Year Recurrence Wind
 with Wind Directionality
 Reference Pressure = 38 PSF

Figure 10n. Peak Pressure Distribution on the Building
 for Cladding Loads




TWO LAKEWAY CENTER
 NORTH ELEVATION
 PEAK NEGATIVE CLADDING LOADS (PSF)
 FOR 50 YEAR RECURRENCE WIND
 WITH WIND DIRECTIONALITY
 REFERENCE PRESSURE = 38 PSF

Figure 10o. Peak Pressure Distribution on the Building
 for Cladding Loads




TWO LAKEWAY CENTER
 EAST ELEVATION
 PEAK NEGATIVE CLADDING LOADS (PSF)
 FOR 50 YEAR RECURRENCE WIND
 WITH WIND DIRECTIONALITY
 REFERENCE PRESSURE = 38 PSF

Figure 10p. Peak Pressure Distribution on the Building
 for Cladding Loads




TWO LAKEWAY CENTER
 SOUTH ELEVATION
 PEAK NEGATIVE CLADDING LOADS (PSF)
 FOR 50 YEAR RECURRENCE WIND
 WITH WIND DIRECTIONALITY
 REFERENCE PRESSURE = 38 PSF

Figure 10q. Peak Pressure Distribution on the Building
 for Cladding Loads




TWO LAKEWAY CENTER
 WEST ELEVATION
 PEAK NEGATIVE CLADDING LOADS (PSF)
 FOR 50 YEAR RECURRENCE WIND
 WITH WIND DIRECTIONALITY
 REFERENCE PRESSURE = 38 PSF

Figure 10r. Peak Pressure Distribution on the Building
 for Cladding Loads



Roof Two Lakeway Center
 Peak Positive Cladding Loads (PSF) for 50 Year
 Recurrence Wind with Wind Directionality
 Reference Pressure = 38 PSF


Figure 10s. Peak Pressure Distribution on the Building
 for Cladding Loads



Soffit
 Peak Positive Cladding Loads (PSF) for 50 Year Recurrence
 Wind with Wind Directionality
 Reference Pressure = 38 PSF


Two Lakeway Center

Figure 10t. Peak Pressure Distribution on the Building
 for Cladding Loads




TWO LAKEWAY CENTER
 NORTH ELEVATION
 PEAK POSITIVE CLADDING LOADS (PSF)
 FOR 50 YEAR RECURRENCE WIND
 WITH WIND DIRECTIONALITY
 REFERENCE PRESSURE = 38 PSF

Figure 10u. Peak Pressure Distribution on the Building
 for Cladding Loads




TWO LAKEWAY CENTER
 EAST ELEVATION
 PEAK POSITIVE CLADDING LOADS (PSF)
 FOR 50 YEAR RECURRENCE WIND
 WITH WIND DIRECTIONALITY
 REFERENCE PRESSURE = 38 PSF

Figure 10v. Peak Pressure Distribution on the Building
 for Cladding Loads





TWO LAKEWAY CENTER
 SOUTH ELEVATION
 PEAK POSITIVE CLADDING LOADS (PSF)
 FOR 50 YEAR RECURRENCE WIND
 WITH WIND DIRECTIONALITY
 REFERENCE PRESSURE = 38 PSF

Figure 10w. Peak Pressure Distribution on the Building
 for Cladding Loads



TWO LAKEWAY CENTER
 WEST ELEVATION
 PEAK POSITIVE CLADDING LOADS (PSF)
 FOR 50 YEAR RECURRENCE WIND
 WITH WIND DIRECTIONALITY
 REFERENCE PRESSURE = 38 PSF

Figure 10x. Peak Pressure Distribution on the Building for Cladding Loads




TOWER ROOF

Negative peak cladding loads for 50 year recurrence wind.
Reference pressure = 38 psf with wind directionality.

THREE LAKEWAY CENTER

Figure 10y. Peak Pressure Distribution on the Building for Cladding Loads



LOWRISE ROOF

Negative peak cladding loads for 50 year recurrence
wind. Reference pressure = 38 psf with wind directionality.

THREE LAKEWAY CENTER

Figure 10z. Peak Pressure Distribution on the Building for Cladding Loads

THREE LAKEWAY CENTER
TOWER . NORTH-WEST ELEVATION
PEAK NEGATIVE CLADDING LOADS (PSF)
FOR 50 YEAR RECURRENCE WIND
WITH WIND DIRECTIONALITY
REFERENCE PRESSURE = 38 PSF




Figure 10aa. Peak Pressure Distribution on the Building
for Cladding Loads

THREE LAKEWAY CENTER
TOWER . NORTH-EAST ELEVATION
PEAK NEGATIVE CLADDING LOADS (PSF)
FOR 50 YEAR RECURRENCE WIND
WITH WIND DIRECTIONALITY
REFERENCE PRESSURE = 38 PSF




Figure 10cc. Peak Pressure Distribution on the Building
for Cladding Loads

THREE LAKEWAY CENTER
TOWER . SOUTH-EAST ELEVATION
PEAK NEGATIVE CLADDING LOADS (PSF)
FOR 50 YEAR RECURRENCE WIND
WITH WIND DIRECTIONALITY
REFERENCE PRESSURE = 38 PSF




Figure 10dd. Peak Pressure Distribution on the Building
for Cladding Loads

THREE LAKEWAY CENTER
 TOWER . SOUTH ELEVATION
 PEAK NEGATIVE CLADDING LOADS (PSF)
 FOR 50 YEAR RECURRENCE WIND
 WITH WIND DIRECTIONALITY
 REFERENCE PRESSURE = 38 PSF




Figure 10ee. Peak Pressure Distribution on the Building
 for Cladding Loads

THREE LAKEWAY CENTER
TOWER . SOUTH-WEST ELEVATION
PEAK NEGATIVE CLADDING LOADS (PSF)
FOR 50 YEAR RECURRENCE WIND
WITH WIND DIRECTIONALITY
REFERENCE PRESSURE = 38 PSF




Figure 10ff. Peak Pressure Distribution on the Building
for Cladding Loads

THREE LAKEWAY CENTER
 LOWRISE . NORTH ELEVATION
 PEAK NEGATIVE CLADDING LOADS (PSF)
 FOR 50 YEAR RECURRENCE WIND
 WITH WIND DIRECTIONALITY
 REFERENCE PRESSURE = 38 PSF





Figure 10gg. Peak Pressure Distribution on the Building
 for Cladding Loads



THREE LAKEWAY CENTER
 LOWRISE . SOUTH ELEVATION
 PEAK NEGATIVE CLADDING LOADS (PSF)
 FOR 50 YEAR RECURRENCE WIND
 WITH WIND DIRECTIONALITY
 REFERENCE PRESSURE = 38 PSF




Figure 10ii. Peak Pressure Distribution on the Building
 for Cladding Loads

THREE LAKEWAY CENTER
 LOWRISE . WEST ELEVATION
 PEAK NEGATIVE CLADDING LOADS (PSF)
 FOR 50 YEAR RECURRENCE WIND
 WITH WIND DIRECTIONALITY
 REFERENCE PRESSURE = 38 PSF






Figure 10jj. Peak Pressure Distribution on the Building
 for Cladding Loads





TOWER ROOF

Positive peak cladding loads for 50 year recurrence wind. Reference pressure = 38 psf with wind directionality.

THREE LAKEWAY CENTER

Figure 10kk. Peak Pressure Distribution on the Building for Cladding Loads



LOWRISE ROOF

Positive peak cladding loads for 50 year recurrence wind. Reference pressure = 38psf with wind directionality.

THREE LAKEWAY CENTER

Figure 10ll. Peak Pressure Distribution on the Building for Cladding Loads

THREE LAKEWAY CENTER
TOWER . NORTH-WEST ELEVATION
PEAK POSITIVE CLADDING LOADS (PSF)
FOR 50 YEAR RECURRENCE WIND
WITH WIND DIRECTIONALITY
REFERENCE PRESSURE = 38 PSF




Figure 10mm. Peak Pressure Distribution on the Building
for Cladding Loads

THREE LAKEWAY CENTER
 TOWER . NORTH ELEVATION
 PEAK POSITIVE CLADDING LOADS (PSF)
 FOR 50 YEAR RECURRENCE WIND
 WITH WIND DIRECTIONALITY
 REFERENCE PRESSURE = 38 PSF




Figure 10nn. Peak Pressure Distribution on the Building
 for Cladding Loads

THREE LAKEWAY CENTER
 TOWER . NORTH-EAST ELEVATION
 PEAK POSITIVE CLADDING LOADS (PSF)
 FOR 50 YEAR RECURRENCE WIND
 WITH WIND DIRECTIONALITY
 REFERENCE PRESSURE = 38 PSF




Figure 1000. Peak Pressure Distribution on the Building
 for Cladding Loads

THREE LAKEWAY CENTER
TOWER . SOUTH-EAST ELEVATION
PEAK POSITIVE CLADDING LOADS (PSF)
FOR 50 YEAR RECURRENCE WIND
WITH WIND DIRECTIONALITY
REFERENCE PRESSURE = 38 PSF




Figure 10pp. Peak Pressure Distribution on the Building
for Cladding Loads

THREE LAKEWAY CENTER
TOWER . SOUTH ELEVATION
PEAK POSITIVE CLADDING LOADS (PSF)
FOR 50 YEAR RECURRENCE WIND
WITH WIND DIRECTIONALITY
REFERENCE PRESSURE = 38 PSF




Figure 10qq. Peak Pressure Distribution on the Building
for Cladding Loads

THREE LAKEWAY CENTER
TOWER . SOUTH-WEST ELEVATION
PEAK POSITIVE CLADDING LOADS (PSF)
FOR 50 YEAR RECURRENCE WIND
WITH WIND DIRECTIONALITY
REFERENCE PRESSURE = 38 PSF




Figure 10rr. Peak Pressure Distribution on the Building
for Cladding Loads

THREE LAKEWAY CENTER
 LOWRISE . NORTH ELEVATION
 PEAK POSITIVE CLADDING LOADS (PSF)
 FOR 50 YEAR RECURRENCE WIND
 WITH WIND DIRECTIONALITY
 REFERENCE PRESSURE = 38 PSF




Figure 10ss. Peak Pressure Distribution on the Building
 for Cladding Loads

THREE LAKEWAY CENTER
LOWRISE . EAST ELEVATION
PEAK POSITIVE CLADDING LOADS (PSF)
FOR 50 YEAR RECURRENCE WIND
WITH WIND DIRECTIONALITY
REFERENCE PRESSURE = 38 PSF




Figure 10tt. Peak Pressure Distribution on the Building
for Cladding Loads

THREE LAKEWAY CENTER
LOWRISE . SOUTH ELEVATION
PEAK POSITIVE CLADDING LOADS (PSF)
FOR 50 YEAR RECURRENCE WIND
WITH WIND DIRECTIONALITY
REFERENCE PRESSURE = 38 PSF




Figure 10uu. Peak Pressure Distribution on the Building
for Cladding Loads

THREE LAKEWAY CENTER
LOWRISE . WEST ELEVATION
PEAK POSITIVE CLADDING LOADS (PSF)
FOR 50 YEAR RECURRENCE WIND
WITH WIND DIRECTIONALITY
REFERENCE PRESSURE = 38 PSF




Figure 10vv. Peak Pressure Distribution on the Building
for Cladding Loads




Figure 11a. Peak Cladding Pressure Zones




Figure 11b. Peak Cladding Pressure Zones




Figure 11c. Peak Cladding Pressure Zones




Figure 11d. Peak Cladding Pressure Zones




Figure 11e. Peak Cladding Pressure Zones





Figure 12a. Coordinate System for Forces and Moments



TWO LAKEWAY CENTER

Figure 12b. Coordinate System for Forces and Moments




Figure 12c. Coordinate System for Forces and Moments




Figure 13a. Load, Shear, and Moment Diagrams for Selected Wind Directions




Figure 13b. Load, Shear, and Moment Diagrams for Selected Wind Directions




Figure 13c. Load, Shear, and Moment Diagrams for Selected Wind Directions




Figure 13d. Load, Shear, and Moment Diagrams for Selected Wind Directions




Figure 13e. Load, Shear, and Moment Diagrams for Selected Wind Directions




Figure 13f. Load, Shear, and Moment Diagrams for Selected Wind Directions

TABLES

TABLE 1
Data Configurations

Configuration A:

- Geometry - One, Two and Three Lakeway in place.
- Pressures - Data measured for 36 wind directions in 10-degree increments from 0, for all tap locations on One, Two, and Three Lakeway.
- Velocities - Pedestrian winds measured for 16 wind directions, in 22.5-degree increments from 0, for locations 1-29 (Figure 4).

Configuration B:

- Geometry - One, Two, and Three Lakeway in place (same as Configuration A).
- Pressures - Data measured in 2-degree increments to both sides of selected wind directions for selected taps on Two and Three Lakeway where large pressure peaks were observed in Configuration A. Taps were selected to obtain the largest peak pressures on the structure.

Configuration C:

- Geometry - One, Two, and Three Lakeway in place (same as Configuration A).
- Pressures - Data measured in 5-degree increments to both sides of selected wind directions for added taps on Three Lakeway where large pressure peaks were observed in Configuration A.

Configuration D:

- Geometry - Three Lakeway out.
- Velocities - Pedestrian winds measured for 16 wind directions, in 22.5-degree increments for locations 1-16, 19-20, 24, and 26 (Figure 4).

TABLE 2--PEDESTRIAN WIND VELOCITIES AND TURBULENCE INTENSITIES
LAKEWAY CENTER WITHOUT THREE LAKEWAY

LOCATION 1				LOCATION 2			
WIND AZIMUTH	U _{MEAN} /U _{INF} (PERCENT)	U _{RMS} /U _{INF} (PERCENT)	U _{MEAN} +3*U _{RMS} /U _{INF} (PERCENT)	WIND AZIMUTH	U _{MEAN} /U _{INF} (PERCENT)	U _{RMS} /U _{INF} (PERCENT)	U _{MEAN} +3*U _{RMS} /U _{INF} (PERCENT)
0.00	84.2	11.3	118.0	0.00	16.8	8.4	42.0
22.50	75.1	12.7	113.2	22.50	25.5	12.2	62.1
45.00	80.7	11.1	113.9	45.00	36.7	12.1	72.9
67.50	74.6	15.5	121.1	67.50	30.9	14.7	74.9
90.00	70.2	14.4	113.3	90.00	30.1	11.7	65.3
112.50	34.4	9.0	61.5	112.50	17.6	7.4	39.8
135.00	16.0	8.3	41.0	135.00	21.0	8.6	46.9
157.50	19.0	8.7	45.1	157.50	16.5	9.5	45.0
180.00	40.0	15.6	86.7	180.00	13.9	6.0	31.8
202.50	68.0	10.3	98.9	202.50	28.5	14.0	70.5
225.00	76.0	11.1	109.4	225.00	41.8	18.2	96.5
247.50	72.3	11.8	107.6	247.50	65.2	19.1	122.6
270.00	70.4	10.6	102.1	270.00	68.2	12.6	105.9
292.50	69.0	11.0	101.9	292.50	71.5	14.1	114.0
315.00	48.1	11.4	82.4	315.00	32.9	15.9	80.5
337.50	33.1	14.6	76.8	337.50	18.5	8.1	42.9

LOCATION 3				LOCATION 4			
WIND AZIMUTH	U _{MEAN} /U _{INF} (PERCENT)	U _{RMS} /U _{INF} (PERCENT)	U _{MEAN} +3*U _{RMS} /U _{INF} (PERCENT)	WIND AZIMUTH	U _{MEAN} /U _{INF} (PERCENT)	U _{RMS} /U _{INF} (PERCENT)	U _{MEAN} +3*U _{RMS} /U _{INF} (PERCENT)
0.00	38.6	17.3	90.3	0.00	41.5	12.6	79.3
22.50	54.3	17.2	105.9	22.50	34.6	12.0	70.6
45.00	67.5	13.0	106.5	45.00	26.0	10.4	57.1
67.50	47.6	12.8	86.0	67.50	25.0	9.1	52.4
90.00	19.4	9.8	48.9	90.00	42.0	9.4	70.2
112.50	21.4	8.7	47.5	112.50	57.6	11.7	92.7
135.00	37.1	15.0	82.1	135.00	50.3	14.8	94.8
157.50	48.8	14.3	91.7	157.50	33.6	13.9	75.3
180.00	46.4	13.7	87.4	180.00	21.5	9.5	50.0
202.50	44.7	15.1	90.1	202.50	13.7	5.4	30.0
225.00	23.3	8.0	47.2	225.00	15.7	6.0	33.6
247.50	43.7	10.6	75.6	247.50	20.3	6.7	40.5
270.00	56.5	13.9	78.3	270.00	18.0	8.6	43.7
292.50	37.2	16.4	86.2	292.50	61.3	10.6	93.0
315.00	27.0	10.7	59.0	315.00	55.7	10.4	87.0
337.50	29.4	11.8	64.8	337.50	51.5	11.1	84.9

TABLE 2--PEDESTRIAN WIND VELOCITIES AND TURBULENCE INTENSITIES
LAKeway CENTER WITHOUT THREE LAKeway

LOCATION 5

WIND AZIMUTH	UMEAN/UINF (PERCENT)	URMS/UINF (PERCENT)	UMEAN+3*URMS/UINF (PERCENT)
0.00	61.4	13.8	102.7
22.50	42.9	11.0	76.0
45.00	23.0	8.3	48.0
67.50	18.8	8.4	44.0
90.00	26.5	9.9	56.1
112.50	37.5	9.6	66.4
135.00	50.7	11.7	85.8
157.50	58.0	10.1	88.2
180.00	47.2	8.9	74.0
202.50	35.1	6.6	55.0
225.00	19.7	6.5	39.3
247.50	20.6	10.2	51.1
270.00	19.9	9.1	47.3
292.50	55.3	13.0	94.3
315.00	68.5	13.1	107.9
337.50	69.8	14.5	119.3

LOCATION 6

WIND AZIMUTH	UMEAN/UINF (PERCENT)	URMS/UINF (PERCENT)	UMEAN+3*URMS/UINF (PERCENT)
0.00	34.2	11.5	68.6
22.50	30.6	14.7	74.8
45.00	28.0	17.0	79.1
67.50	30.3	12.7	68.4
90.00	26.1	13.0	65.2
112.50	38.3	13.3	78.1
135.00	55.6	14.9	100.2
157.50	59.2	13.4	99.5
180.00	59.9	13.2	99.6
202.50	58.4	13.8	99.7
225.00	47.3	10.7	79.4
247.50	27.0	8.1	51.2
270.00	15.5	9.2	43.1
292.50	83.8	22.2	150.3
315.00	37.5	9.7	66.7
337.50	32.0	9.6	60.8

LOCATION 7

WIND AZIMUTH	UMEAN/UINF (PERCENT)	URMS/UINF (PERCENT)	UMEAN+3*URMS/UINF (PERCENT)
0.00	72.7	20.6	134.4
22.50	78.9	17.1	130.2
45.00	68.2	13.7	109.4
67.50	42.9	11.9	78.5
90.00	18.7	9.3	46.6
112.50	24.9	10.8	57.4
135.00	44.8	15.7	91.9
157.50	47.9	14.2	90.4
180.00	60.6	14.4	103.7
202.50	61.2	12.2	97.8
225.00	53.1	12.8	91.4
247.50	24.2	12.4	61.4
270.00	16.7	8.5	42.1
292.50	13.9	6.5	33.5
315.00	29.2	12.7	67.4
337.50	58.5	21.0	121.4

LOCATION 8

WIND AZIMUTH	UMEAN/UINF (PERCENT)	URMS/UINF (PERCENT)	UMEAN+3*URMS/UINF (PERCENT)
0.00	76.0	13.8	117.6
22.50	59.6	13.3	99.4
45.00	65.0	14.8	109.6
67.50	50.8	15.1	96.1
90.00	22.2	12.3	59.0
112.50	32.7	12.1	69.1
135.00	38.1	12.8	76.4
157.50	36.9	12.9	75.6
180.00	46.7	12.5	84.4
202.50	54.4	12.4	91.5
225.00	50.1	12.8	88.6
247.50	35.5	13.5	76.0
270.00	23.0	12.0	58.9
292.50	27.4	14.4	70.6
315.00	62.2	18.5	117.8
337.50	82.5	14.2	125.1

TABLE 2--PEDESTRIAN WIND VELOCITIES AND TURBULENCE INTENSITIES
LAKEWAY CENTER WITHOUT THREE LAKEWAY

LOCATION 9

WIND AZIMUTH	U _{MEAN} /U _{INF} (PERCENT)	U _{RMS} /U _{INF} (PERCENT)	U _{MEAN} +3*U _{RMS} /U _{INF} (PERCENT)
0.00	79.5	9.1	106.8
22.50	73.1	9.8	102.7
45.00	47.1	17.6	100.0
67.50	42.2	11.6	77.0
90.00	25.7	12.8	64.2
112.50	67.3	14.0	109.2
135.00	87.4	13.3	127.4
157.50	80.5	12.7	118.5
180.00	78.4	13.6	119.1
202.50	48.3	12.6	84.2
225.00	31.3	9.6	60.0
247.50	25.6	8.1	49.8
270.00	24.0	10.8	56.5
292.50	27.2	23.4	127.4
315.00	78.6	7.4	100.9
337.50	82.8	8.6	108.5

LOCATION 10

WIND AZIMUTH	U _{MEAN} /U _{INF} (PERCENT)	U _{RMS} /U _{INF} (PERCENT)	U _{MEAN} +3*U _{RMS} /U _{INF} (PERCENT)
0.00	20.8	10.1	51.2
22.50	14.2	6.9	34.8
45.00	17.5	7.6	40.4
67.50	17.8	8.3	42.8
90.00	11.9	5.2	27.5
112.50	11.4	5.1	26.9
135.00	22.9	9.9	52.6
157.50	37.2	13.2	76.7
180.00	54.1	12.6	91.9
202.50	40.3	12.1	76.6
225.00	23.2	10.3	54.1
247.50	33.0	12.9	71.6
270.00	44.9	14.9	89.6
292.50	59.9	10.0	89.9
315.00	71.3	9.0	98.3
337.50	70.0	10.4	101.3

LOCATION 11

WIND AZIMUTH	U _{MEAN} /U _{INF} (PERCENT)	U _{RMS} /U _{INF} (PERCENT)	U _{MEAN} +3*U _{RMS} /U _{INF} (PERCENT)
0.00	67.9	17.3	119.8
22.50	63.5	17.4	115.7
45.00	32.5	16.6	82.2
67.50	41.5	17.1	92.9
90.00	40.8	13.0	79.7
112.50	39.4	11.0	72.3
135.00	36.8	10.8	69.2
157.50	32.1	11.0	65.0
180.00	36.3	11.0	69.2
202.50	51.2	16.4	100.3
225.00	50.6	14.5	93.9
247.50	26.6	10.6	58.4
270.00	23.3	10.8	55.7
292.50	20.5	11.1	53.7
315.00	47.0	18.7	103.3
337.50	59.7	17.5	112.3

LOCATION 12

WIND AZIMUTH	U _{MEAN} /U _{INF} (PERCENT)	U _{RMS} /U _{INF} (PERCENT)	U _{MEAN} +3*U _{RMS} /U _{INF} (PERCENT)
0.00	30.9	11.5	65.6
22.50	20.0	8.6	45.7
45.00	27.8	10.2	58.4
67.50	22.3	9.7	51.5
90.00	41.3	13.2	80.8
112.50	37.5	12.9	76.2
135.00	31.6	10.5	63.2
157.50	24.6	10.0	54.6
180.00	22.4	9.5	50.0
202.50	23.0	11.1	56.6
225.00	32.3	13.8	73.9
247.50	28.0	12.2	64.5
270.00	22.5	9.4	50.8
292.50	16.0	7.4	38.0
315.00	19.4	9.6	48.2
337.50	23.0	9.8	52.3

TABLE 2--PEDESTRIAN WIND VELOCITIES AND TURBULENCE INTENSITIES
LAKEWAY CENTER WITHOUT THREE LAKEWAY

LOCATION 13

WIND AZIMUTH	UMEAN/UINF (PERCENT)	URMS/UINF (PERCENT)	UMEAN+3*URMS/UINF (PERCENT)
0.00	15.0	6.6	34.8
22.50	18.5	8.5	44.0
45.00	13.1	4.6	26.9
67.50	28.6	7.5	51.0
90.00	36.9	10.1	67.3
112.50	19.9	8.6	45.6
135.00	14.3	6.3	33.3
157.50	16.9	7.4	39.1
180.00	29.1	13.8	70.4
202.50	37.9	14.8	82.2
225.00	43.3	16.3	92.3
247.50	26.0	11.7	61.1
270.00	18.4	9.4	46.6
292.50	23.3	10.9	56.0
315.00	26.4	8.0	50.5
337.50	22.0	10.2	52.6

LOCATION 14

WIND AZIMUTH	UMEAN/UINF (PERCENT)	URMS/UINF (PERCENT)	UMEAN+3*URMS/UINF (PERCENT)
0.00	44.9	11.2	78.4
22.50	59.1	10.3	90.1
45.00	55.3	10.5	86.8
67.50	30.2	12.0	66.3
90.00	38.0	11.2	71.6
112.50	19.5	8.2	44.1
135.00	22.0	8.6	47.9
157.50	36.4	9.0	65.0
180.00	48.0	9.7	77.2
202.50	52.7	9.7	81.7
225.00	47.0	8.2	71.7
247.50	43.2	11.6	77.9
270.00	24.6	11.7	59.8
292.50	34.3	15.0	79.2
315.00	17.4	8.2	41.9
337.50	21.5	9.4	49.7

LOCATION 15

WIND AZIMUTH	UMEAN/UINF (PERCENT)	URMS/UINF (PERCENT)	UMEAN+3*URMS/UINF (PERCENT)
0.00	28.8	14.8	73.3
22.50	40.9	21.1	104.1
45.00	58.9	17.6	111.7
67.50	57.4	19.4	115.5
90.00	84.8	16.5	134.3
112.50	36.9	20.6	98.6
135.00	23.0	12.3	60.0
157.50	22.0	11.9	57.6
180.00	24.5	12.0	60.6
202.50	47.4	13.1	86.6
225.00	59.9	12.1	96.3
247.50	65.3	12.5	102.8
270.00	75.5	16.3	124.2
292.50	34.5	18.4	89.8
315.00	30.6	16.8	81.0
337.50	29.4	14.1	71.6

LOCATION 16

WIND AZIMUTH	UMEAN/UINF (PERCENT)	URMS/UINF (PERCENT)	UMEAN+3*URMS/UINF (PERCENT)
0.00	53.7	18.4	108.9
22.50	39.5	15.8	76.8
45.00	32.6	14.3	75.4
67.50	32.3	13.3	72.0
90.00	31.3	13.0	70.4
112.50	28.6	10.8	61.1
135.00	23.1	8.8	49.6
157.50	16.1	7.2	37.7
180.00	14.7	7.1	36.0
202.50	16.0	6.4	35.1
225.00	22.5	7.7	45.5
247.50	17.9	5.9	35.6
270.00	23.2	8.3	48.2
292.50	20.6	9.7	49.8
315.00	37.0	15.2	82.7
337.50	43.9	20.5	105.4

TABLE 2--PEDESTRIAN WIND VELOCITIES AND TURBULENCE INTENSITIES
LAKEWAY CENTER WITHOUT THREE LAKEWAY

LOCATION 19

WIND AZIMUTH	UMEAN/UINF (PERCENT)	URMS/UINF (PERCENT)	UMEAN+3*URMS/UINF (PERCENT)
0.00	46.5	12.3	83.3
22.50	50.8	10.8	83.3
45.00	53.1	12.4	72.3
67.50	53.2	14.5	96.7
90.00	30.0	9.9	59.8
112.50	27.9	9.5	56.4
135.00	26.4	10.0	56.3
157.50	31.0	9.7	60.2
180.00	36.0	9.6	64.7
202.50	40.6	10.1	71.0
225.00	35.7	9.3	63.5
247.50	33.3	12.2	69.9
270.00	28.2	11.1	62.6
292.50	29.1	14.7	73.3
315.00	22.8	10.2	53.3
337.50	22.9	10.9	55.6

LOCATION 20

WIND AZIMUTH	UMEAN/UINF (PERCENT)	URMS/UINF (PERCENT)	UMEAN+3*URMS/UINF (PERCENT)
0.00	25.0	11.7	60.1
22.50	24.7	13.0	63.7
45.00	69.1	16.2	117.6
67.50	61.3	16.8	111.6
90.00	53.6	18.1	108.0
112.50	47.2	14.9	92.0
135.00	43.0	10.7	75.1
157.50	27.6	10.9	60.2
180.00	20.4	9.2	47.9
202.50	28.7	12.4	65.9
225.00	47.8	12.5	85.1
247.50	45.4	14.5	89.1
270.00	53.0	16.8	103.3
292.50	76.0	15.1	121.3
315.00	75.5	23.1	144.7
337.50	30.2	16.3	79.2

LOCATION 24

WIND AZIMUTH	UMEAN/UINF (PERCENT)	URMS/UINF (PERCENT)	UMEAN+3*URMS/UINF (PERCENT)
0.00	27.8	11.9	63.5
22.50	31.3	12.5	68.8
45.00	35.8	10.7	67.8
67.50	45.0	12.6	82.9
90.00	37.4	11.0	70.5
112.50	29.3	11.5	63.8
135.00	22.2	9.6	51.1
157.50	17.8	7.4	40.0
180.00	28.6	9.3	56.5
202.50	28.4	10.5	59.7
225.00	29.8	12.5	67.3
247.50	34.4	13.6	75.0
270.00	28.0	11.3	62.1
292.50	46.3	20.0	106.3
315.00	52.8	19.3	110.9
337.50	38.3	16.4	87.4

LOCATION 26

WIND AZIMUTH	UMEAN/UINF (PERCENT)	URMS/UINF (PERCENT)	UMEAN+3*URMS/UINF (PERCENT)
0.00	40.6	13.1	79.8
22.50	31.5	10.8	64.0
45.00	52.2	12.0	88.1
67.50	49.0	11.2	82.8
90.00	39.1	10.1	69.3
112.50	34.5	9.9	64.1
135.00	38.2	12.0	74.3
157.50	28.7	9.6	57.6
180.00	19.4	9.6	48.2
202.50	35.6	15.4	81.9
225.00	47.9	13.3	87.9
247.50	31.7	10.7	63.8
270.00	31.4	11.7	66.5
292.50	27.9	12.9	66.5
315.00	25.2	13.2	64.8
337.50	22.4	11.0	55.3

TABLE 2 --PEDESTRIAN WIND VELOCITIES AND TURBULANCE INTENSITIES
LAKEWAY CENTER WITHOUT THREE LAKEWAY

** GREATEST VALUES **

U _{MEAN} /U _{INF} (PERCENT)					U _{RMS} /U _{INF} (PERCENT)					U _{MEAN} +3*U _{RMS} /U _{INF} (PERCENT)				
LOC	AZ	MEAN	RMS	M+3RMS	LOC	AZ	MEAN	RMS	M+3RMS	LOC	AZ	MEAN	RMS	M+3RMS
9	135.0	87.4	13.3	127.4	9	292.5	57.2	23.4	127.4	6	292.5	83.8	22.2	150.3
15	90.0	84.8	16.5	134.3	20	315.0	75.5	23.1	144.7	20	315.0	75.5	23.1	144.7
1	0.0	84.2	11.3	118.0	6	292.5	83.8	22.2	150.3	7	0.0	72.7	20.6	134.4
6	292.5	83.8	22.2	150.3	15	22.5	40.9	21.1	104.1	15	90.0	84.8	16.5	134.3
9	337.5	82.8	8.6	108.5	7	337.5	58.5	21.0	121.4	7	22.5	78.9	17.1	130.2
8	337.5	82.5	14.2	125.1	15	112.5	36.9	20.6	98.6	9	292.5	57.2	23.4	127.4
1	45.0	80.7	11.1	113.9	7	0.0	72.7	20.6	134.4	9	135.0	87.4	13.3	127.4
9	157.5	80.5	12.7	118.5	16	337.5	43.9	20.5	105.4	8	337.5	82.5	14.2	125.1
9	0.0	79.5	9.1	106.8	24	292.5	46.3	20.0	106.3	15	270.0	75.5	16.3	124.2
7	22.5	78.9	17.1	130.2	15	67.5	57.4	19.4	115.5	2	247.5	65.2	19.1	122.6

TABLE 2--PEDESTRIAN WIND VELOCITIES AND TURBULENCE INTENSITIES
LAKEWAY CENTER WITH THREE LAKEWAY

LOCATION 1				LOCATION 2			
WIND AZIMUTH	UMEAN/UINF (PERCENT)	URMS/UINF (PERCENT)	UMEAN+3*URMS/UINF (PERCENT)	WIND AZIMUTH	UMEAN/UINF (PERCENT)	URMS/UINF (PERCENT)	UMEAN+3*URMS/UINF (PERCENT)
0.00	84.3	10.4	115.5	0.00	17.0	8.4	42.2
22.50	85.1	13.4	125.3	22.50	30.8	13.5	71.3
45.00	90.4	11.4	124.5	45.00	38.2	11.8	73.6
67.50	75.6	14.9	120.4	67.50	33.9	15.3	79.7
90.00	64.8	14.5	108.3	90.00	26.8	12.4	63.9
112.50	35.5	11.5	69.9	112.50	17.7	7.8	41.0
135.00	40.5	12.7	78.4	135.00	18.0	8.3	42.8
157.50	23.9	11.3	57.9	157.50	29.2	12.1	65.3
180.00	33.9	14.8	78.4	180.00	21.6	9.8	50.9
202.50	63.2	11.0	96.2	202.50	36.1	15.7	83.1
225.00	77.4	9.9	107.0	225.00	39.8	17.9	93.5
247.50	69.6	9.9	99.3	247.50	71.4	19.7	130.6
270.00	64.8	10.6	96.5	270.00	69.0	13.2	108.8
292.50	60.9	12.0	96.9	292.50	69.3	13.9	110.9
315.00	49.9	12.1	86.3	315.00	35.2	16.8	85.5
337.50	28.1	14.2	70.5	337.50	18.1	7.8	41.4

LOCATION 3				LOCATION 4			
WIND AZIMUTH	UMEAN/UINF (PERCENT)	URMS/UINF (PERCENT)	UMEAN+3*URMS/UINF (PERCENT)	WIND AZIMUTH	UMEAN/UINF (PERCENT)	URMS/UINF (PERCENT)	UMEAN+3*URMS/UINF (PERCENT)
0.00	31.4	13.7	72.6	0.00	36.0	12.1	72.4
22.50	56.7	16.3	105.6	22.50	30.5	12.7	68.6
45.00	63.2	10.9	95.9	45.00	25.4	10.1	55.7
67.50	35.6	13.3	75.6	67.50	29.4	10.1	59.6
90.00	19.8	8.4	45.0	90.00	54.5	10.1	84.8
112.50	26.0	14.8	70.4	112.50	56.1	11.8	91.4
135.00	22.2	9.3	50.0	135.00	41.0	13.6	81.7
157.50	11.5	5.3	27.3	157.50	20.1	11.9	55.8
180.00	21.1	10.1	51.4	180.00	13.6	5.6	30.3
202.50	30.2	16.7	80.3	202.50	12.7	5.5	29.2
225.00	27.7	17.3	79.0	225.00	15.2	6.8	35.6
247.50	26.5	13.5	66.9	247.50	21.2	10.0	51.1
270.00	41.4	12.8	80.0	270.00	17.8	9.1	45.0
292.50	42.3	17.3	94.1	292.50	60.3	12.8	98.7
315.00	31.6	10.7	63.7	315.00	55.5	10.6	87.2
337.50	29.2	11.3	63.1	337.50	52.3	11.6	87.2

TABLE 2--PEDESTRIAN WIND VELOCITIES AND TURBULENCE INTENSITIES
LAKEWAY CENTER WITH THREE LAKEWAY

LOCATION 5

WIND AZIMUTH	U _{MEAN} /U _{INF} (PERCENT)	U _{RMS} /U _{INF} (PERCENT)	U _{MEAN} +3*U _{RMS} /U _{INF} (PERCENT)
0.00	50.2	14.5	93.8
22.50	31.8	10.5	63.1
45.00	12.8	6.6	32.7
67.50	15.0	8.2	39.6
90.00	31.7	10.0	61.7
112.50	37.4	8.8	63.6
135.00	43.9	11.7	79.1
157.50	58.4	10.8	90.8
180.00	53.1	13.4	93.2
202.50	21.9	11.2	55.5
225.00	24.8	12.3	61.7
247.50	33.8	12.3	70.6
270.00	34.5	12.6	72.4
292.50	66.4	11.2	100.1
315.00	73.3	13.6	114.0
337.50	68.3	15.6	115.1

LOCATION 6

WIND AZIMUTH	U _{MEAN} /U _{INF} (PERCENT)	U _{RMS} /U _{INF} (PERCENT)	U _{MEAN} +3*U _{RMS} /U _{INF} (PERCENT)
0.00	30.4	11.2	64.1
22.50	35.9	16.7	86.1
45.00	19.7	9.2	47.3
67.50	31.2	11.7	66.2
90.00	33.5	8.1	58.0
112.50	20.9	10.4	52.2
135.00	17.0	8.7	43.2
157.50	33.8	14.6	77.6
180.00	46.0	12.9	86.9
202.50	59.6	12.6	97.5
225.00	66.8	15.3	106.6
247.50	52.1	12.9	90.8
270.00	17.4	9.4	45.7
292.50	62.4	19.8	121.8
315.00	35.3	9.9	64.9
337.50	31.3	9.4	59.6

LOCATION 7

WIND AZIMUTH	U _{MEAN} /U _{INF} (PERCENT)	U _{RMS} /U _{INF} (PERCENT)	U _{MEAN} +3*U _{RMS} /U _{INF} (PERCENT)
0.00	53.8	23.1	123.1
22.50	73.3	14.9	118.0
45.00	41.6	14.2	84.2
67.50	28.2	12.7	66.3
90.00	19.3	10.1	49.4
112.50	26.9	13.2	66.5
135.00	29.8	13.6	70.6
157.50	41.1	18.4	96.2
180.00	38.6	17.6	91.5
202.50	60.6	22.2	127.2
225.00	41.8	20.8	104.1
247.50	24.6	12.4	61.7
270.00	27.5	11.8	62.9
292.50	17.2	10.8	49.7
315.00	21.0	11.4	55.0
337.50	67.4	22.5	134.9

LOCATION 8

WIND AZIMUTH	U _{MEAN} /U _{INF} (PERCENT)	U _{RMS} /U _{INF} (PERCENT)	U _{MEAN} +3*U _{RMS} /U _{INF} (PERCENT)
0.00	73.0	15.6	119.8
22.50	39.1	13.8	80.5
45.00	43.5	13.8	84.8
67.50	28.0	14.4	71.2
90.00	43.7	14.7	87.8
112.50	31.6	12.8	70.0
135.00	49.2	12.9	87.8
157.50	38.6	18.2	93.1
180.00	25.5	11.0	58.7
202.50	27.3	14.3	70.2
225.00	35.4	20.4	96.7
247.50	31.7	15.2	77.2
270.00	46.8	13.2	86.5
292.50	23.4	15.7	70.4
315.00	45.3	23.2	115.0
337.50	86.2	14.6	130.1

TABLE 2--PEDESTRIAN WIND VELOCITIES AND TURBULENCE INTENSITIES
LAKEWAY CENTER WITH THREE LAKEWAY

LOCATION 9

WIND AZIMUTH	U _{MEAN} /U _{INF} (PERCENT)	U _{RMS} /U _{INF} (PERCENT)	U _{MEAN} +3*U _{RMS} /U _{INF} (PERCENT)
0.00	67.3	12.5	104.7
22.50	44.9	13.5	85.6
45.00	25.9	12.3	62.7
67.50	25.9	11.8	61.3
90.00	27.3	14.0	69.3
112.50	50.5	16.2	99.0
135.00	44.7	11.2	78.2
157.50	31.0	13.6	71.8
180.00	54.8	14.1	97.0
202.50	58.8	16.8	109.2
225.00	59.9	16.0	107.8
247.50	54.2	13.4	94.3
270.00	38.6	11.6	73.3
292.50	56.0	25.7	133.0
315.00	82.7	9.0	109.5
337.50	78.3	8.3	103.1

LOCATION 10

WIND AZIMUTH	U _{MEAN} /U _{INF} (PERCENT)	U _{RMS} /U _{INF} (PERCENT)	U _{MEAN} +3*U _{RMS} /U _{INF} (PERCENT)
0.00	22.0	12.3	59.1
22.50	16.8	9.1	44.2
45.00	17.8	9.2	45.5
67.50	19.9	9.2	47.5
90.00	17.3	8.8	43.7
112.50	60.7	12.5	98.2
135.00	73.2	11.4	107.4
157.50	57.3	11.7	92.5
180.00	48.4	12.8	86.7
202.50	22.7	11.7	57.8
225.00	32.1	11.7	76.1
247.50	25.6	14.7	66.3
270.00	31.5	13.6	72.8
292.50	60.6	13.8	88.5
315.00	48.0	9.3	100.4
337.50	66.8	10.8	98.2

LOCATION 11

WIND AZIMUTH	U _{MEAN} /U _{INF} (PERCENT)	U _{RMS} /U _{INF} (PERCENT)	U _{MEAN} +3*U _{RMS} /U _{INF} (PERCENT)
0.00	27.7	16.6	77.4
22.50	20.2	11.6	54.9
45.00	22.0	13.2	61.4
67.50	26.5	14.3	69.4
90.00	48.5	13.8	90.0
112.50	50.9	15.3	94.9
135.00	29.9	11.3	63.7
157.50	36.7	12.7	74.7
180.00	37.0	11.7	72.2
202.50	39.1	11.6	74.0
225.00	38.3	10.7	70.3
247.50	43.7	13.7	84.8
270.00	36.3	13.6	77.0
292.50	29.1	18.6	85.0
315.00	70.5	17.3	122.4
337.50	55.1	17.9	108.7

LOCATION 12

WIND AZIMUTH	U _{MEAN} /U _{INF} (PERCENT)	U _{RMS} /U _{INF} (PERCENT)	U _{MEAN} +3*U _{RMS} /U _{INF} (PERCENT)
0.00	45.2	18.3	100.0
22.50	33.3	14.6	77.1
45.00	34.4	15.4	82.5
67.50	29.6	15.1	74.8
90.00	56.7	14.9	101.4
112.50	50.8	15.0	95.7
135.00	17.7	18.5	43.2
157.50	37.9	15.7	85.1
180.00	41.4	17.9	95.0
202.50	31.0	11.8	66.3
225.00	33.8	13.8	75.1
247.50	31.8	15.3	77.8
270.00	27.8	14.1	70.0
292.50	17.6	10.2	48.3
315.00	30.1	14.5	73.6
337.50	21.7	12.8	60.1

TABLE 2--PEDESTRIAN WIND VELOCITIES AND TURBULENCE INTENSITIES
LAKEWAY CENTER WITH THREE LAKEWAY

LOCATION 13

WIND AZIMUTH	U _{MEAN} /U _{INF} (PERCENT)	U _{RMS} /U _{INF} (PERCENT)	U _{MEAN} +3*U _{RMS} /U _{INF} (PERCENT)
0.00	28.5	16.4	77.8
22.50	43.7	17.0	94.6
45.00	46.5	14.0	88.7
67.50	45.5	11.5	80.0
90.00	47.5	12.3	84.3
112.50	40.7	14.3	83.8
135.00	32.1	13.3	71.9
157.50	46.8	17.2	98.3
180.00	44.8	18.6	100.4
202.50	62.0	18.0	115.8
225.00	60.3	18.5	115.7
247.50	64.8	14.9	109.5
270.00	53.8	13.7	94.8
292.50	19.2	13.1	58.5
315.00	30.4	15.9	77.9
337.50	32.6	15.3	78.5

LOCATION 14

WIND AZIMUTH	U _{MEAN} /U _{INF} (PERCENT)	U _{RMS} /U _{INF} (PERCENT)	U _{MEAN} +3*U _{RMS} /U _{INF} (PERCENT)
0.00	37.6	21.1	101.0
22.50	32.6	17.8	86.1
45.00	21.4	11.1	54.6
67.50	19.2	10.4	50.5
90.00	24.8	12.7	63.0
112.50	44.2	18.5	99.7
135.00	51.3	16.2	100.0
157.50	53.9	12.8	92.3
180.00	48.2	13.7	89.3
202.50	22.6	9.1	50.0
225.00	17.1	7.2	38.8
247.50	15.8	6.6	35.5
270.00	26.3	11.0	59.2
292.50	43.0	18.7	99.0
315.00	44.0	17.2	95.7
337.50	45.8	17.1	97.1

LOCATION 15

WIND AZIMUTH	U _{MEAN} /U _{INF} (PERCENT)	U _{RMS} /U _{INF} (PERCENT)	U _{MEAN} +3*U _{RMS} /U _{INF} (PERCENT)
0.00	42.5	25.8	120.0
22.50	52.9	21.3	116.8
45.00	64.5	18.1	118.8
67.50	66.8	21.0	129.8
90.00	90.1	17.3	141.9
112.50	59.9	21.8	125.3
135.00	35.3	17.1	86.7
157.50	33.1	13.1	72.3
180.00	30.7	11.5	65.2
202.50	36.6	13.4	76.9
225.00	49.9	10.5	81.4
247.50	52.5	10.4	83.7
270.00	52.9	14.0	100.7
292.50	36.2	21.4	100.4
315.00	29.8	15.9	77.4
337.50	25.0	13.6	65.7

LOCATION 16

WIND AZIMUTH	U _{MEAN} /U _{INF} (PERCENT)	U _{RMS} /U _{INF} (PERCENT)	U _{MEAN} +3*U _{RMS} /U _{INF} (PERCENT)
0.00	56.1	15.7	103.2
22.50	80.0	18.0	133.9
45.00	80.9	17.7	133.9
67.50	70.8	17.5	123.3
90.00	68.8	13.1	108.1
112.50	59.8	11.2	93.3
135.00	45.0	15.6	91.7
157.50	60.8	10.0	90.9
180.00	69.3	9.3	97.2
202.50	76.4	7.8	99.9
225.00	82.1	10.5	113.7
247.50	74.5	10.0	104.6
270.00	66.8	11.5	101.3
292.50	34.9	15.8	82.3
315.00	54.4	18.0	108.5
337.50	25.3	15.5	71.9

TABLE 2--PEDESTRIAN WIND VELOCITIES AND TURBULENCE INTENSITIES
LAKEWAY CENTER WITH THREE LAKEWAY

LOCATION 17

WIND AZIMUTH	U _{MEAN} /U _{INF} (PERCENT)	U _{RMS} /U _{INF} (PERCENT)	U _{MEAN} +3*U _{RMS} /U _{INF} (PERCENT)
0.00	35.3	16.2	84.0
22.50	56.6	13.0	95.6
45.00	58.1	10.9	90.7
67.50	56.3	12.6	94.3
90.00	47.8	10.4	79.1
112.50	44.3	12.0	80.2
135.00	28.1	12.1	64.3
157.50	17.9	8.3	42.8
180.00	11.9	4.7	25.8
202.50	15.4	6.6	35.1
225.00	20.4	18.8	46.9
247.50	22.4	12.8	60.9
270.00	43.7	26.2	122.3
292.50	14.8	10.3	45.5
315.00	38.8	15.0	83.8
337.50	33.4	14.1	75.8

LOCATION 18

WIND AZIMUTH	U _{MEAN} /U _{INF} (PERCENT)	U _{RMS} /U _{INF} (PERCENT)	U _{MEAN} +3*U _{RMS} /U _{INF} (PERCENT)
0.00	26.2	13.4	66.4
22.50	36.5	11.9	72.2
45.00	30.7	9.2	58.4
67.50	38.6	12.9	77.4
90.00	40.0	10.7	72.1
112.50	29.3	9.5	57.8
135.00	20.8	8.0	44.7
157.50	19.8	9.9	49.5
180.00	24.8	13.0	63.7
202.50	25.2	14.0	67.1
225.00	35.1	18.0	89.1
247.50	36.3	16.9	87.0
270.00	50.3	14.3	93.1
292.50	21.0	11.5	55.6
315.00	29.5	14.6	73.3
337.50	25.7	13.4	65.9

LOCATION 19

WIND AZIMUTH	U _{MEAN} /U _{INF} (PERCENT)	U _{RMS} /U _{INF} (PERCENT)	U _{MEAN} +3*U _{RMS} /U _{INF} (PERCENT)
0.00	59.6	17.4	111.9
22.50	54.8	14.1	97.2
45.00	37.0	14.4	80.3
67.50	29.0	14.7	73.1
90.00	40.1	13.5	80.7
112.50	61.1	12.7	99.2
135.00	72.0	11.8	107.5
157.50	59.4	11.1	92.7
180.00	55.0	14.1	97.4
202.50	23.3	12.8	61.7
225.00	31.7	15.7	78.7
247.50	21.9	11.5	56.4
270.00	33.3	13.8	74.7
292.50	32.6	15.3	78.4
315.00	43.5	21.8	108.9
337.50	50.0	19.2	107.7

LOCATION 20

WIND AZIMUTH	U _{MEAN} /U _{INF} (PERCENT)	U _{RMS} /U _{INF} (PERCENT)	U _{MEAN} +3*U _{RMS} /U _{INF} (PERCENT)
0.00	26.0	15.5	72.6
22.50	76.6	19.0	133.5
45.00	80.7	17.3	132.6
67.50	66.2	22.2	132.9
90.00	67.4	23.5	137.9
112.50	43.2	17.1	94.4
135.00	23.4	10.9	56.0
157.50	26.6	14.7	70.6
180.00	27.4	11.6	62.1
202.50	19.5	9.9	49.3
225.00	32.5	12.6	70.2
247.50	35.8	12.4	72.9
270.00	34.6	15.9	82.2
292.50	77.6	14.8	122.0
315.00	72.1	22.7	140.4
337.50	27.5	15.3	73.4

TABLE 2--PEDESTRIAN WIND VELOCITIES AND TURRULENCE INTENSITIES
LAKEWAY CENTER WITH THREE LAKEWAY

LOCATION 21

WIND AZIMUTH	UMEAN/UINF (PERCENT)	URMS/UINF (PERCENT)	UMEAN+3*URMS/UINF (PERCENT)
0.00	15.6	9.6	44.4
22.50	32.0	18.5	87.4
45.00	21.0	12.3	58.0
67.50	19.3	11.3	53.3
90.00	20.2	12.3	57.2
112.50	17.5	8.1	41.8
135.00	12.3	5.3	28.3
157.50	35.0	16.7	84.9
180.00	33.9	14.1	76.1
202.50	32.7	10.5	64.1
225.00	30.3	9.4	58.5
247.50	21.1	8.8	47.6
270.00	18.8	7.4	41.1
292.50	23.1	12.3	60.1
315.00	15.8	9.3	43.7
337.50	22.2	12.0	58.1

LOCATION 22

WIND AZIMUTH	UMEAN/UINF (PERCENT)	URMS/UINF (PERCENT)	UMEAN+3*URMS/UINF (PERCENT)
0.00	76.4	22.4	143.5
22.50	52.0	14.7	96.0
45.00	42.2	14.9	87.0
67.50	29.3	17.9	82.9
90.00	46.8	21.1	110.3
112.50	47.9	14.8	92.2
135.00	74.6	12.9	113.3
157.50	86.5	12.8	124.9
180.00	65.4	22.6	133.1
202.50	26.3	10.4	57.4
225.00	27.8	11.8	61.2
247.50	25.5	12.1	61.9
270.00	23.5	10.6	55.3
292.50	39.7	21.0	102.9
315.00	69.4	16.5	119.0
337.50	72.9	19.3	130.9

LOCATION 23

WIND AZIMUTH	UMEAN/UINF (PERCENT)	URMS/UINF (PERCENT)	UMEAN+3*URMS/UINF (PERCENT)
0.00	65.4	12.2	101.9
22.50	71.4	9.6	100.4
45.00	79.0	11.1	112.3
67.50	83.9	11.7	118.9
90.00	45.2	14.7	89.4
112.50	31.8	13.9	73.4
135.00	71.2	12.0	107.3
157.50	74.3	10.0	106.4
180.00	86.4	9.7	115.5
202.50	78.9	13.9	120.7
225.00	45.4	22.1	111.7
247.50	19.9	7.0	40.9
270.00	20.7	8.7	46.6
292.50	23.5	12.2	60.0
315.00	49.9	13.4	90.1
337.50	50.7	12.6	88.5

LOCATION 24

WIND AZIMUTH	UMEAN/UINF (PERCENT)	URMS/UINF (PERCENT)	UMEAN+3*URMS/UINF (PERCENT)
0.00	48.8	10.6	80.7
22.50	58.2	17.9	111.9
45.00	32.1	16.8	82.5
67.50	25.8	15.5	75.4
90.00	44.7	15.0	89.8
112.50	48.7	10.0	78.8
135.00	56.5	10.3	87.3
157.50	78.8	11.7	113.8
180.00	61.6	12.4	98.9
202.50	27.3	9.4	55.6
225.00	20.8	8.8	47.2
247.50	33.4	12.1	69.7
270.00	17.2	11.8	82.5
292.50	61.7	18.0	115.7
315.00	40.8	12.0	76.8
337.50	41.9	11.4	75.9

TABLE 2--PEDESTRIAN WIND VELOCITIES AND TURBULENCE INTENSITIES
LAKEWAY CENTER WITH THREE LAKEWAY

LOCATION 25

WIND AZIMUTH	UMEAN/UINF (PERCENT)	URMS/UINF (PERCENT)	UMEAN+3*URMS/UINF (PERCENT)
0.00	15.1	9.0	42.0
22.50	15.9	7.1	37.3
45.00	39.6	17.5	92.0
67.50	49.1	18.0	103.3
90.00	46.0	12.0	82.1
112.50	43.6	9.1	70.7
135.00	40.4	10.1	70.6
157.50	27.6	9.9	57.1
180.00	20.0	8.5	45.6
202.50	27.2	10.2	57.7
225.00	43.3	11.5	77.8
247.50	50.4	10.6	82.2
270.00	51.4	10.0	81.3
292.50	47.6	16.1	95.7
315.00	10.4	6.4	29.5
337.50	14.6	9.5	43.2

LOCATION 26

WIND AZIMUTH	UMEAN/UINF (PERCENT)	URMS/UINF (PERCENT)	UMEAN+3*URMS/UINF (PERCENT)
0.00	56.3	13.4	96.5
22.50	72.2	10.0	102.3
45.00	85.7	9.8	115.1
67.50	93.4	10.8	126.0
90.00	68.1	12.5	105.7
112.50	31.1	13.0	70.2
135.00	30.6	12.2	67.1
157.50	50.4	15.1	95.7
180.00	71.7	19.4	130.0
202.50	85.0	16.0	133.1
225.00	70.6	15.8	118.1
247.50	53.7	13.6	94.3
270.00	34.9	14.1	77.3
292.50	20.2	10.8	52.6
315.00	12.6	7.7	35.6
337.50	38.8	12.8	77.3

LOCATION 27

WIND AZIMUTH	UMEAN/UINF (PERCENT)	URMS/UINF (PERCENT)	UMEAN+3*URMS/UINF (PERCENT)
0.00	15.1	7.1	36.3
22.50	14.6	6.3	33.7
45.00	26.9	13.0	65.9
67.50	36.5	15.7	83.6
90.00	25.2	13.8	66.7
112.50	27.0	11.4	61.2
135.00	16.8	7.7	39.9
157.50	20.7	9.1	48.1
180.00	34.8	11.3	68.8
202.50	58.4	12.6	96.1
225.00	53.8	11.8	89.2
247.50	49.1	11.0	81.9
270.00	48.5	12.3	85.4
292.50	28.1	14.1	70.3
315.00	14.1	6.8	34.5
337.50	18.5	8.4	43.8

LOCATION 28

WIND AZIMUTH	UMEAN/UINF (PERCENT)	URMS/UINF (PERCENT)	UMEAN+3*URMS/UINF (PERCENT)
0.00	27.3	10.6	59.2
22.50	24.0	8.4	49.1
45.00	17.9	7.2	39.4
67.50	20.9	11.8	56.1
90.00	30.8	17.5	83.2
112.50	18.3	7.7	41.4
135.00	16.3	7.1	37.3
157.50	25.9	12.4	63.0
180.00	32.7	15.3	78.6
202.50	40.3	14.4	83.5
225.00	47.2	16.2	96.0
247.50	30.4	10.2	60.8
270.00	29.5	13.4	69.8
292.50	21.8	11.0	54.7
315.00	40.5	20.2	101.0
337.50	40.6	18.9	97.2

TABLE 2--PEDESTRIAN WIND VELOCITIES AND TURBULENCE INTENSITIES
LAKEWAY CENTER WITH THREE LAKEWAY

LOCATION 29

WIND AZIMUTH	U _{MEAN} /U _{INF} (PERCENT)	U _{RMS} /U _{INF} (PERCENT)	U _{MEAN} +3*U _{RMS} /U _{INF} (PERCENT)
0.00	13.8	5.4	29.9
22.50	35.5	6.9	56.1
45.00	31.3	5.3	47.2
67.50	22.7	5.4	38.9
90.00	13.5	3.8	24.9
112.50	19.4	9.4	47.6
135.00	32.0	16.3	81.0
157.50	30.8	7.4	53.1
180.00	16.9	8.3	41.9
202.50	17.8	9.5	46.4
225.00	32.0	11.6	66.8
247.50	30.6	7.3	52.5
270.00	29.1	6.4	48.5
292.50	14.9	7.2	36.4
315.00	29.9	11.2	63.4
337.50	33.1	9.4	61.2

TABLE 2 --PEDESTRIAN WIND VELOCITIES AND TURBULANCE INTENSITIES
LAKEWAY CENTER WITH THREE LAKEWAY

** GREATEST VALUES **

U _{MEAN} /U _{INF} (PERCENT)					U _{RMS} /U _{INF} (PERCENT)					U _{MEAN} +3*U _{RMS} /U _{INF} (PERCENT)				
LOC	AZ	MEAN	RMS	M+3RMS	LOC	AZ	MEAN	RMS	M+3RMS	LOC	AZ	MEAN	RMS	M+3RMS
26	67.5	93.4	10.8	126.0	17	270.0	43.7	26.2	122.3	22	0.0	76.4	22.4	143.5
1	45.0	90.4	11.4	124.5	15	0.0	42.5	25.8	120.0	15	90.0	90.1	17.3	141.9
15	90.0	90.1	17.3	141.9	9	292.5	56.0	25.7	133.0	20	315.0	72.1	22.7	140.4
22	157.5	86.5	12.8	124.9	20	90.0	67.4	23.5	137.9	20	90.0	67.4	23.5	137.9
23	180.0	86.4	9.7	115.5	8	315.0	45.3	23.2	115.0	7	337.5	67.4	22.5	134.9
8	337.5	86.2	14.6	130.1	7	0.0	53.8	23.1	123.1	16	45.0	80.9	17.7	133.9
26	45.0	85.7	9.8	115.1	20	315.0	72.1	22.7	140.4	16	22.5	80.0	18.0	133.9
1	22.5	85.1	13.4	125.3	22	180.0	65.4	22.6	133.1	20	22.5	76.6	19.0	133.5
26	202.5	85.0	16.0	133.1	7	337.5	67.4	22.5	134.9	26	202.5	85.0	16.0	133.1
1	0.0	84.3	10.4	115.5	22	0.0	76.4	22.4	143.5	22	180.0	65.4	22.6	133.1

TABLE 3

PERCENTAGE FREQUENCY OF WIND DIRECTION AND SPEED

NEW ORLEANS, LOUISIANA

INT. APRT (1965-1974)

SEASON : ANNUAL NO. OF OBS. = 29216 HT. OF MEAS. = 20 FT

VELOCITY LEVELS IN MPH

DIRECTION	0-3	4-7	8-12	13-18	19-24	25 +	TOTAL
N	1.10	3.10	3.90	2.50	20	0.00	10.80
NNE	.70	1.90	2.70	1.30	0.00	0.00	6.70
NE	.80	1.90	2.80	1.20	0.00	0.00	6.70
ENE	1.00	2.10	2.30	1.10	0.00	0.00	6.50
E	1.00	2.30	2.20	.90	10	0.00	6.50
ESE	.60	2.20	2.20	.80	10	0.00	5.90
SE	.30	1.50	2.50	1.30	10	0.00	5.70
SSE	.20	1.30	2.40	1.60	20	0.00	5.70
S	.50	2.50	3.80	2.50	30	0.00	9.70
SSW	.50	1.90	1.50	.50	10	0.00	4.50
SW	.60	1.60	1.20	.50	0.00	0.00	3.80
WSW	.70	1.20	.90	.40	0.00	0.00	3.30
W	1.30	1.70	.90	.50	10	0.00	4.60
WNW	.70	1.10	.90	.40	0.00	0.00	3.00
NW	.70	1.00	1.10	.90	10	0.00	3.70
NNW	.80	1.10	1.60	1.20	20	0.00	4.80
CALM	0.00	0.00	0.00	0.00	0.00	0.00	0.00
TOT	19.20	28.50	32.70	17.70	1.60	.20	100.00

TABLE 4
SUMMARY OF WIND EFFECTS ON PEOPLE

	<u>Beaufort number</u>	<u>Speed (mph)</u>	<u>Effects</u>
Calm, light air	0,1	0-3	Calm, no noticeable wind
Light breeze	2	4-7	Wind felt on face
Gentle breeze	3	8-12	Wind extends light flag Hair is disurbed Clothing flaps
Moderate breeze	4	13-18	Raises dust, dry soil and loose paper Hair disarranged
Fresh breeze	5	19-24	Force of wind felt on body Drifting snow becomes airborne Limit of agreeable wind on land
Strong breeze	6	25-31	Umbrellas used with difficulty Hair blown straight Difficult to walk steadily Wind noise on ears unpleasant Windborne snow above head height (blizzard)
Near gale	7	32-38	Inconvenience felt when walking
Gale	8	39-46	Generally impedes progress Great difficulty with balance in gusts
Strong gale	9	47-54	People blown over by gusts

Note: Table from Reference 4, p. 40.

TABLE 5

CALCULATION OF REFERENCE PRESSURE

1. Basic wind speed from ANSI A58.1 (Ref. 6):

50-year fastest mile at 30 ft = 90 mph

Mean hourly wind speed = $\frac{90}{1.28} = 70.3$ mph

Mean hourly gradient wind speed = $70.3 \left(\frac{900}{30} \right)^{.16} = 121.1$ mph

Mean hourly wind at reference location = U_{∞} = gradient wind
= 121.1 mph

Reference Pressure = $0.5 \rho U_{\infty}^2 = (.00256) (121.1)^2 = \underline{\underline{37.6}}$

Use 38 psf

2. Loads for 100-year recurrence wind:

100-year fastest mile at 30 ft = 102 mph

Multiply 50-year loads by $\left(\frac{102}{90} \right)^2 = 1.28$

3. Gust load factors to convert hourly mean integrated loads to various gust durations (see Section 4.4):

<u>Gust Duration (sec)</u>	<u>Gust Load Factor</u>
10 - 15	$(1.40)^2 = 1.96$
30	$(1.32)^2 = 1.74$
45	$(1.26)^2 = 1.59$

The 30-second gust load factor was used in Table 7.




Table 5 (Con't.)

TABLE 5 (continued)

APPROACH WIND DIRECTION, DEGREES	FASTEST MILE WIND SPEED MPH*	DIRECTIONAL LOAD FACTOR FOR REFERENCE PRESSURE*
0	76	0.71
10	79	0.77
20	82	0.83
30	85	0.89
40	88	0.96
50	89	0.98
60	90	1.00
70	90	1.00
80	87	0.93
90	85	0.89
100	82	0.83
110	83	0.85
120	84	0.87
130	85	0.89
140	86	0.96
150	87	0.93
160	88	0.96
170	89	0.98
180	90	1.00
190	88	0.96
200	85	0.89
210	83	0.85
220	81	0.81
230	78	0.75
240	76	0.71
250	73	0.66
260	72	0.64
270	73	0.66
280	73	0.66
290	73	0.66
300	74	0.68
310	74	0.68
320	74	0.68
330	75	0.83
340	75	0.83
350	75	0.83

*Based on upper-bound curve on previous page.

TABLE 6A. PEAK LOADS FOR CONFIGURATION A : ONE LAKEWAY CENTER
LARGEST VALUES OF CLADDING LOAD REFERENCE PRESSURE = 38.0 PSF

TAP	AZI-NUTH	PRESS COEFF	NEGATIVE PEAK	POSITIVE PEAK	TAP	AZI-NUTH	PRESS COEFF	NEGATIVE PEAK	POSITIVE PEAK	TAP	AZI-NUTH	PRESS COEFF	NEGATIVE PEAK	POSITIVE PEAK
			PSF	PSF				PSF	PSF				PSF	PSF
1101	150	-1.29	-45.7	28.6	1149	350	.75	-19.1	23.6	1235	180	-2.54	-96.4	28.6
1102	300	-1.87	-48.2	12.4	1150	340	.72	-16.4	22.7	1236	180	-1.10	-42.0	24.2
1103	140	-1.01	-36.7	7.6	1151	270	-1.04	-26.2	26.2	1237	20	-1.42	-44.7	22.7
1104	240	-1.60	-43.2	12.1	1152	90	-.84	-28.6	27.3	1238	150	-1.50	-52.9	29.6
1105	240	-1.28	-34.4	25.5	1153	330	-.70	-18.0	22.0	1239	150	-1.37	-48.5	27.6
1106	180	-1.18	-44.9	26.2	1154	270	-1.08	-27.1	21.0	1240	150	-1.35	-47.9	38.4
1107	80	-1.60	-56.7	30.0	1155	270	-1.23	-30.8	21.9	1241	330	-1.16	-37.2	19.4
1108	90	-1.47	-49.7	24.9	1156	30	.73	-16.3	24.7	1242	180	-1.21	-46.0	32.1
1109	140	-1.02	-37.3	18.5	1157	10	.82	-19.8	24.1	1243	190	-.84	-30.6	27.7
1110	140	-1.06	-38.7	18.7	1158	340	.87	-19.4	27.3	1244	130	.83	-24.1	28.0
1111	230	-1.28	-36.5	17.7	1159	270	-1.46	-36.6	21.5	1245	90	.70	-22.4	23.8
1112	120	-1.57	-52.0	19.1	1160	30	.73	-18.9	24.7	1246	70	.71	-24.5	26.9
1113	140	-.99	-35.9	21.8	1161	340	.87	-18.4	27.5	1247	130	-1.41	-47.6	29.4
1114	150	-.99	-33.5	22.9	1162	340	.91	-16.3	28.6	1248	10	-1.21	-33.4	30.6
1115	80	-1.26	-44.7	39.3	1163	270	-1.66	-41.6	20.9	1249	50	.44	-11.7	16.5
1116	90	-1.20	-40.7	36.7	1201	210	-1.99	-64.2	19.8	1250	50	.46	-13.3	17.0
1117	10	1.14	-29.7	33.2	1202	80	-1.48	-32.3	19.8	1251	50	.61	-15.9	22.6
1118	20	.97	-25.7	30.5	1203	180	-1.91	-72.6	17.5	1252	60	.60	-22.6	23.0
1119	350	.95	-27.3	30.0	1204	180	-1.47	-56.0	19.0	1253	30	.50	-12.6	16.8
1120	340	1.03	-22.7	32.6	1205	180	-1.15	-43.6	28.8	1254	40	.44	-13.7	16.1
1121	340	1.00	-24.9	31.6	1206	200	-1.25	-42.2	29.7	1255	50	.47	-13.2	17.4
1122	330	.97	-25.7	30.6	1207	200	-1.18	-40.0	34.8	1256	180	-.47	-17.8	14.7
1123	80	-1.37	-48.4	37.5	1208	210	-1.13	-36.4	31.8	1257	160	-.48	-17.6	13.8
1124	90	-1.39	-47.0	36.7	1209	190	-1.15	-41.8	29.2	1258	190	-.50	-18.2	14.8
1125	30	.91	-28.9	30.9	1210	180	-2.27	-86.2	10.9	1301	340	-1.54	-48.6	22.0
1126	30	.88	-24.4	29.6	1211	190	-2.17	-79.1	16.0	1302	190	-1.61	-58.8	23.8
1127	10	1.00	-19.2	29.4	1212	150	-1.09	-38.6	29.5	1303	140	-1.08	-39.4	33.7
1128	340	.93	-17.3	29.4	1213	160	-.91	-35.2	32.5	1304	90	-1.19	-40.3	24.3
1129	340	.96	-22.2	30.2	1214	150	1.05	-31.5	36.9	1305	110	-1.70	-55.1	13.7
1130	340	.93	-20.7	29.2	1215	90	1.02	-32.5	34.6	1306	40	-1.55	-36.5	35.1
1131	150	-1.39	-49.3	40.7	1216	80	.96	-32.1	33.9	1307	120	-1.18	-39.2	36.5
1132	80	-1.55	-54.8	31.8	1217	190	-2.07	-75.4	11.0	1308	130	-1.44	-48.7	6.8
1133	30	1.02	-33.9	34.4	1218	170	-1.82	-67.9	11.5	1309	50	-1.05	-39.1	35.2
1134	10	1.00	-23.1	29.3	1219	160	-1.45	-52.8	25.5	1310	120	-1.06	-34.9	34.4
1135	10	1.08	-19.5	31.6	1220	160	-.91	-33.4	31.4	1311	190	-1.07	-39.1	8.5
1136	350	1.00	-19.7	31.6	1221	120	.88	-24.4	29.1	1312	170	1.01	-33.7	37.7
1137	240	-1.05	-28.4	27.0	1222	70	1.02	-36.9	38.9	1313	180	.87	-23.2	33.2
1138	230	-.91	-25.9	25.3	1223	40	-1.04	-38.0	34.6	1314	110	-1.18	-38.0	12.5
1139	100	-1.52	-48.0	27.0	1224	180	-2.34	-89.1	8.8	1315	170	1.04	-34.1	38.6
1140	80	-1.14	-40.1	19.1	1225	180	-1.76	-67.0	13.4	1316	190	.94	-31.6	34.1
1141	150	-.88	-31.0	26.4	1226	170	-.83	-30.9	27.4	1317	180	-1.03	-39.1	9.8
1142	120	-.90	-29.7	24.6	1227	170	-.87	-32.3	31.7	1318	90	-1.36	-46.0	13.1
1143	350	.82	-24.0	25.9	1228	180	-1.28	-48.7	28.3	1319	180	1.15	-23.0	43.7
1144	350	.80	-20.4	25.4	1229	40	-.84	-30.8	29.4	1320	230	-1.19	-33.9	29.4
1145	350	.89	-21.0	28.0	1230	50	-.85	-31.5	29.9	1321	180	-1.02	-38.7	14.7
1146	340	.81	-22.3	25.6	1231	180	-1.10	-41.7	24.1	1322	220	-.58	-17.9	16.9
1147	340	.83	-25.2	26.3	1233	330	-1.22	-38.4	20.8	1323	180	-.75	-16.0	27.8
1148	110	-.93	-30.0	23.9	1234	190	-2.11	-77.1	32.3	1324	330	-.72	-22.6	21.6

TABLE 6A. PEAK LOADS FOR CONFIGURATION A : ONE LAKEWAY CENTER
LARGEST VALUES OF CLADDING LOAD REFERENCE PRESSURE = 38.0 PSF

TAP	AZI- MUTH	PRESS COEFF	NEGATIVE PEAK ----- PSF	POSITIVE PEAK ----- PSF	TAP	AZI- MUTH	PRESS COEFF	NEGATIVE PEAK ----- PSF	POSITIVE PEAK ----- PSF	TAP	AZI- MUTH	PRESS COEFF	NEGATIVE PEAK ----- PSF	POSITIVE PEAK ----- PSF
1325	190	-.87	-31.8	11.1	1425	10	-1.36	-39.7	21.9	1901	90	-1.33	-45.0	36.0
1326	90	-.92	-31.0	12.2	1426	20	-.73	-23.0	18.3	1902	330	-1.26	-39.7	16.4
1327	180	-.73	-17.6	28.4	1427	20	-.95	-29.9	16.8	1903	120	-.96	-31.7	7.2
1328	180	.60	-21.6	23.0	1428	200	-.99	-33.4	19.4	1904	200	-1.00	-33.8	12.8
1329	180	.71	-22.9	27.1	1429	180	-1.79	-67.9	25.2	1905	120	-1.19	-39.3	13.2
1330	170	.68	-18.1	25.5	1430	190	-2.55	-92.9	23.4	1906	70	-1.88	-71.4	26.4
1331	200	.74	-15.4	24.9	1431	260	-1.02	-24.8	24.3	1907	10	-1.97	-57.7	28.4
1332	220	.60	-17.3	18.5	1432	270	-1.25	-31.3	23.3	1908	330	-1.44	-45.3	15.0
1333	170	-.81	-30.3	13.5	1433	30	-.81	-27.5	21.5	1909	170	-1.46	-54.2	8.5
1334	190	.54	-17.8	19.9	1434	210	-.84	-27.1	20.2	1910	170	-.83	-31.0	9.5
1401	170	-1.11	-41.3	19.3	1435	210	-1.54	-49.6	23.6	1911	340	-.88	-27.8	9.3
1402	200	-1.44	-48.6	18.8	1436	200	-1.61	-54.4	24.5	1912	200	-.98	-33.3	7.6
1403	170	-.87	-32.5	24.5	1437	180	-1.61	-61.2	22.3	1913	150	-1.09	-38.4	19.8
1404	250	-1.72	-43.2	22.9	1438	260	-1.46	-35.5	27.4	1914	140	-.98	-28.5	35.7
1405	240	-1.42	-38.3	9.4	1439	220	-1.97	-60.6	22.8	1915	170	-1.03	-38.5	11.3
1406	180	-1.08	-41.2	10.5	1440	270	-1.81	-45.4	25.6	1916	80	-1.39	-49.2	7.3
1407	160	-1.21	-44.2	7.4	1441	190	-1.94	-70.9	23.9	1917	340	-1.17	-36.9	13.7
1408	180	-1.57	-59.5	8.3	1442	270	-1.40	-35.1	24.6	1918	170	-.89	-33.0	12.8
1409	180	-1.81	-69.0	10.1	1443	270	-1.14	-28.5	24.3	1919	170	-1.14	-42.4	11.9
1410	280	-1.15	-28.8	26.8	1444	220	-.69	-21.3	19.6	1920	180	-.93	-35.2	11.4
1411	290	1.09	-26.5	27.4	1445	220	-.83	-25.6	23.4	1921	170	-1.16	-43.0	10.9
1412	150	-.85	-30.1	18.8	1446	210	-1.04	-33.6	30.6	1922	140	-1.35	-49.3	13.1
1413	190	-.76	-27.6	19.5	1447	180	-1.01	-38.4	32.7	1923	190	-1.02	-37.1	11.4
1414	190	-1.26	-46.0	15.2	1448	180	-.96	-36.4	20.9	1924	170	-1.21	-45.0	19.0
1415	180	-1.54	-58.5	16.1	1449	180	-.72	-19.4	27.2	1925	210	-2.00	-64.6	11.8
1416	180	-1.97	-75.0	17.0	1450	270	-1.46	-36.7	24.3	1926	180	-1.18	-44.9	12.3
1417	350	-.99	-31.4	25.3	1451	270	-1.46	-36.6	23.2	1927	190	-1.33	-48.4	13.7
1418	10	-1.13	-33.1	25.3	1452	350	-.83	-21.2	26.1	1928	200	-1.62	-54.8	22.2
1419	190	-.61	-22.1	19.5	1453	200	-.62	-20.9	16.2	1929	190	-1.97	-71.9	27.2
1420	210	-.70	-22.7	19.3	1454	130	-.66	-22.2	17.9	1930	220	-2.04	-62.9	18.2
1421	200	-1.36	-46.0	18.6	1455	180	-.63	-24.1	20.0	1931	180	-1.46	-55.5	19.1
1422	180	-1.66	-62.9	21.8	1456	170	-.67	-24.9	19.4	1932	330	-1.45	-45.6	38.5
1423	190	-1.69	-61.7	13.5	1457	170	-1.47	-54.8	17.4	1933	170	-1.72	-63.9	25.2
1424	350	-1.09	-34.5	22.5										

TABLE 6A. PEAK LOADS FOR CONFIGURATION A : ONE LAKEMAY CENTER
LARGEST VALUES OF CLADDING LOAD REFERENCE PRESSURE = 38.0 PSF

* * 15 GREATEST PRESSURE MAGNITUDES * *

TAP	AZI- MUTH	PRESS COEFF	NEGATIVE PEAK ----- PSF	POSITIVE PEAK ----- PSF
1235	180	-2.54	-96.4	28.6
1430	190	-2.55	-92.9	23.4
1224	180	-2.34	-89.1	8.8
1210	180	-2.27	-86.2	10.9
1211	190	-2.17	-79.1	16.0
1234	190	-2.11	-77.1	32.3
1217	190	-2.07	-75.4	11.0
1416	180	-1.97	-73.0	17.0
1203	180	-1.91	-72.6	17.5
1929	190	-1.97	-71.9	27.2
1906	70	-1.88	-71.4	26.4
1441	190	-1.94	-70.9	23.9
1409	180	-1.81	-69.0	10.1
1429	180	-1.79	-67.9	25.2
1218	170	-1.82	-67.9	11.5

TABLE 6A. PEAK LOADS FOR CONFIGURATION A : TWO LAKEWAY CENTER
LARGEST VALUES OF CLADDING LOAD REFERENCE PRESSURE = 38.0 PSF

TAP	AZI-MUTH	PRESS COEFF	NEGATIVE PEAK	POSITIVE PEAK	TAP	AZI-MUTH	PRESS COEFF	NEGATIVE PEAK	POSITIVE PEAK	TAP	AZI-MUTH	PRESS COEFF	NEGATIVE PEAK	POSITIVE PEAK
			-----	PSF -----				-----	PSF -----				-----	PSF -----
2101	10	-1.98	-58.0	40.7	2149	310	-1.21	-31.3	30.0	2218	180	-1.43	-54.5	21.7
2102	190	-1.26	-45.9	32.9	2150	310	-1.34	-34.6	30.3	2219	180	-1.45	-55.0	24.8
2103	350	-1.99	-62.9	28.2	2151	40	1.00	-35.7	36.6	2220	180	-1.89	-71.7	27.1
2104	10	-1.69	-49.6	33.4	2152	50	1.03	-26.7	38.2	2221	170	-2.11	-78.5	37.5
2105	10	-1.69	-49.5	20.9	2153	60	1.78	-25.5	29.8	2222	180	-2.01	-76.3	32.1
2106	40	-1.51	-55.0	19.0	2154	300	-1.39	-35.9	28.4	2223	30	-1.58	-53.3	18.2
2107	140	-1.60	-58.3	29.9	2155	310	-1.62	-41.9	29.2	2224	180	-1.39	-49.0	12.7
2108	150	-1.32	-44.5	32.2	2156	40	1.85	-29.0	30.9	2225	190	-2.79	-101.8	21.4
2109	180	-1.18	-44.7	30.4	2157	310	-1.64	-42.4	27.3	2226	190	-1.61	-58.8	28.1
2110	210	-1.24	-40.1	26.2	2158	210	-1.08	-34.8	19.6	2227	190	-1.09	-39.6	22.9
2111	180	-1.36	-51.5	26.4	2159	170	-1.99	-36.7	22.6	2228	40	-1.30	-47.5	16.0
2112	160	-1.14	-41.5	19.1	2160	180	-1.65	-62.7	27.6	2229	180	-1.23	-46.8	14.3
2113	180	-1.55	-58.9	23.2	2161	290	-1.55	-38.8	34.4	2230	200	-1.67	-56.4	31.7
2114	170	-1.87	-69.6	24.4	2162	40	1.92	-29.5	33.4	2231	340	-1.06	-33.5	21.3
2115	120	-1.70	-56.1	35.3	2163	60	1.07	-25.9	40.7	2232	30	-1.14	-38.4	33.6
2116	100	-1.47	-46.4	40.9	2164	70	1.09	-23.9	41.3	2233	150	-1.05	-35.8	37.3
2117	150	-1.11	-39.1	33.6	2165	300	-1.09	-28.3	22.5	2234	220	-1.45	-44.5	10.7
2118	50	1.98	-28.8	36.7	2166	300	-1.07	-27.5	21.0	2235	70	-1.69	-64.3	20.0
2119	60	1.00	-30.7	38.1	2167	310	-1.96	-50.7	19.2	2236	180	-1.40	-53.3	18.8
2120	50	1.98	-36.0	36.3	2168	310	-1.73	-44.6	21.6	2237	190	-1.80	-29.2	19.2
2121	180	-1.24	-47.1	30.6	2169	180	-1.47	-55.7	25.4	2238	140	-1.02	-37.4	23.2
2122	190	-2.07	-75.5	31.5	2170	190	-1.12	-40.7	27.5	2239	130	-1.94	-31.7	21.6
2123	120	-1.89	-62.5	24.3	2171	300	-1.20	-31.0	29.6	2240	130	-1.95	-32.0	18.7
2124	120	-1.43	-47.1	21.8	2172	60	-1.03	-39.1	25.9	2241	50	-1.81	-30.3	17.1
2125	150	-1.01	-35.8	26.3	2173	180	-1.08	-41.0	26.4	2242	130	-1.95	-32.3	20.5
2126	50	1.95	-25.4	35.3	2174	190	-1.97	-35.6	30.9	2243	140	-1.86	-31.3	9.4
2127	60	1.02	-26.6	38.9	2175	180	-1.88	-33.5	27.5	2244	190	-1.45	-52.9	9.3
2128	50	1.99	-28.1	37.0	2176	60	1.02	-27.8	38.6	2245	220	-1.11	-34.2	12.2
2129	180	-1.04	-39.4	29.9	2177	40	-2.02	-73.6	19.5	2246	210	-1.89	-28.7	11.4
2130	190	-1.00	-36.4	29.1	2178	30	1.09	-29.4	36.8	2247	190	-1.36	-49.6	23.3
2131	120	-1.61	-53.3	11.2	2179	40	-1.11	-40.4	20.5	2248	120	-1.82	-27.0	9.8
2132	120	-1.33	-44.1	10.6	2201	220	-2.16	-66.6	40.0	2249	190	-1.65	-23.8	15.3
2133	200	-1.00	-33.8	25.0	2202	70	-1.83	-69.6	30.1	2250	290	-1.13	-28.3	15.4
2134	50	1.87	-24.9	32.5	2203	160	-2.04	-75.1	24.1	2251	290	-1.60	-40.2	16.6
2135	60	1.11	-25.0	42.1	2204	180	-1.49	-56.6	27.6	2252	330	1.67	-16.6	21.0
2136	70	1.88	-29.3	33.5	2205	150	-3.28	-115.9	31.7	2253	50	1.70	-17.0	26.2
2137	310	-1.27	-32.9	28.3	2206	170	-1.93	-72.0	32.1	2254	100	1.71	-17.1	23.5
2138	320	-1.48	-38.2	29.3	2207	160	-1.42	-51.9	32.4	2255	10	1.82	-14.1	24.1
2139	120	-1.33	-43.9	16.0	2208	40	-1.41	-51.5	29.8	2256	130	-1.71	-24.2	22.1
2140	190	-1.04	-37.8	16.2	2209	40	-2.09	-76.3	30.9	2257	10	-1.31	-38.5	19.5
2141	180	-1.88	-33.4	25.1	2210	140	-1.75	-63.9	30.0	2258	200	-1.54	-52.2	24.1
2142	50	1.91	-25.6	34.0	2211	150	-1.61	-56.7	35.6	2259	60	1.63	-20.3	23.8
2143	60	1.84	-30.1	31.7	2212	180	-1.38	-52.3	32.5	2260	60	1.54	-19.2	20.5
2144	310	-1.31	-34.0	31.4	2213	40	-1.49	-54.3	35.4	2261	290	-1.93	-48.5	21.6
2145	310	-1.39	-36.0	25.9	2214	180	-1.48	-56.2	39.6	2262	180	-1.57	-21.6	15.4
2146	310	-1.92	-49.7	29.1	2215	140	-1.65	-60.2	27.2	2301	40	-1.53	-56.0	37.8
2147	180	-1.19	-45.1	20.7	2216	170	-1.58	-58.7	30.5	2302	210	-1.50	-48.4	32.5
2148	50	1.98	-27.5	36.5	2217	190	-1.55	-56.7	33.2	2303	180	-1.82	-69.2	22.9

TABLE 6A. PEAK LOADS FOR CONFIGURATION A : TWO LAKEWAY CENTER
LARGEST VALUES OF CLADDING LOAD REFERENCE PRESSURE = 38.0 PSF

TAP	AZI-MUTH	PRESS COEFF	NEGATIVE PEAK	POSITIVE PEAK	TAP	AZI-MUTH	PRESS COEFF	NEGATIVE PEAK	POSITIVE PEAK	TAP	AZI-MUTH	PRESS COEFF	NEGATIVE PEAK	POSITIVE PEAK
			PSF	PSF				PSF	PSF				PSF	PSF
23304	280	-2.24	-56.2	13.7	23352	40	-1.68	-24.7	14.0	2434	150	-1.31	-46.3	21.6
23305	180	-1.05	-39.8	29.5	23353	40	-1.72	-26.3	7.8	2435	0	-1.59	-42.8	22.5
23306	180	-2.46	-93.4	11.0	23354	40	-1.99	-35.9	6.3	2436	20	-1.21	-38.1	21.3
23307	70	-1.55	-58.7	25.1	23355	180	-1.06	-40.3	16.8	2437	180	-1.31	-45.9	18.8
23308	70	-1.43	-54.5	23.3	23356	40	-1.65	-23.6	8.5	2438	190	-2.31	-84.3	19.3
23309	70	-1.34	-51.0	20.3	23357	40	-1.58	-21.3	15.2	2439	200	-2.38	-77.2	19.1
23310	70	-2.05	-78.1	17.8	23358	40	-1.65	-23.8	8.2	2440	10	-1.78	-51.9	26.4
23311	40	-1.43	-52.0	21.5	23359	40	-1.85	-31.1	4.6	2441	180	-1.97	-36.7	20.2
23312	90	-1.86	-62.9	30.6	23360	190	-1.90	-33.0	15.8	2442	180	-1.60	-60.6	22.9
23313	120	-1.88	-62.0	33.3	23361	40	-1.53	-19.3	8.5	2443	30	-1.42	-48.0	25.1
23314	50	-1.38	-51.4	30.1	23362	40	-1.80	-29.3	20.5	2444	0	-1.93	-52.0	27.5
23315	70	-1.10	-41.9	31.6	23363	40	-1.58	-21.3	11.6	2445	10	-1.48	-43.3	24.6
23316	180	.92	-32.6	35.0	23364	50	-1.55	-20.6	9.3	2446	10	-1.37	-40.0	20.9
23317	170	.95	-34.4	35.5	23365	50	-1.68	-25.2	7.6	2447	180	-1.18	-44.9	17.9
23318	170	.98	-36.4	36.5	23366	160	-1.66	-23.9	22.6	2448	180	-1.72	-65.3	20.4
23319	90	-1.78	-60.2	36.5	23401	170	-1.48	-35.0	35.9	2449	180	-1.78	-67.8	21.6
23320	90	-1.74	-58.8	32.6	23402	200	-1.69	-57.1	21.4	2450	40	-1.08	-39.4	35.3
23321	40	-1.41	-51.3	29.8	23403	80	-1.33	-47.0	37.1	2451	40	-1.13	-40.7	32.2
23322	50	-1.26	-46.9	33.6	23404	50	-1.50	-35.8	8.9	2452	0	-1.78	-48.0	22.2
23323	180	.96	-35.8	36.5	23405	170	-1.97	-73.2	20.5	2453	190	-3.25	-118.6	17.8
23324	170	.97	-32.8	36.0	23406	170	-1.94	-72.4	17.6	2454	50	-1.72	-26.6	20.3
23325	70	-1.08	-41.0	37.7	23407	180	-1.25	-47.4	12.7	2455	180	-1.85	-32.4	23.5
23326	100	-1.82	-57.3	34.0	23408	190	-1.70	-61.9	15.4	2456	0	-2.65	-71.6	15.1
23327	100	-1.72	-54.4	28.4	23409	190	-1.68	-61.2	13.2	2457	0	-1.54	-41.6	16.3
23328	50	-1.21	-45.0	26.6	23410	30	-1.60	-54.0	18.6	2458	10	-1.32	-38.7	17.4
23329	40	-1.30	-47.6	30.1	23411	210	-2.46	-79.5	20.4	2459	170	-1.05	-38.9	20.8
23330	280	-1.58	-39.6	30.5	23412	160	-1.35	-49.2	29.2	2460	180	-1.46	-55.4	17.5
23331	60	-1.13	-43.1	36.3	23413	350	-1.33	-41.9	27.3	2461	190	-1.59	-58.2	16.9
23332	70	-1.14	-43.2	32.8	23414	0	-1.83	-49.4	26.7	2462	190	-1.42	-51.9	16.4
23333	70	-1.49	-56.6	30.3	23415	180	-1.98	-37.4	24.7	2463	180	-1.78	-29.6	13.6
23334	70	-1.38	-52.3	33.4	23416	190	-1.28	-46.5	23.3	2464	180	-1.64	-24.5	15.5
23335	270	-2.98	-74.7	22.2	23417	30	-1.31	-44.3	26.7	2465	10	-1.44	-42.1	22.9
23336	280	-1.82	-45.6	21.3	23418	200	-1.25	-42.2	25.6	2466	10	-1.24	-36.3	27.5
23337	50	-1.03	-38.3	31.9	23419	350	-1.58	-49.8	30.8	2467	10	-1.21	-35.3	26.1
23338	30	-1.17	-39.9	32.9	23420	0	-1.29	-34.7	29.2	2468	260	-1.20	-29.2	29.3
23339	40	-1.45	-52.9	32.4	23421	0	-1.44	-39.0	25.7	2469	350	-1.52	-48.1	23.9
23340	60	-1.40	-53.3	22.1	23422	180	-1.96	-36.3	23.7	2470	10	-1.07	-31.4	19.2
23341	90	-1.87	-63.2	18.9	23423	180	-1.16	-43.9	24.5	2471	40	-1.76	-27.8	19.1
23342	280	-1.91	-47.9	20.9	23424	200	-1.35	-45.8	23.7	2472	40	-1.73	-26.7	23.0
23343	30	-1.03	-34.8	30.1	23425	20	-1.33	-42.1	26.5	2801	0	-2.03	-54.8	10.4
23344	80	-1.04	-36.8	13.9	23426	350	-1.20	-37.8	28.0	2802	0	-1.76	-47.4	10.7
23345	40	-1.87	-51.7	18.9	23427	350	-1.64	-51.8	25.7	2803	300	-1.42	-36.6	10.3
23346	40	-1.17	-42.7	34.1	23428	0	-1.58	-42.6	24.5	2804	50	-1.48	-55.0	9.1
23347	40	-1.12	-40.9	36.0	23429	190	-1.01	-37.0	23.9	2805	70	-1.64	-62.5	16.2
23348	40	-1.06	-38.5	26.0	23430	180	-1.29	-49.1	23.7	2806	170	-1.16	-43.2	9.2
23349	180	-1.03	-36.5	39.3	23431	190	-1.48	-53.9	22.5	2807	180	-1.66	-25.1	11.6
23350	70	-1.13	-42.8	29.3	23432	220	-1.54	-48.5	21.5	2808	170	-1.51	-19.1	15.4
23351	70	-2.02	-76.8	20.6	23433	350	-1.96	-61.7	22.9	2901	350	-3.10	-97.7	9.0

TABLE 6A. PEAK LOADS FOR CONFIGURATION A : TWO LAKEWAY CENTER
LARGEST VALUES OF CLADDING LOAD REFERENCE PRESSURE = 38.0 PSF

TAP	AZI-MUTH	PRESS COEFF	NEGATIVE PEAK	POSITIVE PEAK	TAP	AZI-MUTH	PRESS COEFF	NEGATIVE PEAK	POSITIVE PEAK	TAP	AZI-MUTH	PRESS COEFF	NEGATIVE PEAK	POSITIVE PEAK
			PSF	PSF				PSF	PSF				PSF	PSF
2902	330	-2.33	-73.6	11.6	2925	50	-1.47	-54.9	6.9	2948	240	-2.42	-65.3	12.2
2903	180	-1.23	-46.9	40.7	2926	60	-1.86	-70.8	3.2	2949	180	-3.11	-118.1	1.3
2904	160	-1.95	-34.7	29.4	2927	170	-2.17	-80.8	33.1	2950	30	-1.72	-58.1	7.3
2905	300	-1.69	-43.8	21.5	2928	170	-1.99	-36.7	14.6	2951	190	-1.66	-60.4	22.3
2906	300	-2.40	-62.1	15.3	2929	290	-1.66	-41.5	12.7	2952	50	-2.07	-77.0	20.9
2907	70	-1.71	-65.0	11.0	2930	190	-1.96	-35.0	11.9	2953	220	-2.39	-73.7	8.2
2908	40	1.14	-25.7	41.7	2931	180	-1.14	-43.5	10.8	2954	180	-1.40	-53.4	10.9
2909	190	-1.88	-32.2	26.3	2932	80	-2.05	-72.5	6.3	2955	180	-1.51	-57.6	12.7
2910	230	-1.84	-52.4	8.3	2933	190	-1.43	-52.0	9.2	2956	30	-1.44	-48.5	9.5
2911	170	-1.31	-48.7	9.5	2934	220	-2.58	-79.6	2.0	2957	180	-1.13	-43.0	27.0
2912	50	1.12	-40.7	41.7	2935	70	-2.39	-90.8	4.8	2958	50	-1.80	-67.0	14.8
2913	190	-1.30	-47.5	37.8	2936	190	-1.90	-32.7	23.3	2959	50	-1.26	-46.9	26.1
2914	190	-1.19	-43.3	22.5	2937	180	-1.40	-53.2	9.4	2960	190	1.14	-41.1	41.7
2915	180	-1.08	-40.9	22.2	2938	190	-1.32	-48.1	9.8	2961	40	-1.23	-44.7	40.5
2916	220	-1.17	-35.9	15.2	2939	70	-1.71	-65.1	6.0	2962	40	-1.98	-35.9	22.1
2917	340	-2.45	-77.3	1.6	2940	180	-1.48	-56.4	17.3	2963	280	-2.86	-71.8	20.0
2918	170	-1.40	-52.2	6.1	2941	40	-1.84	-30.8	16.5	2964	50	-1.09	-40.5	37.9
2919	70	-1.88	-33.2	33.3	2942	160	-1.24	-45.1	20.9	2965	40	-1.06	-38.7	37.5
2920	190	-1.58	-57.5	21.5	2943	130	-1.08	-36.5	19.9	2966	190	1.02	-33.8	37.1
2921	300	-1.58	-40.7	13.1	2944	150	-1.94	-33.2	18.6	2967	60	-1.05	-39.8	28.7
2922	150	-1.13	-39.9	14.8	2945	190	-1.10	-40.1	29.9	2968	40	-2.07	-75.5	17.8
2923	150	-1.96	-34.0	11.2	2946	290	-1.09	-27.3	19.7	2969	280	-1.73	-43.4	34.7
2924	280	-2.75	-69.1	1.6	2947	100	-1.04	-32.8	25.3	2970	70	-1.42	-53.9	39.7

TABLE 6A. PEAK LOADS FOR CONFIGURATION A : TWO LAKEWAY CENTER
LARGEST VALUES OF CLADDING LOAD REFERENCE PRESSURE = 38.0 PSF

* * 15 GREATEST PRESSURE MAGNITUDES * *

TAP	AZI- MUTH	PRESS COEFF	NEGATIVE PEAK ----- PSF	POSITIVE PEAK ----- PSF
2453	190	-3.25	-118.6	17.8
2949	180	-3.11	-118.1	1.3
2205	150	-3.28	-115.9	31.7
2225	190	-2.79	-101.8	21.4
2901	350	-3.10	-97.7	9.0
2306	180	-2.46	-93.4	11.0
2935	70	-2.39	-90.8	4.8
2438	190	-2.31	-84.3	19.2
2927	170	-2.17	-80.8	33.1
2934	220	-2.58	-79.6	2.0
2411	210	-2.46	-79.5	20.4
2221	170	-2.11	-78.5	27.5
2310	70	-2.05	-78.1	17.8
2917	340	-2.45	-77.3	1.6
2439	200	-2.28	-77.2	19.1

TABLE 6A. PEAK LOADS FOR CONFIGURATION A : THREE LAKEWAY CENTER
LARGEST VALUES OF CLADDING LOAD REFERENCE PRESSURE = 38.0 PSF

TAP	AZI- MUTH	PRESS COEFF	NEGATIVE PEAK PSF	POSITIVE PEAK PSF	TAP	AZI- MUTH	PRESS COEFF	NEGATIVE PEAK PSF	POSITIVE PEAK PSF	TAP	AZI- MUTH	PRESS COEFF	NEGATIVE PEAK PSF	POSITIVE PEAK PSF
31101	70	-1.81	-1.69	23.3	31149	330	-1.53	-48.4	33.0	3227	130	-1.43	-48.4	41.8
31102	70	-1.57	-1.59	17.2	31150	80	-1.41	-49.8	26.8	3228	140	-1.32	-48.1	41.1
31103	80	-1.45	-1.51	16.9	31151	80	-1.42	-50.3	28.2	3229	140	-1.05	-38.3	38.3
31104	80	-1.06	-1.37	18.3	31152	80	-1.40	-49.5	26.1	3230	140	-1.17	-42.5	40.2
31105	290	-2.09	-1.52	21.5	31153	80	-1.45	-51.1	24.9	3231	120	-1.39	-46.0	34.6
31106	80	-1.93	-1.68	23.6	31154	290	-1.81	-45.3	29.5	3232	130	-1.45	-49.0	35.9
31107	80	-1.86	-1.65	23.6	31155	290	-2.11	-52.9	29.0	3233	130	-1.61	-54.5	40.5
31108	80	-1.21	-1.42	27.9	31156	330	-1.64	-55.6	29.7	3234	60	-1.19	-43.5	45.4
31109	290	-2.16	-1.54	28.1	31157	330	-1.29	-40.7	34.6	3235	140	-1.19	-43.5	38.5
31110	290	-2.00	-1.50	27.9	31158	80	-2.51	-88.7	32.7	3236	330	-1.38	-43.3	34.7
31111	80	-1.31	-1.46	25.7	31159	80	-1.73	-61.0	33.7	3237	120	-1.53	-50.5	36.3
31112	80	-1.09	-1.38	31.4	31160	80	-1.16	-41.1	37.3	3238	120	-1.43	-47.7	35.5
31113	90	-1.75	-1.59	32.2	31161	290	-1.15	-40.9	35.0	3239	130	-1.49	-50.2	41.2
31114	80	-1.56	-1.55	33.0	31162	2290	-1.71	-43.0	39.0	3240	140	-1.47	-50.6	43.4
31115	290	-2.20	-1.55	33.0	31163	2290	-2.00	-50.2	36.7	3241	140	-1.31	-47.7	38.5
31116	300	-1.56	-1.40	33.3	31164	40	-2.28	-83.3	30.1	3242	320	-1.70	-54.0	40.3
31117	80	-1.44	-1.33	32.3	31165	80	-1.52	-53.6	33.6	3243	140	-1.37	-50.0	45.1
31118	70	-1.41	-1.53	33.8	31166	80	-1.19	-42.2	25.9	3244	140	-1.23	-45.1	37.6
31119	80	-1.23	-1.43	32.8	31167	340	-1.51	-47.7	32.0	3245	40	-1.06	-35.9	38.6
31120	220	-1.43	-1.44	32.2	31168	340	-1.50	-47.7	15.2	3246	130	-1.46	-49.9	34.5
31121	330	-1.47	-1.46	32.4	31169	320	-1.60	-49.3	30.5	3247	130	-1.60	-53.5	32.0
31122	70	-1.35	-1.51	31.2	31170	30	-2.10	-70.9	14.2	3248	130	-2.54	-83.3	39.2
31123	290	-3.03	-1.75	33.2	32001	70	-1.76	-67.0	25.3	3249	130	-2.41	-81.4	38.3
31124	40	-1.96	-1.66	34.5	32002	70	-1.55	-59.0	11.2	3250	50	-0.99	-36.4	36.8
31125	150	-1.20	-1.42	34.4	32003	70	-1.80	-68.5	10.7	3251	220	-1.82	-56.1	40.0
31126	70	-1.18	-1.44	31.7	32004	70	-1.66	-63.0	5.7	3252	220	-1.35	-41.6	38.5
31127	80	-1.57	-1.55	33.4	32005	130	-1.21	-40.9	24.8	3253	310	-1.76	-60.0	32.9
31128	80	-1.27	-1.44	33.4	32006	240	-1.54	-41.5	23.1	3254	310	-2.32	-63.3	31.1
31129	80	-1.27	-1.44	33.5	32007	140	-1.53	-58.0	15.3	3255	140	-1.43	-52.2	35.6
31130	290	-1.69	-1.42	33.3	32008	140	-1.37	-50.0	12.9	3256	140	-1.42	-51.7	36.7
31131	290	-1.61	-1.40	33.6	32009	160	-1.51	-55.2	17.2	3257	140	-1.01	-36.9	35.9
31132	20	-2.40	-1.75	33.4	32010	160	-2.14	-78.2	18.1	3258	50	-1.00	-32.2	37.2
31133	140	-1.10	-1.40	33.4	32011	330	-1.69	-53.4	20.0	3259	40	-1.70	-62.2	32.7
31134	80	-1.31	-1.46	32.6	32012	130	-1.14	-38.6	34.3	3260	140	-1.50	-63.4	32.4
31135	70	-1.17	-1.44	33.2	32013	130	-1.29	-45.6	34.6	3261	130	-1.87	-63.3	33.3
31136	80	-1.23	-1.43	33.8	32014	140	-1.23	-44.8	32.6	3262	140	-1.68	-61.1	39.2
31137	80	-1.30	-1.45	33.3	32015	140	-1.26	-45.9	29.1	3263	130	-2.16	-72.9	40.5
31138	290	-1.47	-1.36	33.4	32016	150	-1.42	-50.0	28.6	3264	50	-1.05	-33.3	39.0
31139	90	-1.21	-1.41	33.7	32017	150	-1.43	-50.0	20.6	3265	60	-1.17	-30.0	44.4
31140	230	-2.01	-1.57	33.3	32018	330	-1.49	-47.4	29.6	3266	60	-1.02	-38.8	38.7
31141	150	-1.18	-1.41	33.4	32019	130	-1.14	-38.5	35.7	33001	60	-1.72	-65.3	14.4
31142	80	-1.25	-1.44	31.2	32200	130	-1.32	-44.8	36.4	33002	190	-1.49	-54.4	32.1
31143	90	-1.46	-1.52	32.4	32201	140	-1.27	-46.4	40.1	33003	60	-1.63	-61.1	22.5
31144	70	-1.09	-1.41	33.3	32202	140	-1.28	-46.4	37.5	33004	50	-1.48	-55.5	19.7
31145	80	-1.31	-1.46	32.4	32203	140	-1.13	-41.1	37.0	33005	60	-1.73	-65.3	20.3
31146	300	-2.04	-1.52	33.7	32204	340	-1.23	-39.9	37.4	33006	70	-2.09	-74.9	23.9
31147	90	-1.27	-1.43	33.0	32205	130	-1.19	-40.0	39.2	33007	70	-2.75	-104.6	26.9
31148	290	-1.96	-1.53	32.0	32206	120	-1.36	-44.8	36.3	33008	210	-2.19	-70.7	32.5

TABLE 6A. PEAK LOADS FOR CONFIGURATION A : THREE LAKEWAY CENTER
LARGEST VALUES OF CLADDING LOAD REFERENCE PRESSURE = 38.0 PSF

TAP	AZI- MUTH	PRESS COEFF	NEGATIVE PEAK ----- PSF	POSITIVE PEAK ----- PSF	TAP	AZI- MUTH	PRESS COEFF	NEGATIVE PEAK ----- PSF	POSITIVE PEAK ----- PSF	TAP	AZI- MUTH	PRESS COEFF	NEGATIVE PEAK ----- PSF	POSITIVE PEAK ----- PSF
3309	50	-1.36	-50.6	35.6	3421	160	-1.36	-49.7	39.1	3505	310	-2.12	-54.7	19.4
3310	60	-1.42	-53.8	31.8	3422	60	-1.49	-56.7	39.6	3506	60	-1.27	-48.1	18.7
3311	70	-2.19	-63.1	28.0	3423	60	-1.82	-69.0	39.1	3507	130	-1.26	-42.6	15.5
3312	70	-3.08	-117.2	31.5	3424	60	-1.79	-68.0	40.0	3508	70	-1.90	-72.2	15.6
3313	70	-1.81	-68.7	39.1	3425	60	-1.14	-43.3	37.3	3509	70	-1.61	-61.0	13.0
3314	70	-2.01	-76.2	37.5	3426	60	-1.40	-53.3	44.3	3510	330	-1.97	-62.1	17.8
3315	70	-1.83	-69.6	36.3	3427	60	-1.41	-53.4	40.8	3511	140	-1.60	-58.3	19.2
3316	70	-1.83	-69.5	36.3	3428	60	-1.43	-54.3	41.5	3512	300	-2.67	-69.1	24.8
3317	60	-1.87	-71.2	39.3	3429	60	-1.31	-49.9	40.1	3513	310	-2.78	-71.9	25.3
3318	70	-1.93	-74.2	37.1	3430	60	-1.25	-47.7	42.8	3514	40	-1.13	-41.4	25.2
3319	70	-1.66	-63.2	34.3	3431	60	-1.19	-45.1	39.2	3515	80	-1.37	-48.3	26.6
3320	70	-1.72	-65.4	32.4	3432	210	-2.03	-65.5	38.2	3516	70	-1.55	-58.9	25.6
3321	60	-1.81	-68.8	30.9	3433	60	-1.05	-39.8	39.2	3517	150	-1.46	-51.5	31.5
3322	70	-1.80	-68.3	30.6	3434	60	-1.25	-47.6	42.8	3518	60	-1.39	-52.3	31.2
3323	70	-1.78	-67.3	33.1	3435	60	-1.20	-45.7	39.6	3519	310	-1.52	-39.3	27.3
3324	60	-1.77	-67.2	31.5	3436	60	-1.38	-52.4	40.4	3520	320	-1.78	-46.0	29.2
3325	70	-1.77	-67.1	30.8	3437	60	-1.41	-53.7	41.2	3521	300	-1.76	-45.3	25.7
3326	60	-1.99	-75.6	36.0	3438	60	-1.31	-49.6	40.3	3522	310	-1.41	-36.5	24.4
3327	60	-1.63	-62.8	34.4	3439	60	-1.41	-53.7	40.3	3523	310	-1.30	-33.5	28.5
3328	60	-2.03	-77.1	32.3	3440	60	-1.88	-71.3	38.4	3524	320	-1.35	-35.0	32.5
3329	60	-2.15	-81.5	31.1	3441	150	-1.33	-47.1	37.7	3525	140	-1.07	-39.2	34.4
3330	70	-2.40	-91.1	31.1	3442	60	-1.07	-40.5	36.2	3526	140	-1.15	-42.0	36.1
3331	70	-2.13	-81.0	30.9	3443	60	-1.14	-43.5	42.8	3527	300	-1.57	-40.6	23.7
3332	70	-1.73	-65.9	30.8	3444	70	-1.27	-44.4	38.8	3528	310	-2.14	-55.2	27.0
3333	210	-1.48	-47.9	32.6	3445	70	-1.17	-48.1	41.7	3529	310	-1.68	-43.5	33.9
3334	70	-2.69	-102.4	32.7	3446	60	-1.35	-51.2	38.5	3530	140	-1.98	-35.8	34.1
3335	70	-2.47	-94.0	30.1	3447	70	-1.13	-42.9	39.3	3531	140	-1.09	-39.9	33.3
3336	60	-2.00	-75.9	27.9	3448	60	-1.86	-70.5	38.0	3532	60	-1.99	-37.7	36.7
3401	60	-1.24	-47.1	21.8	3449	140	-1.37	-50.0	36.4	3533	300	-2.04	-52.7	23.6
3402	60	-1.20	-45.4	20.0	3450	60	-1.98	-37.1	35.5	3534	310	-1.98	-51.2	23.5
3403	60	-1.63	-62.9	20.1	3451	310	-1.68	-41.3	36.0	3535	310	-1.44	-37.1	31.2
3404	60	-1.53	-58.1	22.3	3452	60	-1.12	-42.7	36.6	3536	340	-1.24	-39.2	31.8
3405	70	-1.54	-58.6	22.7	3453	60	-1.14	-43.3	36.8	3537	140	-1.07	-39.2	35.7
3406	60	-1.33	-50.5	32.1	3454	60	-1.47	-56.0	38.7	3538	150	-1.10	-38.8	35.1
3407	60	-1.31	-49.7	33.0	3455	60	-1.34	-50.8	38.7	3539	300	-1.96	-50.6	26.2
3408	60	-1.51	-57.4	31.1	3456	170	-1.68	-63.8	34.7	3540	300	-1.85	-47.8	24.4
3409	60	-1.93	-74.2	33.3	3457	130	-1.46	-49.3	30.2	3541	320	-1.67	-43.1	33.6
3410	60	-1.63	-62.6	33.3	3458	250	-1.60	-40.1	36.2	3542	320	-1.45	-37.5	33.3
3411	60	-1.26	-47.7	34.7	3459	310	-1.88	-48.5	34.7	3543	140	-1.20	-43.9	38.6
3412	60	-1.41	-53.8	34.0	3460	100	-1.29	-40.6	34.7	3544	140	-1.30	-47.4	34.5
3413	70	-1.27	-48.2	37.2	3461	100	-1.59	-50.1	36.6	3545	50	-1.04	-36.8	31.6
3414	60	-1.62	-61.5	37.5	3462	60	-1.60	-60.8	37.3	3546	60	-1.98	-37.7	32.4
3415	60	-1.44	-54.5	35.3	3463	60	-1.57	-59.6	38.2	3547	140	-1.10	-40.2	37.0
3416	60	-1.54	-58.4	40.3	3464	210	-1.87	-60.5	36.6	3548	310	-2.89	-74.7	22.4
3417	60	-1.80	-68.3	39.2	3501	60	-1.42	-53.9	14.6	3549	320	-1.89	-49.0	24.5
3418	70	-1.10	-42.0	40.7	3502	180	-1.30	-49.4	7.5	3550	310	-1.99	-51.4	29.0
3419	60	-1.55	-58.7	37.7	3503	190	-1.27	-46.5	7.3	3551	340	-1.25	-39.3	29.0
3420	70	-1.55	-58.8	37.5	3504	90	-2.03	-68.5	3.7	3552	140	-1.23	-44.9	32.3

TABLE 6A. PEAK LOADS FOR CONFIGURATION A : THREE LAKEWAY CENTER
LARGEST VALUES OF CLADDING LOAD REFERENCE PRESSURE = 38.9 PSF

TAP	AZI- MUTH	PRESS COEFF	NEGATIVE PEAK PSF	POSITIVE PEAK PSF	TAP	AZI- MUTH	PRESS COEFF	NEGATIVE PEAK PSF	POSITIVE PEAK PSF	TAP	AZI- MUTH	PRESS COEFF	NEGATIVE PEAK PSF	POSITIVE PEAK PSF
35533	50	-1.90	-33.4	30.9	3641	220	-1.77	-54.5	33.9	3689	50	-1.92	-34.1	27.9
35534	50	-1.88	-32.9	30.2	3642	230	-1.90	-54.2	30.9	3690	60	-1.01	-38.4	27.7
35535	40	-1.02	-32.2	33.5	3643	240	-2.46	-68.4	23.1	3691	60	-1.24	-47.0	24.3
35536	320	-1.97	-50.8	22.1	3644	290	-2.12	-53.1	21.4	3692	60	-1.18	-45.0	24.4
35537	330	-1.79	-56.3	23.6	3645	180	-1.45	-55.1	26.4	3693	60	-1.35	-51.5	25.5
35538	310	-1.78	-46.0	27.7	3646	350	-2.02	-63.8	33.4	3694	60	-1.70	-64.4	23.8
35539	330	-1.17	-37.0	31.3	3647	180	-1.45	-55.1	28.3	3695	60	-1.89	-71.9	26.2
35560	140	-1.17	-42.7	37.8	3648	30	-1.16	-39.1	30.7	3696	60	-1.63	-62.0	28.6
3601	60	-1.64	-62.2	12.6	3649	340	-1.77	-53.9	32.1	3697	60	-2.23	-84.9	25.1
3602	60	-1.72	-65.5	19.8	3650	340	-2.61	-82.4	33.4	3698	40	-1.33	-48.7	23.7
3603	40	-1.64	-59.8	21.0	3651	180	-1.02	-38.6	21.6	3699	50	-1.72	-64.1	21.5
3604	40	-1.26	-46.1	20.7	3652	180	-1.22	-46.3	28.6	3700	60	-1.56	-59.2	19.4
3605	240	-1.77	-47.9	19.6	3653	190	-1.00	-36.6	29.5	3701	160	-1.33	-48.6	16.4
3606	70	-1.30	-57.2	28.0	3654	80	-1.83	-58.8	29.5	3702	300	-1.42	-56.7	22.5
3607	240	-1.98	-53.3	21.3	3655	350	-1.26	-59.7	29.1	3703	50	-1.79	-69.3	23.2
3608	40	-1.83	-66.7	30.8	3656	210	-1.37	-44.5	35.8	3704	50	-1.98	-86.3	26.1
3609	80	-1.58	-56.7	28.8	3657	180	-1.84	-52.6	26.3	3705	40	-1.95	-84.7	34.2
3610	50	-1.24	-46.2	30.0	3658	180	-1.87	-53.1	24.3	3706	190	-1.90	-81.9	32.8
3611	230	-2.08	-59.9	28.6	3659	90	-1.85	-55.1	28.8	3707	180	-1.93	-82.7	35.4
3612	250	-2.33	-59.0	27.9	3660	70	-1.82	-56.0	31.0	3708	170	-1.84	-80.3	31.2
3613	40	-1.26	-45.9	31.1	3661	350	-1.16	-36.6	32.1	3709	50	-1.94	-85.0	31.9
3614	230	-1.67	-47.7	29.6	3662	220	-1.53	-47.2	31.4	3710	40	-1.03	-37.5	31.0
3615	80	-1.52	-53.8	28.2	3663	170	-1.68	-62.4	25.0	3711	50	-1.12	-41.7	27.1
3616	60	-1.35	-51.2	29.9	3664	280	-2.11	-52.9	33.1	3712	60	-1.40	-53.0	26.8
3617	30	-1.46	-49.4	31.1	3665	280	-1.75	-43.8	27.1	3713	60	-1.92	-73.0	21.9
3618	230	-1.93	-53.1	28.8	3666	250	-2.01	-50.4	34.1	3714	60	-1.81	-68.9	24.5
3619	60	-1.45	-53.2	27.7	3667	190	-1.87	-51.3	31.8	3715	60	-1.78	-67.6	23.0
3620	70	-1.75	-66.4	28.7	3668	170	-1.99	-52.8	36.9	3716	340	-1.99	-82.8	17.0
3621	90	-1.60	-54.1	33.0	3669	260	-1.40	-34.0	33.5	3717	180	-1.39	-52.6	24.9
3622	230	-2.19	-62.4	27.5	3670	170	-1.92	-52.8	34.2	3718	340	-2.41	-76.0	19.9
3623	230	-2.13	-60.7	21.4	3671	80	-1.07	-40.7	31.4	3719	50	-1.48	-55.1	24.3
3624	80	-1.91	-67.4	26.4	3672	90	-1.39	-47.1	21.9	3720	50	-1.04	-38.9	17.6
3625	90	-1.64	-55.6	28.4	3673	100	-2.30	-72.6	29.5	3721	190	-1.55	-66.6	21.2
3626	220	-1.86	-57.7	27.8	3674	90	-1.32	-44.6	33.4	3722	180	-1.97	-75.0	22.4
3627	70	-1.37	-52.1	24.2	3675	100	-1.52	-48.1	35.2	3723	60	-1.90	-84.1	22.6
3628	230	-2.51	-71.1	28.8	3676	40	-1.28	-46.7	36.6	3724	50	-1.00	-37.2	24.5
3629	40	-1.26	-45.8	27.1	3677	40	-1.65	-60.4	32.0	3725	40	-1.30	-47.3	13.3
3630	330	-1.49	-46.9	24.4	3678	60	-1.53	-58.0	31.4	3726	50	-1.29	-48.2	13.2
3631	220	-1.63	-50.9	24.4	3679	70	-2.17	-82.6	32.2	3727	40	-1.17	-42.7	17.9
3632	230	-2.36	-67.3	23.8	3680	70	-2.87	-108.9	28.8	3728	80	-1.35	-47.8	18.4
3633	220	-3.38	-104.2	23.3	3681	70	-3.74	-142.1	32.9	3729	40	-1.93	-86.1	20.6
3634	230	-2.58	-73.5	24.3	3682	60	-2.74	-104.0	28.9	3730	70	-1.87	-82.9	21.5
3635	40	-1.91	-69.9	22.3	3683	290	-2.21	-55.4	19.1	3731	50	-1.96	-85.6	19.7
3636	30	-1.83	-62.6	19.8	3684	240	-1.86	-51.3	20.5	3732	170	-1.23	-46.0	17.7
3637	40	-1.43	-52.3	22.9	3685	290	-1.21	-30.9	18.2	3733	170	-1.99	-86.7	14.8
3638	40	-1.26	-46.6	22.5	3686	50	-1.93	-54.0	22.1	3734	170	-1.99	-87.0	17.2
3639	40	-1.46	-53.2	28.3	3687	50	-1.77	-52.8	24.8	3735	20	-1.42	-44.7	13.0
3640	40	-1.16	-42.5	30.8	3688	50	-1.89	-53.0	24.1	3736	30	-1.54	-52.2	14.8

TABLE 6A. PEAK LOADS FOR CONFIGURATION A : THREE LAKEWAY CENTER
LARGEST VALUES OF CLADDING LOAD REFERENCE PRESSURE = 38.0 PSF

TAP	AZI- MUTH	PRESS COEFF	NEGATIVE PEAK	POSITIVE PEAK	TAP	AZI- MUTH	PRESS COEFF	NEGATIVE PEAK	POSITIVE PEAK	TAP	AZI- MUTH	PRESS COEFF	NEGATIVE PEAK	POSITIVE PEAK
			----- PSF -----	----- PSF -----				----- PSF -----	----- PSF -----				----- PSF -----	----- PSF -----
37337	40	-1.11	-40.6	21.9	37883	350	-.96	-22.3	30.3	39331	60	-1.62	-61.7	19.3
37338	80	-1.41	-49.7	19.5	37884	350	-.87	-22.9	29.6	39332	60	-1.23	-46.7	19.2
37339	50	-.83	-31.1	20.9	37885	210	-.99	-32.1	25.9	39333	50	-1.17	-43.4	11.9
3740	60	-.85	-32.3	23.2	37886	190	-.99	-36.0	33.7	39334	170	-1.11	-41.5	16.0
3741	70	-.80	-30.5	20.3	37887	220	-.98	-30.1	20.3	39335	60	-1.46	-55.3	10.6
3742	70	-.80	-30.5	20.5	37888	180	-.98	-37.3	20.1	39336	60	-1.40	-53.0	35.1
3743	160	-1.27	-46.3	20.0	37889	220	-1.14	-35.0	23.1	39337	60	-1.67	-63.4	31.4
3744	160	-.98	-35.9	18.3	37890	180	-.70	-26.6	17.8	39338	90	-1.76	-59.7	12.1
3745	170	-.94	-35.0	17.7	37891	330	-1.35	-42.5	18.5	39339	60	-1.22	-46.5	8.7
3746	350	-2.46	-77.6	33.0	37892	210	-.81	-26.3	15.8	39340	60	-1.08	-40.9	15.1
3747	110	-1.01	-32.6	31.6	37893	210	-1.16	-37.5	11.8	3941	140	-1.50	-54.6	8.8
3748	30	-.96	-31.5	32.5	37894	280	-1.77	-44.3	17.2	3942	50	-1.52	-56.5	38.7
3749	170	-.82	-30.4	28.8	37895	50	-1.45	-54.1	7.6	3943	50	-1.31	-48.9	15.3
3750	170	-1.10	-40.9	29.0	38001	280	-1.28	-32.2	16.2	3944	40	-1.49	-54.3	27.2
3751	70	-1.67	-63.5	27.1	38002	190	-1.15	-41.9	19.5	3945	40	-1.74	-63.3	30.0
3752	70	-1.44	-54.8	27.2	38003	50	-.84	-31.1	20.7	3946	310	-2.30	-59.5	39.0
3753	90	-1.13	-38.3	19.5	39001	210	-1.37	-44.4	25.2	3947	210	-1.47	-47.7	32.1
3754	210	-1.34	-43.3	15.3	39002	330	-1.40	-44.1	24.1	3948	220	-1.36	-41.8	26.9
3755	210	-1.33	-43.0	23.8	39003	330	-1.54	-48.6	23.5	3949	280	-1.42	-35.6	23.0
3756	50	-1.88	-69.9	19.7	39004	70	-1.63	-62.0	25.6	3950	220	-1.89	-58.2	19.9
3757	200	-1.41	-47.6	26.0	39005	290	-1.74	-43.8	29.4	39501	220	-1.33	-37.8	29.0
3758	90	-1.28	-43.2	21.1	39006	80	-1.36	-47.9	35.5	39502	220	-2.31	-71.1	33.3
3759	190	-.83	-33.3	27.6	39007	80	-1.82	-64.4	30.5	39503	30	-1.42	-48.1	30.7
3760	220	-1.07	-33.0	20.5	39008	290	-1.97	-49.3	26.4	39504	40	-1.08	-31.6	39.3
3761	220	-.94	-28.8	22.4	39009	80	-1.11	-39.2	33.9	39505	230	-1.08	-30.7	18.5
3762	200	-1.23	-42.2	19.6	3910	80	-2.31	-81.6	31.4	39506	230	-2.18	-62.1	38.3
3763	210	-.98	-31.7	25.0	3911	270	-2.30	-57.6	29.2	39507	290	-1.39	-35.0	23.5
3764	220	-1.21	-37.2	24.6	39112	80	-1.18	-41.6	31.9	39508	140	-1.96	-71.5	45.0
3765	350	-1.87	-58.9	26.8	39113	80	-1.63	-57.5	31.1	39509	60	-.83	-31.4	26.0
3766	60	-.74	-22.9	28.1	39114	230	-2.24	-63.9	34.4	3960	250	-1.01	-25.4	17.1
3767	120	-.79	-26.1	25.4	39115	80	-1.41	-49.7	39.4	3961	50	-.84	-31.1	28.0
3768	20	-.86	-25.5	27.2	39116	80	-1.95	-68.8	36.5	3962	40	-.88	-32.3	27.4
3769	40	-.75	-21.7	27.5	39117	30	-1.57	-53.3	31.7	3963	310	-1.32	-34.0	32.5
3770	190	-.97	-33.5	23.1	39118	80	-1.09	-38.5	27.0	3964	70	-.93	-33.2	31.2
3771	210	-1.09	-33.1	25.2	39119	80	-1.75	-61.9	25.1	3965	260	-1.18	-28.8	18.9
3772	190	-.88	-32.2	20.9	3920	60	-1.56	-59.3	28.6	3966	50	-.99	-36.9	25.8
3773	210	-1.13	-36.4	11.9	3921	60	-1.28	-48.7	10.8	3967	100	-1.40	-44.1	26.0
3774	210	-1.09	-35.1	20.2	3922	90	-1.88	-63.7	8.6	3968	140	-1.07	-39.1	27.2
3775	40	-1.52	-55.5	13.8	3923	70	-1.55	-58.8	17.0	3969	140	-1.09	-39.6	33.6
3776	210	-1.02	-33.0	21.8	3924	70	-1.22	-46.5	7.1	3970	140	-1.17	-42.8	33.4
3777	20	-.75	-22.3	23.8	3925	80	-1.66	-58.7	17.3	3971	70	-1.41	-53.4	39.0
3778	220	-1.07	-33.0	23.5	3926	70	-1.44	-54.9	2.0	3972	200	-2.10	-70.9	35.4
3779	210	-1.05	-34.0	16.5	3927	60	-1.49	-56.5	2.8	3973	190	-1.35	-49.3	24.9
3780	350	-1.86	-58.7	23.3	3928	70	-1.83	-69.9	7.2	3974	230	-1.13	-32.3	20.4
3781	210	-1.00	-32.5	33.1	3929	60	-1.46	-55.9	11.4	3975	40	-1.77	-64.5	8.3
3782	20	-.97	-22.5	30.7	3930	70	-1.49	-56.6	35.1					

TABLE 6A. PEAK LOADS FOR CONFIGURATION A : THREE LAKEWAY CENTER
LARGEST VALUES OF CLADDING LOAD REFERENCE PRESSURE = 38.0 PSF

* * 15 GREATEST PRESSURE MAGNITUDES * *

TAP	AZI- MUTH	PRESS COEFF	NEGATIVE PEAK ----- PSF	POSITIVE PEAK ----- PSF
3681	70	-3.74	-142.1	32.9
3312	70	-3.08	-117.2	31.5
3680	70	-2.87	-108.9	28.8
3397	70	-2.75	-104.6	26.5
3633	220	-3.38	-104.2	23.8
3682	60	-2.74	-104.0	28.9
3334	70	-2.69	-102.4	32.7
3335	70	-2.47	-94.0	30.1
3330	70	-2.40	-91.1	31.1
3158	80	-2.51	-88.7	32.7
3248	130	-2.54	-85.8	39.2
3697	60	-2.23	-84.9	25.1
3164	40	-2.28	-83.3	30.1
3311	70	-2.19	-83.1	28.0
3679	70	-2.17	-82.6	32.2

TABLE 6A. PEAK LOADS FOR CONFIGURATION B : THREE LAKEWAY CENTER
LARGEST VALUES OF CLADDING LOAD REFERENCE PRESSURE = 38.0 PSF

TAP	AZI- MUTH	PRESS COEFF	NEGATIVE PEAK ----- PSF	POSITIVE PEAK ----- PSF	TAP	AZI- MUTH	PRESS COEFF	NEGATIVE PEAK ----- PSF	POSITIVE PEAK ----- PSF	TAP	AZI- MUTH	PRESS COEFF	NEGATIVE PEAK ----- PSF	POSITIVE PEAK ----- PSF
3123	294	-2.49	-62.5	37.6	3513	308	-1.92	-49.7	17.2	3650	344	-2.84	-89.6	34.7
3307	64	-2.88	-109.5	21.2	3548	320	-2.39	-61.7	27.1	3680	74	-3.21	-122.0	8.1
3312	62	-3.55	-134.8	28.0	3628	240	-2.13	-57.6	24.9	3681	64	-4.16	-158.0	17.4
3334	68	-2.35	-89.3	21.6	3633	226	-2.73	-77.8	-3.1	3682	62	-2.88	-109.5	-2.8
3512	308	-2.38	-61.5	19.6										

TABLE 6A. PEAK LOADS FOR CONFIGURATION B : THREE LAKEWAY CENTER
LARGEST VALUES OF CLADDING LOAD REFERENCE PRESSURE = 38.0 PSF

* * 13 GREATEST PRESSURE MAGNITUDES * *

TAP	AZI- MUTH	PRESS COEFF	NEGATIVE PEAK ----- PSF	POSITIVE PEAK ----- PSF
3681	64	-4.16	-158.0	17.4
3312	62	-3.55	-134.8	28.0
3680	74	-3.21	-122.0	8.1
3682	62	-2.88	-109.5	-2.8
3307	64	-2.88	-109.5	21.2
3650	344	-2.84	-89.6	34.7
3334	68	-2.35	-89.3	21.6
3633	226	-2.73	-77.8	-3.1
3123	294	-2.49	-62.5	37.6
3548	320	-2.39	-61.7	27.1
3512	308	-2.38	-61.5	19.6
3628	240	-2.13	-57.6	24.9
3513	308	-1.92	-49.7	17.2

TABLE 6A. PEAK LOADS FOR CONFIGURATION C : THREE LAKEWAY CENTER
LARGEST VALUES OF CLADDING LOAD

REFERENCE PRESSURE = 38.0 PSF

TAP	AZI- MUTH	PRESS COEFF	NEGATIVE PEAK ----- PSF	POSITIVE PEAK ----- PSF	TAP	AZI- MUTH	PRESS COEFF	NEGATIVE PEAK ----- PSF	POSITIVE PEAK ----- PSF	TAP	AZI- MUTH	PRESS COEFF	NEGATIVE PEAK ----- PSF	POSITIVE PEAK ----- PSF
3247	135	-1.76	-64.2	7.5	4005	135	-1.37	-49.9	15.8	4012	125	-1.26	-42.7	-1.2
3248	135	-2.28	-83.3	7.2	4006	140	-1.69	-61.8	7.8	4013	135	-1.98	-72.3	8.6
3249	135	-1.87	-68.1	16.2	4007	130	-2.27	-76.7	9.4	4014	135	-1.88	-68.6	9.3
4001	135	-1.86	-67.8	10.3	4008	135	-1.74	-63.4	7.3	4015	135	-1.98	-72.1	10.3
4002	130	-2.29	-77.4	8.3	4009	140	-1.40	-51.2	13.0	4016	135	-1.97	-71.8	10.9
4003	135	-1.55	-56.4	10.3	4010	140	-1.35	-49.2	11.8	4017	140	-1.49	-54.4	12.9
4004	135	-2.07	-75.4	9.0	4011	140	-1.63	-59.5	5.8					

TABLE 6A. PEAK LOADS FOR CONFIGURATION C : THREE LAKEWAY CENTER
LARGEST VALUES OF CLADDING LOAD REFERENCE PRESSURE = 38.0 PSF

* * 15 GREATEST PRESSURE MAGNITUDES * *

TAP	AZI- MUTH	PRESS COEFF	NEGATIVE PEAK ----- PSF	POSITIVE PEAK ----- PSF
3248	135	-2.28	-83.3	7.2
4002	130	-2.29	-77.4	8.3
4007	130	-2.27	-76.7	9.4
4004	135	-2.07	-75.4	9.0
4013	135	-1.98	-72.3	8.6
4015	135	-1.98	-72.1	10.3
4016	135	-1.97	-71.8	10.9
4014	135	-1.88	-68.6	9.3
3249	135	-1.87	-68.1	16.2
4001	135	-1.86	-67.8	10.3
3247	135	-1.76	-64.2	7.5
4008	135	-1.74	-63.4	7.3
4006	140	-1.69	-61.8	7.8
4011	140	-1.63	-59.5	5.8
4003	135	-1.55	-56.4	10.3

TABLE 7. BASE SHEAR AND MOMENT SUMMARY : ONE LAKEWAY CENTER
 CONFIGURATION A REFERENCE PRESSURE 38.0 GUST FACTOR 1.32

AZIMUTH	SHEAR (KIPS)		MOMENT (1000-FT-KIPS)			ECCEN (FT)	
	X	Y	X	Y	Z	X	Y
0	-784.4	-151.8	11.0	-77.5	-26.7	6	-33
10	-816.7	-123.4	10.4	-81.2	-38.9	7	-47
20	-821.6	-14.1	6.2	-82.1	-47.5	1	-58
30	-747.9	113.9	-2.1	-72.9	-54.2	-11	-71
40	-592.8	198.3	-11.4	-56.5	-43.0	-22	-65
50	-498.6	183.5	-12.6	-45.9	-26.5	-17	-47
60	-364.9	248.2	-19.4	-30.6	-7.6	-10	-14
70	-98.6	390.4	-31.9	-5.2	17.4	42	11
80	210.1	461.8	-39.8	24.8	39.5	71	-32
90	491.3	590.2	-50.4	52.5	58.3	58	-49
100	486.5	482.0	-42.2	50.3	45.6	47	-47
110	546.5	579.9	-51.5	55.7	41.8	38	-36
120	597.2	655.4	-60.4	60.7	39.4	33	-30
130	602.8	651.4	-63.8	60.9	37.6	31	-29
140	395.2	368.3	-41.6	40.1	27.2	34	-37
150	260.6	168.0	-19.3	22.4	19.9	35	-54
160	1.1	-46.8	2.1	-5.5	-0	1	0
170	-86.1	-123.1	10.7	-15.4	-10.9	59	-42
180	-100.5	-141.6	13.5	-17.8	-13.6	64	-45
190	-70.4	-162.4	15.6	-15.9	-13.3	69	-30
200	-31.7	-121.2	12.9	-12.5	-12.7	98	-26
210	-24.9	-49.3	8.1	-12.0	-12.9	208	-105
220	66.5	40.1	1.9	-3.4	-9.7	-65	107
230	56.5	44.4	2.2	-3.0	-7.2	-62	79
240	35.6	79.6	-2.0	-3.1	-6.6	-69	31
250	35.4	114.9	-6.6	-1.4	-6.2	-49	15
260	12.6	122.9	-8.9	-2.2	-5.2	-42	4
270	-1	139.5	-11.3	-2.5	-5.3	-38	-0
280	-148.6	85.0	-7.2	-15.4	-5.7	-17	-29
290	-324.5	-234.5	23.1	-31.8	-13.4	20	-27
300	-458.2	-498.5	45.0	-43.3	-12.8	14	-13
310	-619.5	-560.1	49.7	-56.3	-14.0	11	-12
320	-810.0	-578.6	52.0	-73.9	-16.8	10	-14
330	-1070.4	-663.1	58.0	-100.4	-24.3	10	-16
340	-1115.9	-515.7	43.3	-103.7	-26.9	9	-20
350	-1071.1	-328.3	27.4	-100.9	-28.3	7	-24

TABLE 7. BASE SHEAR AND MOMENT SUMMARY : TWO LAKEWAY CENTER
 CONFIGURATION A REFERENCE PRESSURE 38.0 GUST FACTOR 1.32

AZIMUTH	SHEAR (KIPS)		MOMENT (1000-FT-KIPS)			ECCEN (FT)	
	X	Y	X	Y	Z	X	Y
0	-1056.5	1663.3	-170.5	-123.5	176.5	76	48
10	-1219.3	2202.5	-234.9	-145.2	189.5	66	36
20	-1450.8	2355.4	-257.1	-175.0	177.6	55	34
30	-1693.3	2390.4	-266.8	-203.3	172.7	48	34
40	-1897.5	2426.5	-278.6	-225.5	173.5	44	35
50	-1915.0	2402.0	-286.8	-231.7	169.3	43	34
60	-1852.3	2340.5	-293.8	-232.8	147.4	39	31
70	-1688.1	2084.1	-272.1	-218.7	109.6	32	26
80	-1368.8	1567.8	-206.3	-179.1	82.0	30	26
90	-944.7	821.0	-108.7	-124.0	41.0	22	25
100	-466.4	247.4	-35.1	-64.2	-17.1	-15	-29
110	-132.5	-81.2	1.3	-18.8	-44.5	150	-244
120	22.9	-267.2	21.9	3.9	-52.1	193	17
130	248.4	-314.3	31.9	36.9	-43.0	84	66
140	445.0	-356.4	47.4	69.0	-41.3	45	57
150	886.9	-808.5	113.6	124.6	-54.6	31	34
160	905.6	-614.7	86.3	124.6	-62.7	32	47
170	946.4	-289.3	45.0	129.0	-59.8	18	58
180	1060.2	-243.3	38.9	141.7	-79.2	16	71
190	1107.7	-473.3	63.5	143.4	-97.8	32	75
200	1149.1	-930.8	119.4	145.0	-114.1	49	60
210	1182.9	-1504.6	187.5	145.5	-135.2	56	44
220	1186.3	-2014.9	251.0	143.4	-154.5	57	34
230	1005.5	-2269.3	280.5	117.1	-157.1	58	26
240	756.0	-2309.0	283.7	84.2	-150.2	59	19
250	478.1	-2220.1	271.3	48.4	-139.3	60	13
260	175.3	-2081.4	251.5	8.4	-130.2	62	5
270	-138.7	-2036.3	245.9	-33.5	-132.5	65	-4
280	-326.2	-1883.8	227.6	-58.4	-135.4	70	-12
290	-26.6	-2495.7	300.3	-15.8	-204.9	82	-1
300	3.5	-2389.5	291.7	-6.1	-215.7	90	0
310	-235.2	-1810.2	228.3	-28.8	-169.8	92	-12
320	-588.1	-1015.3	132.3	-70.7	-85.6	63	-37
330	-950.8	-397.9	66.9	-112.3	-13.6	5	-12
340	-1080.0	370.5	-20.5	-127.4	72.9	21	60
350	-1148.2	1173.5	-113.0	-134.8	151.1	66	64

TABLE 7. BASE SHEAR AND MOMENT SUMMARY : THREE LAKEWAY CENTER PROJECT #6013
 CONFIGURATION A REFERENCE PRESSURE 38.0 GUST FACTOR 1.32

AZIMUTH	SHEAR (KIPS)		MOMENT (1000-FT-KIPS)			ECCEN (FT)	
	X	Y	X	Y	Z	X	Y
0	-1959.4	-946.4	247.8	-473.2	-7.4	1	-3
10	-2501.4	-759.4	204.3	-589.9	-33.9	4	-12
20	-2858.0	-488.5	125.8	-662.7	-67.0	4	-23
30	-3179.9	-326.1	72.8	-733.1	-101.7	3	-32
40	-3659.3	-387.7	81.0	-839.8	-136.3	4	-37
50	-3868.2	-485.1	104.1	-884.0	-176.6	6	-45
60	-3705.6	-623.6	188.6	-840.9	-225.4	13	-58
70	-3161.0	-637.7	150.4	-710.5	-250.0	15	-76
80	-2422.1	533.1	-128.9	-543.5	-206.3	-18	-81
90	-2156.9	911.0	-214.0	-498.3	-159.5	-27	-63
100	-1823.7	690.4	-155.3	-440.6	-113.5	-21	-54
110	-1284.6	925.2	-205.7	-317.0	-63.9	-24	-33
120	-494.8	1143.5	-261.9	-124.5	10.7	8	3
130	358.7	1129.7	-264.0	77.4	70.6	57	-18
140	965.0	1271.6	-300.7	215.7	66.4	33	-25
150	1530.9	1606.5	-370.5	341.5	49.5	16	-15
160	2107.9	1873.6	-426.2	469.3	47.5	11	-13
170	2662.5	1963.6	-443.8	598.3	35.5	6	-9
180	3203.8	1853.3	-415.3	725.5	11.7	2	-3
190	3421.3	1440.2	-317.2	780.9	-28.9	-3	7
200	3284.0	879.8	-180.7	748.8	-75.3	-6	21
210	3223.0	506.4	-86.9	733.3	-116.0	-6	35
220	3123.5	510.0	-86.5	707.9	-128.9	-7	40
230	2701.8	528.5	-94.9	608.7	-142.2	-10	51
240	2151.6	439.1	-83.2	482.2	-155.7	-14	69
250	1600.0	26.8	11.3	359.9	-141.1	-1	88
260	1484.0	-179.6	61.2	338.0	-114.5	9	76
270	1504.1	-302.7	92.0	347.1	-90.6	12	58
280	1418.4	-369.4	107.9	322.5	-74.1	13	49
290	1314.1	-142.8	57.0	318.0	-82.5	7	62
300	477.0	-472.1	133.1	124.6	-21.5	23	23
310	-122.5	-789.9	216.9	-41.0	41.5	-51	8
320	-453.0	-719.3	207.8	-129.2	40.4	-40	25
330	-973.4	-1042.4	286.8	-241.5	35.0	-18	17
340	-1230.2	-1232.8	328.8	-303.7	19.3	-8	8
350	-1759.2	-1232.8	323.3	-431.1	11.0	-3	4

TABLE 7. ONE LAKEWAY CENTER

PROJECT 6011

CONFIGURATION A

SCALE = 300

REF. PRESSURE = 38.0

GUST FACTOR = 1.32

STANDARD FLOOR HEIGHT = 12.00

NUMBER OF SIDES = 6

NO. OF FLOORS = 14

SIDE	ANGLE	Z-AXIS	SHFACT
1	0.0	6.707	1.0
2	90.0	3.186	1.0
3	180.0	3.186	1.0
4	270.0	4.600	1.0
5	225.0	3.214	1.0
6	225.0	3.214	0.0

FLOOR #	LABEL	HEIGHT-FT	WIND AZIMUTH	LOAD FACTOR
1	GRND	17.00	0	.71
2	MEZZ	13.00	10	.77
3	4TH	12.00	20	.83
4	5TH	12.00	30	.89
5	6TH	12.00	40	.96
6	7TH	12.00	50	.98
7	8TH	12.00	60	1.00
8	9TH	12.00	70	1.00
9	10TH	12.00	80	.93
10	11TH	12.00	90	.89
11	12TH	12.00	100	.83
12	13TH	12.00	110	.85
13	14TH	12.00	120	.87
14	MECH	14.88	130	.89
			140	.96
			150	.93
			160	.96
			170	.98
			180	1.00
			190	.96
			200	.89
			210	.85
			220	.81
			230	.75
			240	.71
			250	.66
			260	.64
			270	.66
			280	.66
			290	.66
			300	.68
			310	.68
			320	.68
			330	.83
			340	.83
			350	.83

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 0

ONE LAKEWAY CENTER
CONFIGURATION A
REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									-784.4	-151.8	11.0	-77.5	-26.7
		-30.7	-15.6	3603	4785	-8.5	-3.3	-3	6					
MEZZ	17.00									-753.8	-136.2	8.6	-64.5	-27.0
		-22.2	-16.3	2755	3659	-8.1	-4.4	-9	12					
4TH	30.00									-731.6	-119.9	6.9	-54.8	-27.4
		-30.2	-18.1	2892	3378	-10.4	-5.4	4	-7					
5TH	42.00									-701.4	-101.8	5.6	-46.2	-27.1
		-27.9	-18.9	2940	3378	-9.5	-5.6	2	-2					
6TH	54.00									-673.5	-82.9	4.5	-38.0	-27.0
		-55.2	-12.6	2921	2450	-18.9	-5.1	8	-36					
7TH	66.00									-618.3	-70.4	3.6	-30.2	-24.9
		-72.3	-5.2	2800	2082	-25.8	-2.5	3	-42					
8TH	78.00									-546.1	-65.1	2.8	-23.2	-21.8
		-74.6	-7.9	2800	2082	-26.6	-3.8	4	-42					
9TH	90.00									-471.5	-57.2	2.0	-17.1	-18.7
		-76.9	-10.5	2800	2082	-27.5	-5.1	6	-41					
10TH	102.00									-394.6	-46.7	1.4	-11.9	-15.5
		-79.4	-10.5	2800	2082	-28.4	-5.1	5	-40					
11TH	114.00									-315.3	-36.2	.9	-7.7	-12.3
		-82.0	-10.2	2800	2082	-29.3	-4.9	5	-39					
12TH	126.00									-233.3	-26.0	.5	-4.4	-9.0
		-83.6	-9.6	2800	2082	-29.9	-4.6	4	-39					
13TH	138.00									-149.7	-16.4	.3	-2.1	-5.7
		-71.9	-7.1	2800	2082	-25.7	-3.4	4	-40					
14TH	150.00									-77.8	-9.3	.1	-.7	-2.8
		-60.1	-4.5	2800	2082	-21.5	-2.1	3	-41					
MECH	162.00									-17.6	-4.8	.0	-.1	-.3
		-17.6	-4.8	2031	1223	-8.7	-3.9	5	-17					
TOP	177.00									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS : ONE LAKEWAY CENTER														
WIND DIRECTION 10		CONFIGURATION A				REFERENCE PRESSURE 38.0 PSF				GUST FACTOR 1.32				
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									-816.7	-123.4	10.4	-81.2	-38.9
		-26.4	-8	3603	4785	-7.3	-2	-0	8					
MEZZ	17.00									-790.3	-122.6	8.3	-67.5	-39.1
		-17.8	-4	2755	3659	-6.5	-1	-0	17					
4TH	30.00									-772.5	-122.2	6.8	-57.4	-39.4
		-28.8	-11.0	2892	3378	-10.0	-3.3	6	-15					
5TH	42.00									-743.6	-111.2	5.4	-48.3	-38.9
		-23.1	-31.3	2940	3378	-9.9	-9.3	-0	0					
6TH	54.00									-714.6	-79.9	4.2	-39.5	-38.9
		-64.3	-17.2	2921	2450	-22.0	-7.0	11	-42					
7TH	66.00									-650.2	-62.7	3.4	-31.3	-36.0
		-80.5	-5.2	2800	2082	-28.8	-2.5	3	-53					
8TH	78.00									-569.7	-57.5	2.6	-24.0	-31.7
		-80.7	-6.9	2800	2082	-28.8	-3.3	5	-54					
9TH	90.00									-488.9	-50.6	2.0	-17.7	-27.3
		-80.9	-8.7	2800	2082	-28.9	-4.2	6	-55					
10TH	102.00									-408.0	-42.0	1.4	-12.3	-22.8
		-82.7	-8.4	2800	2082	-29.5	-4.0	6	-55					
11TH	114.00									-325.3	-33.6	1.0	-7.9	-18.2
		-84.7	-7.8	2800	2082	-30.3	-3.7	5	-56					
12TH	126.00									-240.6	-25.8	.6	-4.5	-13.4
		-85.9	-7.2	2800	2082	-30.7	-3.4	5	-56					
13TH	138.00									-154.7	-18.7	.3	-2.1	-8.6
		-74.4	-6.4	2800	2082	-26.6	-3.1	5	-57					
14TH	150.00									-80.3	-12.3	.2	-.7	-4.3
		-63.0	-5.6	2800	2082	-22.5	-2.7	5	-58					
MECH	162.00									-17.3	-6.6	.0	-.1	-.6
		-17.3	-6.6	2031	1223	-8.5	-5.4	12	-32					
TOP	177.00									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 20

ONE LAKEWAY CENTER

CONFIGURATION A

REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									-821.6	-14.1	6.2	-82.1	-47.5
MEZZ	17.00	-24.8	22.3	3603	4785	-6.9	4.7	5	6	-796.8	-36.4	5.8	-68.4	-47.8
4TH	30.00	-17.2	22.0	2755	3659	-6.2	6.0	8	6	-779.6	-58.4	5.1	-58.1	-48.1
		-30.0	11.8	2892	3378	-10.4	3.5	-9	-24					
5TH	42.00	-29.7	-12.3	2940	3378	-10.1	-3.6	4	-11	-749.6	-70.2	4.4	-49.0	-47.2
6TH	54.00	-64.6	-9.1	2921	2450	-22.1	-3.7	9	-61	-719.8	-57.9	3.6	-40.1	-46.9
7TH	66.00	-78.8	-1.8	2800	2082	-28.1	-.9	2	-66	-655.2	-48.8	3.0	-31.9	-42.8
8TH	78.00	-79.5	-3.8	2800	2082	-28.4	-1.8	3	-66	-576.5	-47.0	2.4	-24.5	-37.6
9TH	90.00	-80.3	-5.9	2800	2082	-28.7	-2.8	5	-67	-497.0	-43.2	1.8	-18.1	-32.3
10TH	102.00	-83.2	-6.1	2800	2082	-29.7	-2.9	5	-66	-416.7	-37.3	1.4	-12.6	-26.9
11TH	114.00	-86.4	-6.2	2800	2082	-30.8	-3.0	5	-65	-333.5	-31.2	1.0	-8.1	-21.4
12TH	126.00	-88.6	-6.2	2800	2082	-31.7	-3.0	4	-64	-247.1	-25.0	.6	-4.6	-15.8
13TH	138.00	-76.7	-6.1	2800	2082	-27.4	-3.0	5	-65	-158.5	-18.8	.4	-2.2	-10.1
14TH	150.00	-64.8	-6.1	2800	2082	-23.2	-2.9	6	-66	-81.7	-12.7	.2	-.7	-5.1
MECH	162.00	-16.9	-6.6	2031	1223	-8.3	-5.4	16	-41	-16.9	-6.6	.0	-.1	-.8
TOP	177.00									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 30

ONE LAKEWAY CENTER

CONFIGURATION A

REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									-747.9	113.9	-2.1	-72.9	-54.2
		-23.5	45.8	3603	4785	-6.5	9.6	-1	-0					
MEZZ	17.00									-724.4	68.1	-1.5	-60.3	-54.2
		-16.3	40.5	2755	3659	-5.9	11.1	-2	-1					
4TH	30.00									-708.1	27.5	.1	-51.0	-54.1
		-29.7	30.5	2892	3378	-10.3	9.0	-22	-21					
5TH	42.00									-678.5	-2.9	.2	-42.7	-52.8
		-31.4	5.7	2940	3378	-10.7	1.7	-7	-36					
6TH	54.00									-647.1	-8.6	.2	-34.8	-51.6
		-63.9	-5.3	2921	2450	-21.9	-2.2	7	-81					
7TH	66.00									-583.2	-3.3	.1	-27.4	-46.4
		-74.7	-1.4	2800	2082	-26.7	-.7	1	-80					
8TH	78.00									-508.4	-2.0	.1	-20.8	-40.4
		-75.3	-1.5	2800	2082	-26.9	-.7	2	-79					
9TH	90.00									-433.2	-.4	.0	-15.2	-34.5
		-75.8	-1.7	2800	2082	-27.1	-.8	2	-77					
10TH	102.00									-357.4	1.2	.1	-10.4	-28.6
		-76.1	-.4	2800	2082	-27.2	-.2	0	-78					
11TH	114.00									-281.3	1.6	.1	-6.6	-22.7
		-76.5	1.1	2800	2082	-27.3	.5	-1	-78					
12TH	126.00									-204.8	.6	.1	-3.7	-16.7
		-76.1	2.4	2800	2082	-27.2	1.1	-2	-79					
13TH	138.00									-128.8	-1.8	.1	-1.7	-10.7
		-64.8	1.0	2800	2082	-23.1	.5	-1	-82					
14TH	150.00									-64.0	-2.8	.0	-.5	-5.4
		-53.5	-.5	2800	2082	-19.1	-.2	1	-85					
MECH	162.00									-10.4	-2.3	.0	-.1	-.8
		-10.4	-2.3	2031	1223	-5.1	-1.9	17	-77					
TOP	177.00									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS : ONE LAKEWAY CENTER																	
WIND DIRECTION 40		CONFIGURATION A								REFERENCE PRESSURE 38.0 PSF					GUST FACTOR 1.32		
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)					
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z			
GRND	0.00																
		-20.7	47.5	3603	4785	-5.7	9.9	-6	-2	-392.8	198.3	-11.4	-56.5	-43.0			
MEZZ	17.00																
		-14.0	42.1	2755	3659	-5.1	11.5	-6	-2	-572.2	150.8	-8.4	-46.6	-42.7			
4TH	30.00																
		-26.3	32.0	2892	3378	-9.1	9.5	-23	-19	-558.2	108.7	-6.7	-39.3	-42.4			
5TH	42.00																
		-28.8	12.7	2940	3378	-9.8	3.7	-14	-32	-531.8	76.8	-5.6	-32.7	-41.2			
6TH	54.00																
		-49.5	1.5	2921	2450	-16.9	.6	-2	-77	-503.0	64.1	-4.8	-26.5	-40.1			
7TH	66.00																
		-59.7	1.4	2800	2082	-21.0	.7	-2	-76	-453.6	62.6	-4.0	-20.8	-36.3			
8TH	78.00																
		-59.6	2.8	2800	2082	-21.3	1.4	-4	-74	-394.9	61.3	-3.3	-15.7	-31.9			
9TH	90.00																
		-60.5	4.3	2800	2082	-21.6	2.1	-5	-73	-335.3	58.4	-2.5	-11.3	-27.4			
10TH	102.00																
		-61.2	6.9	2800	2082	-21.9	3.3	-8	-75	-274.7	54.1	-1.9	-7.6	-23.0			
11TH	114.00																
		-61.9	9.8	2800	2082	-22.1	4.7	-12	-76	-213.5	47.2	-1.3	-4.7	-18.3			
12TH	126.00																
		-61.7	12.3	2800	2082	-22.0	5.9	-16	-78	-151.6	37.4	-.8	-2.5	-13.5			
13TH	138.00																
		-49.4	11.1	2800	2082	-17.7	5.3	-19	-83	-89.9	25.1	-.4	-1.1	-8.5			
14TH	150.00																
		-37.1	9.8	2800	2082	-13.3	4.7	-24	-92	-40.4	14.1	-.1	-.3	-4.2			
MECH	162.00																
		-3.3	4.3	2031	1223	-1.6	3.5	-73	-57	-3.3	4.3	-.0	-.0	-.5			
TOP	177.00																
										0.0	0.0	0.0	0.0	0.0			

TABLE 7. SHEAR AND MOMENT DIAGRAMS :															
WIND DIRECTION 50		ONE LAKEWAY CENTER CONFIGURATION A								REFERENCE PRESSURE 38.0 PSF			GUST FACTOR 1.32		
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)			
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z	
GRND	0.00									-498.6	183.5	-12.6	-45.9	-26.5	
		-22.2	29.1	3603	4785	-6.2	6.1	-4	-3						
MEZZ	17.00									-476.4	154.5	-9.7	-37.6	-26.3	
		-16.3	29.4	2755	3659	-5.9	8.0	-8	-5						
4TH	30.00									-460.0	125.1	-7.9	-31.5	-26.0	
		-27.3	25.6	2892	3378	-9.4	7.6	-18	-19						
5TH	42.00									-432.8	99.5	-6.6	-26.2	-25.0	
		-32.2	14.6	2940	3378	-10.9	4.3	-8	-18						
6TH	54.00									-400.6	84.9	-5.5	-21.2	-24.3	
		-39.8	8.1	2921	2450	-13.6	3.3	-9	-43						
7TH	66.00									-360.9	76.8	-4.5	-16.6	-22.6	
		-44.8	5.1	2800	2082	-16.0	2.5	-6	-50						
8TH	78.00									-316.1	71.7	-3.6	-12.6	-20.3	
		-46.9	5.1	2800	2082	-16.8	2.4	-6	-52						
9TH	90.00									-269.2	66.6	-2.8	-9.0	-17.8	
		-49.1	5.1	2800	2082	-17.5	2.4	-6	-54						
10TH	102.00									-220.0	61.6	-2.0	-6.1	-15.2	
		-49.4	8.5	2800	2082	-17.7	4.1	-10	-58						
11TH	114.00									-170.6	53.1	-1.3	-3.8	-12.2	
		-49.5	12.4	2800	2082	-17.7	5.9	-15	-61						
12TH	126.00									-121.1	40.7	-.7	-2.0	-9.0	
		-48.9	15.8	2800	2082	-17.5	7.6	-20	-63						
13TH	138.00									-72.2	24.9	-.4	-.9	-5.6	
		-39.7	12.3	2800	2082	-14.2	5.9	-20	-66						
14TH	150.00									-32.5	12.6	-.1	-.2	-2.8	
		-30.4	8.7	2800	2082	-10.9	4.2	-20	-71						
MECH	162.00									-2.1	3.9	-.0	-.0	-.4	
		-2.1	3.9	2031	1223	-1.1	3.2	-81	-44						
TOP	177.00									0.0	0.0	0.0	0.0	0.0	

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 60

ONE LAKEWAY CENTER
CONFIGURATION A
REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00	-27.0	20.0	3603	4785	-7.5	4.2	-6	-8	-364.9	248.2	-19.4	-30.6	-7.6
ME22	17.00	-20.3	21.3	2755	3659	-7.4	5.8	-11	-11	-337.8	228.2	-15.3	-24.7	-7.2
4TH	30.00	-28.8	22.3	2892	3378	-10.0	6.6	-13	-17	-317.5	206.9	-12.5	-20.4	-6.8
5TH	42.00	-34.3	22.2	2940	3378	-11.7	6.6	-6	-10	-288.7	184.6	-10.2	-16.8	-6.0
6TH	54.00	-29.7	21.7	2921	2450	-10.2	8.8	-3	-4	-254.4	162.4	-8.1	-13.5	-5.5
7TH	66.00	-29.3	19.2	2800	2082	-10.5	9.2	-5	-8	-224.7	140.7	-6.3	-10.6	-5.3
8TH	78.00	-29.5	18.7	2800	2082	-10.5	9.0	-6	-10	-195.4	121.5	-4.7	-8.1	-5.0
9TH	90.00	-29.7	18.2	2800	2082	-10.6	8.8	-7	-11	-165.9	102.8	-3.3	-5.9	-4.6
10TH	102.00	-29.0	19.1	2800	2082	-10.4	9.2	-10	-15	-136.2	84.6	-2.2	-4.1	-4.1
11TH	114.00	-28.2	20.2	2800	2082	-10.1	9.7	-13	-18	-107.2	65.5	-1.3	-2.7	-3.5
12TH	126.00	-27.3	20.9	2800	2082	-9.7	10.1	-16	-21	-79.0	45.2	-.6	-1.6	-2.7
13TH	138.00	-23.3	15.7	2800	2082	-8.3	7.5	-16	-23	-51.7	24.3	-.2	-.8	-1.8
14TH	150.00	-19.3	10.4	2800	2082	-6.9	5.0	-14	-26	-28.4	8.6	-.0	-.3	-1.0
MECH	162.00	-9.1	-1.8	2031	1223	-4.5	-1.4	7	-38	-9.1	-1.8	.0	-.1	-.4
TOP	177.00									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS :				ONE LAKEWAY CENTER				REFERENCE PRESSURE 38.0 PSF				GUST FACTOR 1.32				
WIND DIRECTION 70		CONFIGURATION A														
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)				
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z		
GRND	0.00									-98.6	390.4	-31.9	-5.2	17.4		
		-20.6	24.1	3603	4785	-5.7	5.0	-14	-12							
MEZZ	17.00									-78.0	366.3	-25.5	-3.7	18.0		
		-16.5	25.8	2755	3659	-6.0	7.1	-19	-12							
4TH	30.00									-61.5	340.4	-20.9	-2.8	18.7		
		-19.6	26.3	2892	3378	-6.8	7.8	-13	-10							
5TH	42.00									-41.9	314.1	-16.9	-2.2	19.2		
		-24.7	35.9	2940	3378	-8.4	10.6	-0	-0							
6TH	54.00									-17.2	278.2	-13.4	-1.8	19.2		
		-3.8	38.5	2921	2450	-1.3	15.7	58	6							
7TH	66.00									-13.3	239.8	-10.3	-1.7	17.0		
		.4	35.4	2800	2082	.2	17.0	71	-1							
8TH	78.00									-13.7	204.4	-7.6	-1.5	14.5		
		1.0	34.2	2800	2082	.3	16.4	75	-2							
9TH	90.00									-14.7	170.2	-5.4	-1.3	11.9		
		1.5	33.0	2800	2082	.5	15.9	79	-4							
10TH	102.00									-16.2	137.2	-3.5	-1.1	9.3		
		1.3	32.9	2800	2082	.5	15.8	75	-3							
11TH	114.00									-17.5	104.3	-2.1	-.9	6.8		
		1.1	33.0	2800	2082	.4	15.9	69	-2							
12TH	126.00									-18.6	71.2	-1.0	-.7	4.5		
		.7	32.6	2800	2082	.2	15.7	63	-1							
13TH	138.00									-19.3	38.6	-.3	-.5	2.5		
		-2.1	24.9	2800	2082	-.7	12.0	61	5							
14TH	150.00									-17.2	13.7	-.0	-.3	.9		
		-4.8	17.1	2800	2082	-1.7	8.2	55	15							
MECH	162.00									-12.4	-3.4	.0	-.1	-.1		
		-12.4	-3.4	2031	1223	-6.1	-2.8	1	-5							
TOP	177.00									0.0	0.0	0.0	0.0	0.0		

TABLE 7. SHEAR AND MOMENT DIAGRAMS :					ONE LAKEWAY CENTER									
WIND DIRECTION 80		CONFIGURATION A					REFERENCE PRESSURE 38.0 PSF					GUST FACTOR 1.32		
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00													
		-10.4	25.1	3603	4785	-2.9	5.2	-17	-7	210.1	461.8	-39.8	24.8	39.5
MEZZ	17.00													
		-8.8	26.0	2755	3659	-3.2	7.1	-18	-6	220.4	436.7	-32.2	21.1	40.0
4TH	30.00													
		-6.4	23.7	2892	3378	-2.2	7.0	-12	-3	229.3	410.7	-26.7	18.2	40.5
5TH	42.00													
		-11.4	38.1	2940	3378	-3.9	11.3	0	0	235.7	387.0	-21.9	15.4	40.9
6TH	54.00													
		24.3	44.9	2921	2450	8.3	18.3	69	-38	247.1	349.0	-17.4	12.5	40.9
7TH	66.00													
		30.5	42.1	2800	2082	10.9	20.2	72	-52	222.7	304.1	-13.5	9.7	36.8
8TH	78.00													
		30.5	41.3	2800	2082	10.9	19.8	74	-55	192.2	262.0	-10.1	7.2	32.2
9TH	90.00													
		30.6	40.4	2800	2082	10.9	19.4	76	-58	161.7	220.7	-7.2	5.1	27.5
10TH	102.00													
		31.0	40.9	2800	2082	11.1	19.6	76	-57	131.1	180.3	-4.8	3.3	22.6
11TH	114.00													
		31.4	41.5	2800	2082	11.2	20.0	75	-57	100.1	139.4	-2.9	2.0	17.7
12TH	126.00													
		31.4	41.7	2800	2082	11.2	20.0	75	-56	68.7	97.9	-1.5	.9	12.8
13TH	138.00													
		24.6	33.7	2800	2082	8.8	16.2	80	-58	37.3	56.2	-.6	.3	7.9
14TH	150.00													
		17.7	25.7	2800	2082	6.3	12.3	89	-61	12.7	22.5	-.1	.0	3.8
MECH	162.00													
		-5.1	-3.2	2031	1223	-2.5	-2.6	-40	64	-5.1	-3.2	.0	-.0	.4
TOP	177.00													
										0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 90

ONE LAKEWAY CENTER
CONFIGURATION A
REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									491.3	590.2	-50.4	52.5	58.3
MEZZ	17.00	-2.1	38.8	3603	4785	-1.6	8.1	-28	-2	493.4	551.4	-40.7	44.1	59.4
4TH	30.00	-4.8	39.3	2755	3659	-1.8	10.7	-28	-3	498.3	512.1	-33.8	37.7	60.6
5TH	42.00	5.6	30.6	2892	3378	1.9	9.1	-12	2	492.7	481.5	-27.8	31.7	60.9
6TH	54.00	3.4	46.7	2940	3378	1.2	13.8	7	-1	489.3	434.8	-22.3	25.8	60.6
7TH	66.00	52.3	52.5	2921	2450	17.9	21.4	59	-59	437.0	382.3	-17.4	20.3	54.4
8TH	78.00	57.6	49.7	2800	2082	20.6	23.9	59	-68	379.4	332.6	-13.1	15.4	47.6
9TH	90.00	56.6	50.1	2800	2082	20.2	24.1	60	-67	322.9	282.5	-9.4	11.2	40.8
10TH	102.00	53.5	50.5	2800	2082	19.8	24.3	61	-67	267.3	231.9	-6.4	7.6	34.0
11TH	114.00	56.7	51.4	2800	2082	20.3	24.7	60	-67	210.6	180.5	-3.9	4.8	27.1
12TH	126.00	53.3	52.4	2800	2082	20.8	25.2	60	-66	152.3	128.1	-2.0	2.6	20.1
13TH	138.00	59.2	52.7	2800	2082	21.1	25.3	59	-66	93.2	75.4	-1.8	1.1	13.0
14TH	150.00	49.8	43.5	2800	2082	17.8	20.9	62	-71	43.4	31.9	-1.2	.3	6.8
MECH	162.00	40.4	34.3	2800	2082	14.4	16.5	66	-78	3.0	-2.5	.0	.0	1.4
TOP	177.00	3.0	-2.5	2031	1223	1.5	-2.0	-221	-272	0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 100

ONE LAKEWAY CENTER

CONFIGURATION A

REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									486.5	482.0	-42.2	50.3	45.6
		5.9	28.6	3603	4785	1.6	6.0	-29	6					
MEZZ	17.00					.8	8.2	-31	2	480.7	453.3	-34.2	42.1	46.5
		2.1	30.2	2755	3659									
4TH	30.00					3.8	6.6	-8	4	478.5	423.2	-28.5	35.9	47.4
		11.0	22.4	2892	3378									
5TH	42.00					3.1	10.9	3	-1	467.5	400.8	-23.6	30.2	47.6
		9.1	36.7	2940	3378									
6TH	54.00					16.3	17.4	47	-52	458.4	364.1	-19.0	24.7	47.5
		47.6	42.6	2921	2450									
7TH	66.00					18.9	19.7	47	-60	410.8	321.5	-14.9	19.4	43.1
		52.8	41.0	2800	2082									
8TH	78.00					18.6	19.8	49	-61	358.0	280.5	-11.2	14.8	38.0
		52.0	41.2	2800	2082									
9TH	90.00					18.3	19.9	51	-63	306.1	239.3	-8.1	10.8	32.8
		51.2	41.5	2800	2082									
10TH	102.00					18.7	20.5	51	-62	254.9	197.8	-5.5	7.5	27.4
		52.4	42.6	2800	2082									
11TH	114.00					19.2	21.1	50	-62	202.5	155.2	-3.4	4.7	22.0
		53.9	43.8	2800	2082									
12TH	126.00					19.6	21.4	50	-61	148.6	111.4	-1.8	2.6	16.5
		54.8	44.6	2800	2082									
13TH	138.00					17.2	18.2	51	-65	93.8	66.8	-.7	1.2	10.9
		48.1	37.9	2800	2082									
14TH	150.00					14.8	15.0	53	-70	45.7	28.9	-.1	.3	5.8
		41.3	31.2	2800	2082									
MECH	162.00					2.2	-1.9	-119	-220	4.4	-2.4	.0	.0	1.2
		4.4	-2.4	2031	1223									
TOP	177.00									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 110

ONE LAKEWAY CENTER
CONFIGURATION A

REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									546.5	579.9	-51.5	55.7	41.8
MEZZ	17.00	10.2	30.3	3603	4785	2.8	6.3	-35	12	536.2	549.6	-41.9	46.5	43.0
		5.0	33.2	2755	3659	1.8	9.1	-35	5					
4TH	30.00									531.3	516.4	-35.0	39.6	44.2
		14.9	26.3	2892	3378	5.2	7.8	-14	8					
5TH	42.00									516.3	490.2	-28.9	33.3	44.6
		14.1	46.0	2940	3378	4.8	13.6	-7	2					
6TH	54.00									502.2	444.2	-23.3	27.2	45.0
		52.7	50.9	2921	2450	18.1	20.8	38	-39					
7TH	66.00									449.5	393.3	-18.3	21.5	41.0
		57.4	49.7	2800	2082	20.5	23.9	41	-47					
8TH	78.00									392.1	343.6	-13.9	16.4	36.3
		56.6	50.3	2800	2082	20.2	24.2	43	-48					
9TH	90.00									335.5	293.3	-10.1	12.1	31.4
		55.8	50.8	2800	2082	19.9	24.4	45	-50					
10TH	102.00									279.7	242.4	-6.9	8.4	26.3
		56.7	51.8	2800	2082	20.3	24.9	45	-50					
11TH	114.00									223.0	190.6	-4.3	5.3	21.2
		57.9	52.8	2800	2082	20.7	25.4	45	-50					
12TH	126.00									165.1	137.8	-2.3	3.0	15.9
		59.7	53.3	2800	2082	20.9	25.6	45	-50					
13TH	138.00									106.5	84.5	-1.0	1.4	10.6
		52.5	46.1	2800	2082	18.8	22.2	46	-52					
14TH	150.00									53.9	38.3	-.2	.4	5.7
		46.4	38.9	2800	2082	16.6	18.7	47	-56					
MECH	162.00									7.6	-.6	.0	.1	1.3
		7.6	-.6	2031	1223	3.7	-.5	-13	-172					
TOP	177.00									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 120

ONE LAKEWAY CENTER

CONFIGURATION A

REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									597.2	655.4	-60.4	60.7	39.4
		10.5	24.9	3603	4785	2.9	5.2	-38	16					
MEZZ	17.00									586.6	630.5	-49.5	50.7	40.6
		6.2	28.3	2755	3659	2.2	7.7	-36	8					
4TH	30.00									580.4	602.2	-41.5	43.1	41.7
		18.2	25.9	2892	3378	6.3	7.7	-9	6					
5TH	42.00									562.2	576.3	-34.4	36.2	42.0
		18.4	53.6	2940	3378	6.3	15.9	-12	4					
6TH	54.00									543.9	522.6	-27.8	29.6	42.7
		58.2	58.6	2921	2450	19.9	23.9	32	-32					
7TH	66.00									485.7	464.0	-21.9	23.4	39.0
		61.8	57.9	2800	2082	22.1	27.8	36	-39					
8TH	78.00									423.9	406.2	-16.7	18.0	34.5
		60.2	58.5	2800	2082	21.5	28.1	39	-40					
9TH	90.00									363.7	347.7	-12.1	13.2	29.8
		58.6	59.0	2800	2082	20.9	28.4	41	-41					
10TH	102.00									305.0	288.7	-8.3	9.2	25.0
		60.3	60.3	2800	2082	21.5	29.0	41	-41					
11TH	114.00									244.7	228.3	-5.2	5.9	20.0
		62.4	61.7	2800	2082	22.3	29.6	40	-41					
12TH	126.00									182.4	166.6	-2.9	3.4	15.0
		63.9	62.5	2800	2082	22.8	30.0	39	-40					
13TH	138.00									118.5	104.1	-1.2	1.6	10.0
		57.7	55.1	2800	2082	20.6	26.5	40	-42					
14TH	150.00									60.8	49.0	-.3	.5	5.4
		51.5	47.6	2800	2082	18.4	22.9	40	-43					
MECH	162.00									9.3	1.4	-.0	.1	1.3
		9.3	1.4	2031	1223	4.6	1.2	21	-133					
TOP	177.00									0.0	0.0	0.0	0.0	0.0

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									602.8	651.4	-63.8	60.9	37.6
MEZZ	17.00	11.6	12.3	3603	4785	3.2	2.6	-20	19	591.2	639.1	-52.8	50.7	38.1
4TH	30.00	8.8	12.5	2755	3659	3.2	3.4	-25	18	582.4	626.6	-44.6	43.1	38.6
5TH	42.00	20.6	20.7	2892	3378	7.1	6.1	-0	0	561.8	605.8	-37.2	36.2	38.6
6TH	54.00	22.4	53.3	2940	3378	7.6	15.8	-9	4	539.4	552.5	-30.3	29.6	39.2
7TH	66.00	60.1	61.0	2921	2450	20.6	24.9	30	-29	479.4	491.6	-24.0	23.5	35.6
8TH	78.00	60.9	60.1	2800	2082	21.8	28.9	34	-34	418.5	431.5	-18.5	18.1	31.5
9TH	90.00	58.5	59.1	2800	2082	20.9	28.4	37	-36	360.0	372.4	-13.6	13.4	27.2
		56.1	58.1	2800	2082	20.0	27.9	39	-38					
10TH	102.00									303.9	314.3	-9.5	9.5	22.8
		57.7	60.7	2800	2082	20.6	29.2	39	-37					
11TH	114.00									246.2	253.6	-6.1	6.2	18.2
		59.9	63.8	2800	2082	21.4	30.6	38	-36					
12TH	126.00									186.4	189.8	-3.5	3.6	13.6
		61.7	66.4	2800	2082	22.0	31.9	38	-35					
13TH	138.00									124.7	123.4	-1.6	1.7	9.0
		58.2	61.2	2800	2082	20.8	29.4	36	-34					
14TH	150.00									66.4	62.2	-.5	.6	4.8
		54.7	56.0	2800	2082	19.5	26.9	34	-33					
MECH	162.00									11.7	6.2	-0.0	.1	1.1
		11.7	6.2	2031	1223	5.8	5.1	38	-71					
TOP	177.00									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS :				ONE LAKEWAY CENTER				REFERENCE PRESSURE 38.0 PSF				GUST FACTOR 1.32				
WIND DIRECTION 140		CONFIGURATION A														
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)				
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z		
GRND	0.00									395.2	368.3	-41.6	40.1	27.2		
MEZZ	17.00	10.3	1.2	3603	4785	2.9	.3	-3	29	384.9	367.1	-35.3	33.5	27.5		
		7.3	-.8	2755	3659	2.6	-.2	2	17							
4TH	30.00									377.6	367.9	-30.6	28.5	27.7		
		19.2	3.2	2892	3378	6.7	1.0	4	-21							
5TH	42.00									358.4	364.7	-26.2	24.1	27.2		
		21.8	19.3	2940	3378	7.4	5.7	4	-4							
6TH	54.00									336.6	345.4	-21.9	19.9	27.1		
		41.4	27.7	2921	2450	14.2	11.3	29	-43							
7TH	66.00									295.3	317.7	-17.9	16.2	24.5		
		37.1	32.3	2800	2082	13.2	15.5	34	-39							
8TH	78.00									258.2	285.4	-14.3	12.8	22.0		
		30.7	29.4	2800	2082	11.0	14.1	38	-40							
9TH	90.00									227.5	256.0	-11.1	9.9	19.6		
		24.3	26.4	2800	2082	8.7	12.7	44	-40							
10TH	102.00									203.2	229.6	-8.1	7.3	17.5		
		27.8	31.5	2800	2082	9.9	15.1	45	-40							
11TH	114.00									175.4	198.1	-5.6	5.1	15.0		
		32.7	37.7	2800	2082	11.7	18.1	48	-37							
12TH	126.00									142.7	160.4	-3.4	3.2	12.0		
		37.5	43.8	2800	2082	13.4	21.0	45	-38							
13TH	138.00									105.2	116.6	-1.8	1.7	8.6		
		40.9	47.6	2800	2082	14.6	22.9	43	-37							
14TH	150.00									64.3	69.0	-.7	.7	5.1		
		44.3	51.4	2800	2082	15.8	24.7	41	-36							
MECH	162.00									19.9	17.6	-.1	.1	1.4		
		19.9	17.6	2031	1223	9.8	14.4	34	-38							
TOP	177.00									0.0	0.0	0.0	0.0	0.0		

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 150

ONE LAKEWAY CENTER
CONFIGURATION A
REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									260.6	168.0	-19.3	22.4	19.9
		16.1	-3.0	3603	4785	4.5	-1.6	6	31					
MEZZ	17.00									244.5	171.0	-16.5	18.1	20.4
		11.5	-1.9	2755	3659	4.2	-1.5	3	16					
4TH	30.00									233.1	172.9	-14.2	15.0	20.6
		23.0	2.4	2892	3378	8.0	.7	1	-5					
5TH	42.00									210.0	170.6	-12.2	12.3	20.5
		26.0	11.6	2940	3378	8.8	3.4	-1	2					
6TH	54.00									184.1	159.0	-10.2	10.0	20.5
		32.4	12.2	2921	2450	11.1	5.0	18	-47					
7TH	66.00									151.6	146.8	-8.4	8.0	18.8
		25.6	16.5	2800	2082	9.1	7.9	28	-43					
8TH	78.00									126.1	130.3	-6.7	6.3	17.2
		17.8	12.9	2800	2082	6.4	6.2	37	-51					
9TH	90.00									108.2	117.4	-5.2	4.9	15.8
		10.1	9.3	2800	2082	3.6	4.5	60	-65					
10TH	102.00									98.1	108.1	-3.9	3.6	14.6
		11.7	12.7	2800	2082	4.2	6.1	71	-65					
11TH	114.00									86.4	95.4	-2.6	2.5	12.9
		14.6	17.1	2800	2082	5.2	8.2	74	-64					
12TH	126.00									71.7	78.3	-1.6	1.6	10.7
		17.6	21.4	2800	2082	6.3	10.3	76	-63					
13TH	138.00									54.1	56.9	-.8	.8	8.0
		21.1	24.9	2800	2082	7.5	11.9	74	-63					
14TH	150.00									33.0	32.1	-.2	.3	4.8
		24.6	28.3	2800	2082	8.8	13.6	72	-62					
MECH	162.00									8.4	3.8	-.0	.1	1.3
		8.4	3.8	2031	1223	4.1	3.1	57	-126					
TOP	177.00									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS : WIND DIRECTION 160														
ONE LAKEWAY CENTER CONFIGURATION A														
REFERENCE PRESSURE 38.0 PSF														
GUST FACTOR 1.32														
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									1.1	-46.8	2.1	-5.5	-1.0
		16.0	-15.2	3603	4785	4.4	-3.2	10	11					
MEZZ	17.00									-14.9	-31.6	1.4	-5.4	.3
		10.3	-2.2	2755	3659	3.7	-.6	6	28					
4TH	30.00									-25.2	-29.4	1.0	-5.2	.6
		18.1	-1.2	2892	3378	6.3	-.4	0	6					
5TH	42.00									-43.3	-28.2	.6	-4.8	.7
		19.4	-1.9	2940	3378	6.6	-.6	-0	-3					
6TH	54.00									-62.7	-26.2	.3	-4.1	.6
		1.0	-12.0	2921	2450	.3	-4.9	-7	-1					
7TH	66.00									-63.7	-14.2	.1	-3.4	.6
		-3.0	-4.9	2800	2082	-1.1	-2.3	35	-22					
8TH	78.00									-60.7	-9.4	-.1	-2.6	.8
		-6.9	-5.6	2800	2082	-2.5	-2.7	16	-20					
9TH	90.00									-53.7	-3.8	-.1	-1.9	1.0
		-10.9	-6.3	2800	2082	-3.9	-3.0	9	-15					
10TH	102.00									-42.9	2.4	-.1	-1.4	1.2
		-10.2	-3.8	2800	2082	-3.6	-1.8	3	-8					
11TH	114.00									-32.7	6.2	-.1	-.9	1.3
		-8.8	-.8	2800	2082	-3.1	-.4	-1	6					
12TH	126.00									-23.9	7.0	-.0	-.6	1.3
		-7.4	2.1	2800	2082	-2.7	1.0	7	25					
13TH	138.00									-16.5	4.9	.1	-.3	1.1
		-5.8	4.5	2800	2082	-2.1	2.2	26	33					
14TH	150.00									-10.7	.4	.1	-.2	.8
		-4.1	6.9	2800	2082	-1.5	3.3	44	26					
MECH	162.00									-6.6	-6.5	.0	-.0	.4
		-6.6	-6.5	2031	1223	-3.2	-5.3	-27	28					
TOP	177.00									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 170

ONE LAKEWAY CENTER

CONFIGURATION A

REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									-86.1	-123.1	10.7	-15.4	-10.9
		21.6	-10.4	3603	4785	6.0	-2.2	12	26					
MEZZ	17.00									-107.7	-112.7	8.7	-13.8	-10.2
		13.4	2.5	2755	3659	4.9	.7	-7	39					
4TH	30.00									-121.1	-115.2	7.2	-12.3	-9.7
		19.7	.0	2892	3378	6.8	.0	-0	17					
5TH	42.00									-140.7	-115.2	5.8	-10.7	-9.3
		19.0	-12.8	2940	3378	6.5	-3.8	-6	-9					
6TH	54.00									-159.8	-102.4	4.5	-8.9	-9.6
		-14.7	-25.1	2921	2450	-5.0	-10.2	13	-8					
7TH	66.00									-145.0	-77.3	3.4	-7.1	-9.1
		-17.0	-13.4	2800	2082	-6.1	-6.4	31	-39					
8TH	78.00									-128.0	-64.0	2.6	-5.5	-8.1
		-18.5	-12.2	2800	2082	-6.6	-5.9	28	-42					
9TH	90.00									-109.6	-51.7	1.9	-4.0	-7.0
		-20.0	-11.1	2800	2082	-7.1	-5.3	25	-45					
10TH	102.00									-89.6	-40.6	1.3	-2.8	-5.8
		-19.1	-9.9	2800	2082	-6.8	-4.8	25	-48					
11TH	114.00									-70.5	-30.7	.9	-1.9	-4.6
		-17.8	-8.7	2800	2082	-6.4	-4.2	25	-51					
12TH	126.00									-52.7	-22.0	.6	-1.1	-3.5
		-16.5	-7.3	2800	2082	-5.9	-3.5	25	-56					
13TH	138.00									-36.2	-14.7	.3	-.6	-2.4
		-14.6	-4.1	2800	2082	-5.2	-2.0	21	-73					
14TH	150.00									-21.6	-10.6	.2	-.3	-1.3
		-12.6	-.9	2800	2082	-4.5	-.4	6	-94					
MECH	162.00									-9.0	-9.7	.1	-.1	-.1
		-9.0	-9.7	2031	1223	-4.4	-7.9	3	-3					
TOP	177.00									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 180

ONE LAKEWAY CENTER
CONFIGURATION A

REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									-100.5	-141.6	13.5	-17.8	-13.6
MEZZ	17.00	27.3	-3.6	3603	4785	7.6	-1.8	5	35	-127.9	-138.0	11.1	-15.9	-12.6
4TH	30.00	16.5	8.1	2755	3659	6.0	2.2	-17	35	-144.4	-146.1	9.2	-14.1	-11.9
5TH	42.00	22.0	3.1	2892	3378	7.6	.9	-3	18	-166.4	-149.2	7.5	-12.3	-11.1
6TH	54.00	20.1	-20.7	2940	3378	6.8	-6.1	-21	-21	-186.5	-128.5	5.8	-10.1	-12.3
7TH	66.00	-19.3	-30.8	2921	2450	-6.6	-12.6	7	-5	-167.2	-97.8	4.4	-8.0	-12.0
8TH	78.00	-21.7	-14.8	2800	2082	-7.8	-7.1	27	-40	-145.5	-83.0	3.4	-6.1	-10.7
9TH	90.00	-22.5	-14.6	2800	2082	-8.0	-7.0	27	-42	-123.0	-68.4	2.4	-4.5	-9.4
10TH	102.00	-23.2	-14.5	2800	2082	-8.3	-6.9	27	-43	-99.8	-54.0	1.7	-3.2	-8.0
11TH	114.00	-21.4	-13.1	2800	2082	-7.7	-6.3	29	-48	-78.4	-40.9	1.1	-2.1	-6.6
12TH	126.00	-19.3	-11.5	2800	2082	-6.9	-5.5	33	-55	-59.0	-29.4	.7	-1.3	-5.2
13TH	138.00	-17.3	-9.8	2800	2082	-6.2	-4.7	36	-64	-41.7	-19.6	.4	-.7	-3.7
14TH	150.00	-16.4	-6.1	2800	2082	-5.8	-2.9	33	-89	-25.4	-13.5	.2	-.3	-2.0
MECH	162.00	-15.4	-2.4	2800	2082	-5.5	-1.1	18	-116	-10.0	-11.1	.1	-.1	-.2
TOP	177.00	-10.0	-11.1	2031	1223	-4.9	-9.1	10	-9	0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 190

CONFIGURATION A

ONE LAKEWAY CENTER
REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									-70.4	-162.4	15.6	-15.9	-13.3
		31.7	-4.1	3603	4785	8.8	-.9	4	29					
MEZZ	17.00									-102.1	-158.3	12.9	-14.4	-12.3
		19.3	9.8	2755	3659	7.0	2.7	-15	29					
4TH	30.00									-121.5	-168.1	10.7	-13.0	-11.7
		25.8	3.1	2892	3378	8.9	.9	-1	9					
5TH	42.00									-147.3	-171.2	8.7	-11.3	-11.4
		24.4	-25.7	2940	3378	8.3	-7.6	-25	-24					
6TH	54.00									-171.7	-145.5	6.8	-9.4	-12.6
		-17.2	-33.9	2921	2450	-5.9	-13.8	6	-3					
7TH	66.00									-154.5	-111.6	5.3	-7.5	-12.4
		-20.7	-16.4	2800	2082	-7.4	-7.9	31	-39					
8TH	78.00									-133.8	-95.2	4.0	-5.7	-11.1
		-20.7	-16.1	2800	2082	-7.4	-7.7	32	-42					
9TH	90.00									-113.1	-79.1	3.0	-4.3	-9.7
		-20.8	-15.7	2800	2082	-7.4	-7.6	34	-44					
10TH	102.00									-92.3	-63.4	2.1	-3.0	-8.2
		-19.1	-14.2	2800	2082	-6.8	-6.8	37	-50					
11TH	114.00									-73.2	-49.2	1.4	-2.0	-6.8
		-17.3	-12.5	2800	2082	-6.2	-6.0	42	-57					
12TH	126.00									-55.9	-36.7	.9	-1.3	-5.2
		-15.5	-10.7	2800	2082	-5.5	-5.2	47	-68					
13TH	138.00									-40.4	-25.9	.6	-.7	-3.7
		-15.2	-7.8	2800	2082	-5.4	-3.7	45	-89					
14TH	150.00									-25.3	-18.2	.3	-.3	-2.0
		-14.8	-4.8	2800	2082	-5.3	-2.3	36	-113					
MECH	162.00									-10.4	-13.4	.1	-.1	-.2
		-10.4	-13.4	2031	1223	-5.1	-11.0	7	-6					
TOP	177.00									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 200

ONE LAKEWAY CENTER

CONFIGURATION A

REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									-31.7	-121.2	12.9	-12.5	-12.7
		33.4	2.1	3603	4785	9.3	.4	-2	32					
MEZZ	17.00									-65.1	-123.3	10.9	-11.6	-11.6
		20.7	11.6	2755	3659	7.5	3.2	-16	28					
4TH	30.00									-85.8	-134.9	9.2	-10.7	-10.8
		27.8	5.5	2892	3378	9.6	1.6	-2	11					
5TH	42.00									-113.6	-140.4	7.5	-9.5	-10.5
		25.8	-19.7	2940	3378	8.8	-5.8	-21	-26					
6TH	54.00									-139.4	-120.7	6.0	-7.9	-11.6
		-12.7	-28.6	2921	2450	-4.4	-11.7	6	-3					
7TH	66.00									-126.7	-92.1	4.7	-6.3	-11.4
		-16.3	-12.9	2800	2082	-5.8	-6.2	35	-44					
8TH	78.00									-110.4	-79.2	3.7	-4.9	-10.2
		-16.4	-12.1	2800	2082	-5.9	-5.8	38	-52					
9TH	90.00									-94.0	-67.1	2.8	-3.7	-8.9
		-16.5	-11.2	2800	2082	-5.9	-5.4	40	-59					
10TH	102.00									-77.5	-55.9	2.1	-2.7	-7.5
		-15.2	-10.5	2800	2082	-5.4	-5.1	44	-64					
11TH	114.00									-62.3	-45.4	1.4	-1.8	-6.1
		-13.7	-9.8	2800	2082	-4.9	-4.7	50	-69					
12TH	126.00									-48.6	-35.5	1.0	-1.2	-4.6
		-12.3	-9.1	2800	2082	-4.4	-4.4	56	-76					
13TH	138.00									-36.2	-26.4	.6	-.7	-3.2
		-12.5	-7.0	2800	2082	-4.5	-3.4	52	-93					
14TH	150.00									-23.7	-19.4	.3	-.3	-1.7
		-12.7	-4.9	2800	2082	-4.5	-2.4	43	-111					
MECH	162.00									-11.0	-14.5	.1	-.1	-.0
		-11.0	-14.5	2031	1223	-5.4	-11.8	1	-1					
TOP	177.00									0.0	0.0	0.0	0.0	0.0

ONE LAKEWAY CENTER CONFIGURATION A REFERENCE PRESSURE 38.0 PSF GUST FACTOR 1.32														
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									-24.9	-49.3	8.1	-12.0	-12.9
		34.0	12.1	3603	4785	9.4	2.5	-13	36					
MEZZ	17.00									-58.9	-61.3	7.2	-11.3	-11.5
		20.4	16.3	2755	3659	7.4	4.5	-22	27					
4TH	30.00									-79.3	-77.6	6.3	-10.4	-10.6
		27.5	11.6	2892	3378	9.5	3.4	-8	19					
5TH	42.00									-106.8	-89.2	5.3	-9.3	-10.0
		26.7	-8.8	2940	3378	9.1	-2.6	-8	-23					
6TH	54.00									-133.5	-80.4	4.3	-7.8	-10.6
		-11.1	-20.8	2921	2450	-3.8	-8.5	13	-7					
7TH	66.00									-122.4	-59.6	3.4	-6.3	-10.3
		-14.8	-7.8	2800	2082	-5.3	-3.7	31	-60					
8TH	78.00									-107.6	-51.9	2.8	-4.9	-9.1
		-15.1	-6.7	2800	2082	-5.4	-3.2	30	-68					
9TH	90.00									-92.5	-45.2	2.2	-3.7	-7.9
		-15.4	-5.6	2800	2082	-5.5	-2.7	28	-77					
10TH	102.00									-77.0	-39.6	1.7	-2.7	-6.6
		-14.5	-5.5	2800	2082	-5.2	-2.6	30	-80					
11TH	114.00									-62.5	-34.1	1.2	-1.9	-5.3
		-13.4	-5.6	2800	2082	-4.8	-2.7	34	-82					
12TH	126.00									-49.1	-28.6	.9	-1.2	-4.0
		-12.4	-5.6	2800	2082	-4.4	-2.7	39	-85					
13TH	138.00									-36.8	-23.0	.6	-.7	-2.7
		-12.5	-4.6	2800	2082	-4.5	-2.2	35	-95					
14TH	150.00									-24.3	-18.4	.3	-.3	-1.3
		-12.7	-3.5	2800	2082	-4.5	-1.7	29	-104					
MECH	162.00									-11.6	-14.9	.1	-.1	.1
		-11.6	-14.9	2031	1223	-5.7	-12.1	-3	2					
TOP	177.00									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 220

ONE LAKEWAY CENTER

CONFIGURATION A

REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									66.5	40.1	1.9	-3.4	-9.7
MEZZ	17.00	36.9	24.1	3603	4785	10.2	5.0	-20	30	29.6	16.0	2.3	-4.2	-8.1
4TH	30.00	22.3	23.7	2755	3659	8.1	6.5	-22	21	7.3	-7.7	2.4	-4.4	-7.1
5TH	30.00	31.4	20.0	2892	3378	10.9	5.9	-10	16					
5TH	42.00	33.1	2.2	2940	3378	11.3	.6	1	-13	-24.1	-27.6	2.2	-4.3	-6.4
6TH	54.00	-2.0	-13.0	2921	2450	-.7	-5.3	8	-1	-57.3	-29.8	1.8	-3.8	-6.9
7TH	66.00	-5.7	-1.8	2800	2082	-2.0	-.9	40	-124	-55.3	-16.8	1.5	-3.2	-6.8
8TH	78.00	-6.1	-.6	2800	2082	-2.2	-.3	15	-152	-49.6	-15.0	1.4	-2.5	-6.0
9TH	90.00	-6.5	.6	2800	2082	-2.3	.3	-16	-167	-43.6	-14.4	1.2	-2.0	-5.1
10TH	102.00	-5.8	.4	2800	2082	-2.1	.2	-11	-172	-37.1	-15.0	1.0	-1.5	-4.0
11TH	114.00	-5.0	-.1	2800	2082	-1.8	-.0	2	-176	-31.3	-15.4	.8	-1.1	-3.0
12TH	126.00	-4.3	-.5	2800	2082	-1.6	-.2	19	-175	-26.2	-15.3	.6	-.7	-2.1
13TH	138.00	-5.6	-.3	2800	2082	-2.0	-.1	7	-139	-21.9	-14.8	.5	-.5	-1.3
14TH	150.00	-6.8	-.1	2800	2082	-2.4	-.1	2	-116	-16.3	-14.6	.3	-.2	-.5
MECH	162.00	-9.5	-14.4	2031	1223	-4.7	-11.8	-13	8	-9.5	-14.4	.1	-.1	.3
TOP	177.00									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 230

CONFIGURATION A

ONE LAKEWAY CENTER

REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									56.5	44.4	2.2	-3.0	-7.2
		23.4	27.0	3603	4785	8.2	5.7	-26	29					
MEZZ	17.00									27.1	17.3	2.7	-3.7	-5.7
		17.4	24.0	2755	3659	6.3	6.6	-26	19					
4TH	30.00									9.7	-6.7	2.8	-3.9	-4.7
		26.5	21.3	2892	3378	9.2	6.3	-14	17					
5TH	42.00									-16.7	-27.9	2.5	-3.9	-4.0
		30.4	5.9	2940	3378	10.4	1.7	1	-5					
6TH	54.00									-47.2	-33.8	2.2	-3.5	-4.1
		.6	-11.3	2921	2450	.2	-4.6	-13	-1					
7TH	66.00									-47.8	-22.6	1.8	-2.9	-4.3
		-2.2	-2.1	2800	2082	-.8	-1.0	77	-79					
8TH	78.00									-45.6	-20.4	1.6	-2.4	-3.9
		-4.0	-1.1	2800	2082	-1.4	-.6	36	-124					
9TH	90.00									-41.7	-19.3	1.3	-1.9	-3.4
		-5.8	-.2	2800	2082	-2.1	-.1	4	-127					
10TH	102.00									-35.9	-19.1	1.1	-1.4	-2.7
		-5.6	-.4	2800	2082	-2.0	-.2	10	-122					
11TH	114.00									-30.3	-18.7	.9	-1.0	-2.0
		-5.2	-.9	2800	2082	-1.9	-.4	20	-115					
12TH	126.00									-25.0	-17.8	.7	-.7	-1.3
		-4.9	-1.3	2800	2082	-1.8	-.6	28	-104					
13TH	138.00									-20.1	-16.5	.5	-.4	-.8
		-5.8	-1.4	2800	2082	-2.1	-.7	21	-86					
14TH	150.00									-14.3	-15.0	.3	-.2	-.3
		-6.7	-1.5	2800	2082	-2.4	-.7	17	-73					
MECH	162.00									-7.6	-13.5	.1	-.1	.3
		-7.6	-13.5	2031	1223	-3.7	-11.0	-15	8					
TOP	177.00									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 240

ONE LAKEWAY CENTER

CONFIGURATION A

REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00	22.7	27.5	3603	4785	6.3	5.8	-28	23	35.6	79.6	-2.0	-3.1	-6.6
MEZZ	17.00	12.6	23.2	2755	3659	4.6	6.3	-26	14	13.0	52.1	-.9	-3.5	-5.3
4TH	30.00	20.5	20.0	2892	3378	7.1	5.9	-17	18	.3	28.8	-.4	-3.6	-4.5
5TH	42.00	25.0	8.8	2940	3378	8.5	2.6	-1	2	-20.1	8.8	-.1	-3.5	-3.8
6TH	54.00	-.9	-7.3	2921	2450	-.3	-3.0	-1	0	-45.1	.1	-.1	-3.1	-3.8
7TH	66.00	-2.9	.2	2800	2082	-1.0	.1	-9	-115	-44.2	7.4	-.0	-2.5	-3.8
8TH	78.00	-4.1	1.1	2800	2082	-1.5	.6	-30	-106	-41.3	7.2	.0	-2.0	-3.4
9TH	90.00	-5.3	2.1	2800	2082	-1.9	1.0	-39	-99	-37.2	6.1	.1	-1.6	-3.0
10TH	102.00	-5.3	2.2	2800	2082	-1.9	1.0	-38	-93	-32.0	4.0	.2	-1.1	-2.4
11TH	114.00	-5.1	2.1	2800	2082	-1.8	1.0	-36	-87	-26.7	1.8	.2	-.8	-1.8
12TH	126.00	-5.0	2.1	2800	2082	-1.8	1.0	-33	-79	-21.6	-.3	.2	-.5	-1.3
13TH	138.00	-5.9	3.1	2800	2082	-2.1	1.5	-33	-64	-16.5	-2.4	.2	-.3	-.8
14TH	150.00	-6.8	4.0	2800	2082	-2.4	1.9	-31	-53	-10.6	-5.4	.2	-.1	-.3
MECH	162.00	-3.8	-9.4	2031	1223	-1.9	-7.7	-14	6	-3.8	-9.4	.1	-.0	.2
TOP	177.00									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 250

ONE LAKEWAY CENTER

CONFIGURATION A

REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									35.4	114.9	-6.6	-1.4	-6.2
		18.6	24.0	3603	4785	5.2	5.0	-26	20					
MEZZ	17.00									16.8	90.9	-4.9	-1.9	-5.2
		10.0	20.4	2755	3659	3.6	5.6	-22	11					
4TH	30.00									6.8	70.5	-3.8	-2.0	-4.6
		15.7	18.4	2892	3378	5.4	5.4	-17	15					
5TH	42.00									-9.0	52.2	-3.1	-2.0	-4.0
		19.1	11.5	2940	3378	6.5	3.4	-2	4					
6TH	54.00									-28.1	40.7	-2.5	-1.8	-3.9
		-1.2	-1.3	2921	2450	-0.4	-0.5	75	-72					
7TH	66.00									-26.8	42.0	-2.0	-1.4	-3.7
		-2.3	4.3	2800	2082	-0.8	2.1	-80	-43					
8TH	78.00									-24.5	37.6	-1.6	-1.1	-3.3
		-2.8	4.9	2800	2082	-1.0	2.4	-76	-43					
9TH	90.00									-21.7	32.7	-1.1	-0.9	-2.8
		-3.2	5.5	2800	2082	-1.2	2.7	-73	-43					
10TH	102.00									-18.5	27.2	-0.8	-0.6	-2.3
		-3.2	5.4	2800	2082	-1.1	2.6	-65	-39					
11TH	114.00									-15.2	21.8	-0.5	-0.4	-1.8
		-3.1	5.2	2800	2082	-1.1	2.5	-56	-34					
12TH	126.00									-12.1	16.6	-0.2	-0.3	-1.4
		-3.1	5.1	2800	2082	-1.1	2.4	-48	-29					
13TH	138.00									-9.1	11.5	-0.1	-0.1	-1.1
		-3.8	6.7	2800	2082	-1.4	3.2	-53	-30					
14TH	150.00									-5.3	4.8	.0	-0.0	-0.6
		-4.6	8.3	2800	2082	-1.6	4.0	-56	-31					
MECH	162.00									-0.7	-3.5	.0	-0.0	.0
		-0.7	-3.5	2031	1223	-0.3	-2.9	-4	1					
TOP	177.00									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 260

ONE LAKEWAY CENTER
CONFIGURATION A

REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									12.6	122.9	-8.9	-2.2	-5.2
MEZZ	17.00	13.2	17.8	3603	4785	3.7	3.7	-24	18	- .5	105.1	-6.9	-2.3	-4.5
4TH	30.00	7.2	15.5	2755	3659	2.6	4.2	-18	8	-7.7	89.5	-5.7	-2.3	-4.2
5TH	42.00	11.8	15.0	2892	3378	4.1	4.5	-11	9	-19.5	74.5	-4.7	-2.1	-3.9
6TH	54.00	14.2	11.6	2940	3378	4.8	3.4	3	-3	-33.7	62.9	-3.8	-1.8	-4.0
7TH	66.00	-2.5	2.5	2921	2450	-.8	1.0	-29	-28	-31.2	60.4	-3.1	-1.4	-3.9
8TH	78.00	-3.9	6.6	2800	2082	-1.4	3.2	-46	-27	-27.3	53.8	-2.4	-1.0	-3.4
9TH	90.00	-4.2	6.8	2800	2082	-1.5	3.3	-47	-29	-23.0	47.0	-1.8	-.7	-3.0
10TH	102.00	-4.5	7.0	2800	2082	-1.6	3.4	-49	-31	-18.5	40.0	-1.3	-.5	-2.5
11TH	114.00	-4.3	7.1	2800	2082	-1.5	3.4	-46	-28	-14.2	32.9	-.9	-.3	-2.1
12TH	126.00	-4.0	7.1	2800	2082	-1.4	3.4	-44	-24	-10.2	25.7	-.5	-.2	-1.7
13TH	138.00	-3.7	7.2	2800	2082	-1.3	3.5	-41	-21	-6.6	18.5	-.2	-.0	-1.3
14TH	150.00	-3.9	8.3	2800	2082	-1.4	4.0	-53	-25	-2.6	10.2	-.1	.0	-.7
MECH	162.00	-4.2	9.4	2800	2082	-1.5	4.5	-62	-28	1.6	.8	-.0	.0	-.1
TOP	177.00	1.6	.8	2031	1223	.8	.7	-13	25	0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS : ONE LAKEWAY CENTER														
WIND DIRECTION 270		CONFIGURATION A				REFERENCE PRESSURE 38.0 PSF					GUST FACTOR 1.32			
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00													
		8.1	15.6	3603	4785	2.2	3.3	-28	15	-1.1	139.5	-11.3	-2.5	-5.3
MEZZ	17.00													
		4.5	9.4	2755	3659	1.6	2.6	-18	9	-8.2	123.9	-9.1	-2.5	-4.7
4TH	30.00													
		7.8	10.8	2892	3378	2.7	3.2	-3	2	-12.6	114.5	-7.5	-2.3	-4.5
5TH	42.00													
		9.3	12.7	2940	3378	3.1	3.8	11	-8	-20.5	103.7	-6.2	-2.1	-4.5
6TH	54.00													
		-1.4	8.0	2921	2450	-1.5	3.3	-7	-1	-29.7	90.9	-5.0	-1.8	-4.7
7TH	66.00													
		-2.4	10.9	2800	2082	-1.8	5.2	-31	-7	-28.3	82.9	-4.0	-1.5	-4.6
8TH	78.00													
		-2.7	10.7	2800	2082	-1.0	5.1	-34	-9	-26.0	72.0	-3.1	-1.2	-4.3
9TH	90.00													
		-3.1	10.5	2800	2082	-1.1	5.1	-37	-11	-23.2	61.3	-2.3	-.9	-3.9
10TH	102.00													
		-3.5	10.2	2800	2082	-1.3	4.9	-42	-15	-20.2	50.8	-1.6	-.6	-3.5
11TH	114.00													
		-4.0	9.9	2800	2082	-1.4	4.7	-48	-19	-16.6	40.6	-1.0	-.4	-3.0
12TH	126.00													
		-4.4	9.5	2800	2082	-1.6	4.6	-53	-24	-12.7	30.7	-.6	-.2	-2.4
13TH	138.00													
		-4.5	9.5	2800	2082	-1.6	4.5	-66	-31	-8.3	21.2	-.3	-.1	-1.8
14TH	150.00													
		-4.6	9.4	2800	2082	-1.7	4.5	-78	-39	-3.8	11.7	-.1	-.0	-1.0
MECH	162.00													
		.8	2.3	2031	1223	.4	1.9	-52	18	.8	2.3	-.0	.0	-.1
TOP	177.00													
										0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 280

ONE LAKEWAY CENTER
CONFIGURATION A

REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									-148.6	85.0	-7.2	-15.4	-5.7
MEZZ	17.00	-5.3	5.2	3603	4785	-1.5	1.1	-26	-26	-143.3	79.8	-5.8	-12.9	-5.5
		-5.2	2.5	2755	3659	-1.9	.7	-10	-21					
4TH	30.00	-2.9	4.3	2892	3378	-1.0	1.3	19	13	-138.2	77.3	-4.8	-11.1	-5.3
5TH	42.00	-4.4	9.3	2940	3378	-1.5	2.8	22	10	-135.3	73.1	-3.9	-9.4	-5.4
6TH	54.00	-11.0	7.6	2921	2450	-3.8	3.1	-7	-10	-130.9	63.7	-3.0	-7.8	-5.7
7TH	66.00	-11.9	9.6	2800	2082	-4.3	4.6	-17	-22	-119.9	56.1	-2.3	-6.3	-5.5
8TH	78.00	-12.8	8.9	2800	2082	-4.6	4.3	-17	-25	-108.0	46.5	-1.7	-5.0	-5.1
9TH	90.00	-13.6	8.2	2800	2082	-4.8	3.9	-17	-28	-95.2	37.6	-1.2	-3.7	-4.6
10TH	102.00	-14.4	7.3	2800	2082	-5.1	3.5	-18	-35	-81.7	29.5	-.8	-2.7	-4.1
11TH	114.00	-15.2	6.4	2800	2082	-5.4	3.1	-18	-41	-67.3	22.1	-.5	-1.8	-3.5
12TH	126.00	-16.0	5.6	2800	2082	-5.7	2.7	-17	-47	-52.0	15.7	-.3	-1.1	-2.7
13TH	138.00	-15.4	5.4	2800	2082	-5.5	2.6	-18	-52	-36.0	10.1	-.1	-.5	-1.9
14TH	150.00	-14.8	5.2	2800	2082	-5.3	2.5	-20	-57	-20.6	4.7	-.0	-.2	-1.0
MECH	162.00	-5.8	-.5	2031	1223	-2.8	-.4	1	-6	-5.8	-.5	.0	-.0	-.0
TOP	177.00									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 290

ONE LAKEWAY CENTER

CONFIGURATION A

REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									-324.5	-234.5	23.1	-31.8	-13.4
		-19.4	-5.5	3603	4785	-5.4	-1.2	15	-53					
ME22	17.00									-305.1	-229.0	19.2	-26.5	-12.3
		-13.8	-6.8	2755	3659	-5.0	-1.9	22	-44					
4TH	30.00									-291.2	-222.1	16.2	-22.6	-11.5
		-5.7	-10.3	2892	3378	-2.0	-3.0	16	-9					
5TH	42.00									-285.6	-211.9	13.6	-19.2	-11.3
		-8.7	-17.1	2940	3378	-3.0	-5.1	-7	4					
6TH	54.00									-276.9	-194.8	11.2	-15.8	-11.5
		-25.0	-22.7	2921	2450	-8.6	-9.2	18	-19					
7TH	66.00									-251.9	-172.1	9.0	-12.6	-10.6
		-28.2	-18.5	2800	2082	-10.1	-8.9	23	-35					
8TH	78.00									-223.7	-153.6	7.0	-9.8	-9.2
		-29.4	-18.9	2800	2082	-10.5	-9.1	22	-34					
9TH	90.00									-194.3	-134.7	5.3	-7.2	-7.8
		-30.6	-19.2	2800	2082	-10.9	-9.2	22	-34					
10TH	102.00									-163.7	-115.5	3.8	-5.1	-6.3
		-31.9	-20.6	2800	2082	-11.4	-9.9	21	-32					
11TH	114.00									-131.8	-94.9	2.5	-3.3	-4.9
		-33.2	-22.1	2800	2082	-11.9	-10.6	20	-30					
12TH	126.00									-98.6	-72.8	1.5	-1.9	-3.4
		-34.2	-23.3	2800	2082	-12.2	-11.2	19	-28					
13TH	138.00									-64.4	-49.5	.8	-1.0	-2.0
		-29.0	-20.3	2800	2082	-10.3	-9.8	20	-29					
14TH	150.00									-35.4	-29.2	.3	-.4	-.8
		-23.8	-17.3	2800	2082	-8.5	-8.3	22	-30					
MECH	162.00									-11.6	-11.9	.1	-.1	.3
		-11.6	-11.9	2031	1223	-5.7	-9.7	-14	13					
TOP	177.00									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 300

ONE LAKEWAY CENTER

CONFIGURATION A

REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									-458.2	-498.5	45.0	-43.3	-12.8
MEZZ	17.00	-29.6	-22.7	3603	4785	-8.2	-4.7	12	-15	-428.6	-475.7	36.7	-35.8	-12.1
4TH	30.00	-21.4	-19.5	2755	3659	-7.8	-5.3	13	-14	-407.2	-456.3	30.7	-30.4	-11.6
5TH	42.00	-14.9	-26.7	2892	3378	-5.1	-7.9	3	-1	-392.3	-429.6	25.3	-25.6	-11.5
6TH	54.00	-16.9	-42.2	2940	3378	-5.8	-12.5	-9	4	-375.4	-387.4	20.4	-21.0	-11.9
7TH	66.00	-37.5	-48.6	2921	2450	-12.8	-19.8	12	-9	-337.9	-338.9	16.1	-16.7	-11.0
8TH	78.00	-40.8	-42.8	2800	2082	-14.6	-20.6	18	-18	-297.2	-296.1	12.3	-12.9	-9.5
9TH	90.00	-41.0	-43.4	2800	2082	-14.6	-20.9	19	-18	-256.2	-252.6	9.0	-9.6	-8.0
10TH	102.00	-41.2	-44.1	2800	2082	-14.7	-21.2	19	-18	-215.0	-208.6	6.2	-6.7	-6.4
11TH	114.00	-42.4	-44.2	2800	2082	-15.1	-21.2	18	-17	-172.7	-164.3	4.0	-4.4	-4.8
12TH	126.00	-43.7	-44.3	2800	2082	-15.6	-21.3	17	-17	-128.9	-120.0	2.3	-2.6	-3.3
13TH	138.00	-44.5	-43.9	2800	2082	-15.9	-21.1	16	-16	-84.4	-76.1	1.1	-1.3	-1.9
14TH	150.00	-37.0	-36.0	2800	2082	-13.2	-17.3	17	-17	-47.4	-40.1	.4	-.5	-.7
MECH	162.00	-29.5	-28.1	2800	2082	-10.6	-13.5	18	-19	-17.8	-12.0	.1	-.1	.4
TOP	177.00	-17.8	-12.0	2031	1223	-8.8	-9.8	-11	16	0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 310

ONE LAKEWAY CENTER
CONFIGURATION A

REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									-619.5	-560.1	49.7	-56.3	-14.0
MEZZ	17.00	-45.4	-33.2	3603	4785	-12.6	-6.9	3	-4	-574.1	-526.9	40.5	-46.2	-13.7
		-33.4	-27.1	2755	3659	-12.1	-7.4	4	-5	-540.7	-499.7	33.8	-38.9	-13.5
4TH	30.00	-28.6	-31.8	2892	3378	-9.9	-9.4	-2	2	-512.1	-467.9	28.0	-32.6	-13.6
5TH	42.00	-29.4	-42.8	2940	3378	-10.0	-12.7	-9	6	-482.7	-425.1	22.6	-26.6	-14.2
6TH	54.00	-50.0	-52.4	2921	2450	-17.1	-21.4	10	-10	-432.7	-372.7	17.9	-21.1	-13.1
7TH	66.00	-53.8	-46.8	2800	2082	-19.2	-22.5	16	-18	-378.9	-325.9	13.7	-16.3	-11.4
8TH	78.00	-54.0	-47.3	2800	2082	-19.3	-22.7	16	-19	-324.9	-278.6	10.0	-12.0	-9.6
9TH	90.00	-54.2	-47.9	2800	2082	-19.4	-23.0	17	-19	-270.7	-230.7	7.0	-8.5	-7.8
10TH	102.00	-54.5	-48.1	2800	2082	-19.5	-23.1	16	-19	-216.2	-182.6	4.5	-5.5	-6.0
11TH	114.00	-54.7	-48.2	2800	2082	-19.6	-23.2	16	-18	-161.5	-134.4	2.6	-3.3	-4.3
12TH	126.00	-54.5	-47.8	2800	2082	-19.5	-23.0	16	-18	-107.0	-86.5	1.3	-1.7	-2.5
13TH	138.00	-46.5	-39.9	2800	2082	-16.6	-19.2	16	-19	-60.5	-46.6	.5	-.7	-1.0
14TH	150.00	-38.6	-32.0	2800	2082	-13.8	-15.4	16	-20	-21.9	-14.5	.1	-.2	.3
MECH	162.00	-21.9	-14.5	2031	1223	-10.8	-11.9	-6	10	0.0	0.0	0.0	0.0	0.0
TOP	177.00													

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 320

ONE LAKEWAY CENTER

CONFIGURATION A

REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									-810.0	-578.6	52.0	-73.9	-16.8
		-56.0	-32.4	3603	4785	-15.6	-6.8	0	-0					
MEZZ	17.00									-753.9	-546.1	42.4	-60.6	-16.8
		-42.2	-26.4	2755	3659	-15.3	-7.2	0	-0					
4TH	30.00									-711.7	-519.7	35.5	-51.1	-16.8
		-39.7	-32.5	2892	3378	-13.7	-9.6	-3	4					
5TH	42.00									-672.0	-487.2	29.4	-42.8	-17.1
		-39.1	-44.1	2940	3378	-13.3	-13.1	-9	8					
6TH	54.00									-632.9	-443.1	23.8	-35.0	-17.8
		-63.6	-54.6	2921	2450	-21.8	-22.3	10	-12					
7TH	66.00									-569.3	-388.5	18.9	-27.7	-16.4
		-70.0	-47.9	2800	2082	-25.0	-23.0	14	-21					
8TH	78.00									-499.3	-340.6	14.5	-21.3	-14.3
		-70.8	-48.8	2800	2082	-25.3	-23.4	14	-21					
9TH	90.00									-428.4	-291.8	10.7	-15.8	-12.1
		-71.6	-49.6	2800	2082	-25.6	-23.8	14	-20					
10TH	102.00									-356.8	-242.2	7.5	-11.1	-10.0
		-72.2	-49.7	2800	2082	-25.8	-23.9	14	-21					
11TH	114.00									-284.7	-192.5	4.9	-7.2	-7.8
		-72.7	-49.6	2800	2082	-26.0	-23.8	14	-21					
12TH	126.00									-212.0	-142.9	2.9	-4.2	-5.6
		-72.5	-49.1	2800	2082	-25.9	-23.6	14	-21					
13TH	138.00									-139.5	-93.8	1.4	-2.1	-3.3
		-62.0	-41.3	2800	2082	-22.1	-19.9	14	-22					
14TH	150.00									-77.5	-52.4	.6	-.8	-1.4
		-51.5	-33.6	2800	2082	-18.4	-16.1	15	-22					
MECH	162.00									-26.1	-18.9	.1	-.2	.2
		-26.1	-18.9	2031	1223	-12.8	-15.4	-4	6					
TOP	177.00									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 330

ONE LAKEWAY CENTER
CONFIGURATION A
REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									-1070.4	-663.1	58.0	-100.4	-24.3
MEZZ	17.00	-61.0	-32.3	3603	4785	-16.9	-6.8	-0	1	-1009.4	-630.8	47.0	-82.8	-24.3
4TH	30.00	-46.8	-29.6	2755	3659	-17.0	-8.1	-1	2	-962.5	-601.1	39.0	-70.0	-24.4
5TH	42.00	-47.7	-43.7	2892	3378	-16.5	-12.9	-3	4	-914.8	-557.4	32.0	-58.7	-24.8
6TH	54.00	-47.0	-64.3	2940	3378	-16.0	-19.0	-11	8	-867.8	-493.2	25.7	-48.0	-25.8
7TH	66.00	-83.9	-68.0	2921	2450	-28.7	-27.7	11	-14	-783.9	-425.2	20.2	-38.1	-23.9
8TH	78.00	-96.2	-56.3	2800	2082	-34.3	-27.1	15	-25	-687.7	-368.9	15.5	-29.3	-20.6
9TH	90.00	-97.3	-56.1	2800	2082	-34.7	-27.0	14	-25	-590.4	-312.8	11.4	-21.6	-17.4
10TH	102.00	-98.4	-55.9	2800	2082	-35.1	-26.8	14	-24	-492.0	-256.9	8.0	-15.1	-14.2
11TH	114.00	-99.7	-54.5	2800	2082	-35.6	-26.2	13	-24	-392.3	-202.4	5.2	-9.8	-11.1
12TH	126.00	-101.1	-53.0	2800	2082	-36.1	-25.5	13	-24	-291.2	-149.4	3.1	-5.7	-7.9
13TH	138.00	-101.4	-51.0	2800	2082	-36.2	-24.5	12	-24	-189.8	-98.4	1.6	-2.8	-4.8
14TH	150.00	-86.7	-41.7	2800	2082	-31.0	-20.0	12	-25	-103.1	-56.7	.7	-1.0	-2.1
MECH	162.00	-71.9	-32.5	2800	2082	-25.7	-15.6	12	-26	-31.2	-24.2	.2	-.2	.1
TOP	177.00	-31.2	-24.2	2031	1223	-15.3	-19.8	-2	3	0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS 1														
WIND DIRECTION 340				ONE LAKEWAY CENTER				REFERENCE PRESSURE 38.0 PSF				GUST FACTOR 1.32		
CONFIGURATION A														
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									-1115.9	-515.7	43.3	-103.7	-26.9
		-66.2	-32.0	3603	4785	-18.4	-6.7	-1	3					
MEZZ	17.00									-1049.7	-483.7	34.9	-85.3	-27.1
		-49.1	-25.0	2755	3659	-17.8	-6.8	-2	5					
4TH	30.00									-1000.6	-458.7	28.7	-71.9	-27.4
		-52.4	-37.5	2892	3378	-18.1	-11.1	-1	1					
5TH	42.00									-948.2	-421.1	23.4	-60.3	-27.5
		-50.8	-54.8	2940	3378	-17.3	-16.2	-7	7					
6TH	54.00									-897.4	-366.4	18.7	-49.2	-28.2
		-86.8	-54.4	2921	2450	-29.7	-22.2	10	-15					
7TH	66.00									-810.6	-312.0	14.7	-38.9	-26.4
		-101.5	-42.9	2800	2082	-36.2	-20.6	12	-28					
8TH	78.00									-709.1	-269.2	11.2	-29.8	-23.0
		-102.4	-42.4	2800	2082	-36.6	-20.3	12	-29					
9TH	90.00									-606.6	-226.8	8.2	-21.9	-19.6
		-103.4	-41.8	2800	2082	-36.9	-20.1	12	-29					
10TH	102.00									-503.3	-185.0	5.7	-15.3	-16.1
		-103.9	-40.2	2800	2082	-37.1	-19.3	11	-29					
11TH	114.00									-399.4	-144.7	3.7	-9.8	-12.6
		-104.4	-38.5	2800	2082	-37.3	-18.5	11	-30					
12TH	126.00									-295.0	-106.3	2.2	-5.7	-9.1
		-103.9	-36.3	2800	2082	-37.1	-17.5	10	-30					
13TH	138.00									-191.2	-69.9	1.2	-2.8	-5.6
		-88.7	-28.9	2800	2082	-31.7	-13.9	10	-31					
14TH	150.00									-102.4	-41.0	.5	-1.0	-2.6
		-73.6	-21.5	2800	2082	-26.3	-10.3	9	-32					
MECH	162.00									-28.8	-19.5	.1	-.2	-.0
		-28.8	-19.5	2031	1223	-14.2	-16.0	0	-0					
TOP	177.00									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 350

ONE LAKEWAY CENTER
CONFIGURATION A REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									-1071.1	-328.3	27.4	-100.9	-28.3
MEZZ	17.00	-58.5	-23.1	3603	4785	-16.2	-4.8	-1	3	-1012.6	-305.2	22.0	-83.2	-28.5
4TH	30.00	-43.3	-20.3	2755	3659	-15.7	-5.6	-2	5	-969.3	-284.9	18.1	-70.3	-28.8
5TH	42.00	-49.7	-22.9	2892	3378	-17.2	-6.8	2	-4	-919.6	-262.0	14.9	-58.9	-28.6
6TH	54.00	-47.2	-32.6	2940	3378	-16.1	-9.7	-3	4	-872.4	-229.3	11.9	-48.2	-28.9
7TH	66.00	-80.6	-32.9	2921	2450	-27.6	-13.4	8	-20	-791.8	-196.5	9.4	-38.2	-27.0
8TH	78.00	-97.7	-24.2	2800	2082	-34.9	-11.6	8	-32	-694.1	-172.2	7.1	-29.3	-23.7
9TH	90.00	-98.4	-25.8	2800	2082	-35.1	-12.4	8	-32	-595.7	-146.4	5.2	-21.6	-20.3
		-99.1	-27.4	2800	2082	-35.4	-13.2	9	-32	-496.5	-119.1	3.6	-15.0	-17.0
10TH	102.00	-101.1	-26.4	2800	2082	-36.1	-12.7	8	-32	-395.5	-92.7	2.4	-9.7	-13.5
11TH	114.00	-103.2	-25.1	2800	2082	-36.9	-12.1	8	-33	-292.3	-67.6	1.4	-5.5	-9.9
12TH	126.00	-104.3	-23.5	2800	2082	-37.2	-11.3	8	-34	-188.0	-44.1	.7	-2.6	-6.1
13TH	138.00	-89.3	-18.4	2800	2082	-31.9	-8.8	7	-35	-98.7	-25.7	.3	-.9	-2.9
14TH	150.00	-74.3	-13.2	2800	2082	-26.5	-6.3	6	-35	-24.4	-12.5	.1	-.2	-.2
MECH	162.00	-24.4	-12.5	2031	1223	-12.0	-10.2	4	-7	0.0	0.0	0.0	0.0	0.0
TOP	177.00													

TABLE 7. TWO LAKEWAY CENTER

PROJECT 6012

SCALE = 300

GUST FACTOR = 1.32

NUMBER OF SIDES = 4

CONFIGURATION A

REF. PRESSURE = 38.0

STANDARD FLOOR HEIGHT = 12.00

NO. OF FLOORS = 21

SIDE	ANGLE	Z-AXIS	SHFACT
1	315.0	2.873	1.0
2	90.0	6.679	1.0
3	180.0	3.017	1.0
4	270.0	2.607	1.0

FLOOR #	LABEL	HEIGHT-FT	WIND AZIMUTH	LOAD FACTOR
1	GRND	9.00	0	.71
2	MEZZ	9.00	10	.77
3	PONT	12.00	20	.83
4	3RD	12.00	30	.89
5	4TH	12.00	40	.96
6	5TH	12.00	50	.98
7	6TH	12.00	60	1.00
8	7TH	12.00	70	1.00
9	8TH	12.00	80	.93
10	9TH	12.00	90	.89
11	10TH	12.00	100	.83
12	11TH	12.00	110	.85
13	12TH	12.00	120	.87
14	13TH	12.00	130	.89
15	14TH	12.00	140	.96
16	15TH	12.00	150	.93
17	16TH	12.00	160	.96
18	17TH	12.00	170	.98
19	18TH	12.00	180	1.00
20	19TH	12.00	190	.96
21	MECH	22.17	200	.89
			210	.85
			220	.81
			230	.75
			240	.71
			250	.66
			260	.64
			270	.66
			280	.66
			290	.66
			300	.68
			310	.68
			320	.68
			330	.83
			340	.83
			350	.83

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00	-34.5	71.4	1649	2872	-20.9	24.9	27	13	-1056.5	1663.3	-170.5	-123.5	176.5
MEZZ	9.00	-37.7	70.6	1687	2921	-22.4	24.2	39	21	-1022.0	1592.0	-155.9	-114.2	174.2
PONT	18.00	-55.3	101.4	2351	4025	-23.5	25.2	53	29	-984.3	1521.4	-141.9	-105.1	170.6
3RD	30.00	-55.3	95.2	2282	3996	-24.2	23.8	57	33	-929.0	1419.9	-124.2	-93.6	163.6
4TH	42.00	-55.4	101.9	2047	3899	-27.0	26.1	73	40	-873.7	1324.7	-107.7	-82.8	156.3
5TH	54.00	-55.6	103.2	1762	3423	-31.6	30.1	74	40	-818.3	1222.8	-92.5	-72.7	146.7
6TH	66.00	-54.6	101.3	1762	3517	-31.0	28.8	79	43	-762.8	1119.6	-78.4	-63.2	136.8
7TH	78.00	-54.9	98.2	1762	3517	-31.2	27.9	82	46	-708.1	1018.3	-65.6	-54.4	126.5
8TH	90.00	-55.3	95.1	1762	3517	-31.4	27.0	84	49	-653.2	920.1	-53.9	-46.2	116.0
9TH	102.00	-55.6	92.3	1762	3517	-31.6	26.2	87	52	-597.9	825.0	-43.5	-38.7	105.2
10TH	114.00	-56.2	92.3	1762	3517	-31.9	26.2	88	53	-542.3	732.7	-34.1	-31.8	94.3
11TH	126.00	-56.7	92.2	1762	3517	-32.2	26.2	89	54	-486.1	640.5	-25.9	-25.7	83.2
12TH	138.00	-57.2	92.2	1762	3517	-32.5	26.2	89	55	-429.4	548.2	-18.8	-20.2	72.0
13TH	150.00	-57.2	91.6	1762	3517	-32.5	26.1	90	56	-372.2	456.0	-12.7	-15.4	60.5
14TH	162.00	-56.7	90.6	1762	3517	-32.2	25.8	90	57	-315.1	364.4	-7.8	-11.3	49.1
15TH	174.00	-56.3	89.5	1762	3517	-31.9	25.5	91	57	-258.3	273.8	-4.0	-7.8	37.7
16TH	186.00	-55.7	88.1	1762	3517	-31.6	25.1	91	58	-202.1	184.3	-1.2	-5.0	26.4
17TH	198.00	-49.5	70.1	1762	3517	-28.1	19.9	87	62	-146.3	96.2	.5	-3.0	15.1
18TH	210.00	-43.4	52.1	1762	3517	-24.6	14.8	81	67	-96.8	26.0	1.2	-1.5	6.0
19TH	222.00	-37.2	34.1	1762	3517	-21.1	9.7	68	74	-53.4	-26.1	1.2	-.6	-1.2
MECH	234.00	-16.2	-60.3	2262	3733	-7.2	-16.1	96	-26	-16.2	-60.3	.7	-.2	-6.2
TOP	256.25									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS : TWO LAKEWAY CENTER														
WIND DIRECTION 10		CONFIGURATION A		REFERENCE PRESSURE 38.0 PSF		GUST FACTOR 1.32								
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	
GRND	0.00									-1219.3	2202.5	-234.9	-145.2	189.5
MEZZ	9.00	-33.7	92.3	1649	2872	-20.4	32.1	29	11	-1185.6	2110.2	-215.5	-134.4	186.5
PONT	18.00	-38.0	90.5	1687	2921	-22.5	31.0	36	15	-1147.6	2019.7	-196.9	-123.9	182.6
3RD	30.00	-60.6	125.4	2351	4025	-25.8	31.1	43	21	-1087.0	1894.3	-173.4	-110.5	176.0
4TH	42.00	-57.8	120.0	2282	3996	-25.3	30.0	50	24	-1029.2	1774.4	-151.4	-97.8	168.7
5TH	54.00	-65.1	130.8	2047	3899	-31.8	33.6	61	30	-964.1	1643.5	-130.9	-85.8	158.7
6TH	66.00	-62.5	127.9	1762	3423	-35.5	37.4	64	31	-901.6	1515.7	-112.0	-74.6	148.6
7TH	78.00	-63.1	128.4	1762	3517	-35.8	36.5	68	33	-838.4	1387.3	-94.6	-64.2	137.8
8TH	90.00	-63.7	124.9	1762	3517	-36.1	35.5	70	36	-774.8	1262.4	-78.7	-54.5	126.7
9TH	102.00	-64.2	121.4	1762	3517	-36.5	34.5	73	39	-710.5	1140.9	-64.2	-45.6	115.4
10TH	114.00	-64.8	118.3	1762	3517	-36.8	33.7	76	41	-645.7	1022.6	-51.3	-37.5	103.7
11TH	126.00	-66.1	119.4	1762	3517	-37.5	33.9	76	42	-579.6	903.2	-39.7	-30.1	91.8
12TH	138.00	-67.3	120.4	1762	3517	-38.2	34.2	77	43	-512.3	782.8	-29.6	-23.6	79.6
13TH	150.00	-68.6	121.4	1762	3517	-38.9	34.5	78	44	-443.7	661.4	-20.9	-17.8	67.1
14TH	162.00	-69.0	121.6	1762	3517	-39.1	34.6	78	44	-374.8	539.8	-13.7	-12.9	54.5
15TH	174.00	-68.7	121.1	1762	3517	-39.0	34.4	79	45	-306.0	418.7	-8.0	-8.8	41.9
16TH	186.00	-68.5	120.6	1762	3517	-38.9	34.3	79	45	-237.5	298.1	-3.7	-5.6	29.4
17TH	198.00	-68.1	119.7	1762	3517	-38.7	34.0	79	45	-169.4	178.4	-.8	-3.1	16.8
18TH	210.00	-60.9	100.8	1762	3517	-34.5	28.7	76	46	-108.6	77.6	.7	-1.5	6.4
19TH	222.00	-53.6	81.9	1762	3517	-30.4	23.3	71	47	-55.0	-4.3	1.2	-.5	-2.0
MECH	234.00	-46.3	63.0	1762	3517	-26.3	17.9	64	47	-8.7	-67.4	.7	-.1	-8.2
TOP	256.25	-8.7	-67.4	2262	3733	-3.8	-18.0	119	-15	0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS : TWO LAKEWAY CENTER
WIND DIRECTION 20 CONFIGURATION A REFERENCE PRESSURE 38.0 PSF

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		GUST FACTOR 1.32		
		X	Y	X	Y	X	Y	X	Y	X	Y	MOMENT (1000-FT-KIPS)	X	Y
GRND	0.00									-1450.8	2355.4	-257.1	-175.0	177.6
MEZZ	9.00	-39.4	95.9	1649	2872	-23.9	33.4	20	8	-1411.4	2259.5	-236.3	-162.1	175.4
PONT	18.00	-44.8	92.4	1687	2921	-26.6	31.6	23	11	-1366.6	2167.0	-216.4	-149.6	172.7
3RD	30.00	-74.0	126.8	2351	4025	-31.5	31.5	28	16	-1292.6	2040.2	-191.1	-133.7	167.9
4TH	42.00	-67.7	121.3	2282	3996	-29.7	30.4	37	21	-1224.9	1918.9	-167.4	-118.6	162.0
5TH	54.00	-76.8	137.2	2047	3899	-37.5	35.2	50	28	-1148.1	1781.7	-145.2	-104.3	153.0
6TH	66.00	-73.0	132.1	1762	3423	-41.4	38.6	53	29	-1075.1	1649.7	-124.6	-91.0	143.9
7TH	78.00	-73.5	131.9	1762	3517	-41.7	37.5	57	32	-1001.6	1517.8	-105.6	-78.5	134.0
8TH	90.00	-74.0	130.7	1762	3517	-42.0	37.2	60	34	-927.7	1387.1	-88.1	-66.9	123.6
9TH	102.00	-74.5	129.5	1762	3517	-42.3	36.8	63	36	-853.2	1257.6	-72.3	-56.3	112.7
10TH	114.00	-75.1	128.4	1762	3517	-42.6	36.5	66	39	-778.1	1129.2	-58.0	-46.5	101.4
11TH	126.00	-76.7	129.7	1762	3517	-43.5	36.9	67	39	-701.4	999.5	-45.2	-37.6	89.7
12TH	138.00	-78.4	131.0	1762	3517	-44.5	37.3	68	40	-623.1	868.4	-34.0	-29.6	77.7
13TH	150.00	-80.0	132.3	1762	3517	-45.4	37.6	68	41	-543.1	736.1	-24.3	-22.7	65.3
14TH	162.00	-80.8	132.3	1762	3517	-45.9	37.6	69	42	-462.3	603.8	-16.3	-16.6	52.9
15TH	174.00	-80.9	131.3	1762	3517	-45.9	37.3	68	42	-381.3	472.6	-9.9	-11.6	40.5
16TH	186.00	-81.1	130.2	1762	3517	-46.0	37.0	68	43	-300.3	342.4	-5.0	-7.5	28.1
17TH	198.00	-81.0	128.8	1762	3517	-46.0	36.6	68	43	-219.2	213.6	-1.6	-4.4	15.9
18TH	210.00	-73.7	110.1	1762	3517	-41.9	31.3	64	43	-145.5	103.4	.3	-2.2	5.7
19TH	222.00	-66.4	91.4	1762	3517	-37.7	26.0	58	42	-79.1	12.0	1.0	-.8	-2.5
MECH	234.00	-59.1	72.8	1762	3517	-33.6	20.7	50	41	-19.9	-60.8	.7	-.2	-8.6
TOP	256.25	-19.9	-60.8	2262	3733	-8.8	-16.3	127	-42	0.0	0.0	0.0	0.0	0.0

WIND DIRECTION 30		CONFIGURATION A		REFERENCE PRESSURE 38.0 PSF		GUST FACTOR 1.32								
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00	-45.5	92.5	1649	2872	-27.6	32.2	9	4	-1693.3	2390.4	-266.8	-203.3	172.7
MEZZ	9.00	-52.7	90.0	1687	2921	-31.2	30.8	12	7	-1647.8	2297.9	-245.7	-188.3	171.7
PONT	18.00	-86.3	127.2	2351	4025	-36.7	31.6	19	13	-1595.1	2207.9	-225.4	-173.7	170.3
3RD	30.00	-77.4	118.7	2282	3996	-33.9	29.7	27	18	-1508.8	2080.7	-199.7	-155.1	166.8
4TH	42.00	-90.9	134.3	2047	3899	-44.4	34.5	40	27	-1431.5	1962.0	-175.4	-137.5	162.2
5TH	54.00	-86.8	127.9	1762	3423	-49.3	37.4	46	31	-1340.6	1827.7	-152.7	-120.8	154.2
6TH	66.00	-88.3	128.9	1762	3517	-50.1	36.7	51	35	-1253.7	1699.8	-131.5	-105.3	145.7
7TH	78.00	-88.7	128.5	1762	3517	-50.3	36.5	54	37	-1165.4	1570.8	-111.9	-90.7	136.1
8TH	90.00	-89.0	128.1	1762	3517	-50.5	36.4	57	40	-1076.8	1442.3	-93.8	-77.3	125.9
9TH	102.00	-89.4	127.9	1762	3517	-50.8	36.4	60	42	-987.7	1314.2	-77.3	-64.9	115.1
10TH	114.00	-90.4	130.2	1762	3517	-51.3	37.0	62	43	-898.3	1186.2	-62.3	-53.6	103.6
11TH	126.00	-91.3	132.5	1762	3517	-51.8	37.7	63	43	-807.9	1056.1	-48.8	-43.4	91.7
12TH	138.00	-92.2	134.7	1762	3517	-52.3	38.3	64	44	-716.6	923.6	-37.0	-34.2	79.4
13TH	150.00	-92.6	136.3	1762	3517	-52.6	38.8	64	44	-624.4	788.9	-26.7	-26.2	66.8
14TH	162.00	-92.7	137.3	1762	3517	-52.6	39.1	64	43	-531.8	652.6	-18.0	-19.2	54.0
15TH	174.00	-92.7	138.4	1762	3517	-52.6	39.3	63	42	-439.1	515.2	-11.0	-13.4	41.2
16TH	186.00	-92.6	139.0	1762	3517	-52.6	39.5	63	42	-346.4	376.8	-5.7	-8.7	28.5
17TH	198.00	-84.6	119.6	1762	3517	-48.0	34.0	58	41	-253.8	237.9	-2.0	-5.1	15.9
18TH	210.00	-76.5	100.3	1762	3517	-43.4	28.5	52	40	-169.2	118.2	.2	-2.5	5.4
19TH	222.00	-68.5	80.9	1762	3517	-38.9	23.0	44	38	-92.7	18.0	1.0	-1.0	-2.9
MECH	234.00	-24.2	-62.9	2262	3733	-10.7	-16.9	126	-48	-24.2	-62.9	.7	-.3	-9.1
TOP	256.25									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS : TWO LAKEWAY CENTER														
WIND DIRECTION 40		CONFIGURATION A				REFERENCE PRESSURE 38.0 PSF						GUST FACTOR 1.32		
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00	-51.1	82.7	1649	2872	-31.0	28.8	-4	-3	-1897.5	2426.5	-278.6	-225.5	173.5
MEZZ	9.00	-61.1	84.2	1687	2921	-36.2	28.8	5	4	-1846.4	2343.7	-257.2	-208.6	174.0
PONT	18.00	-102.5	126.2	2351	4025	-43.6	31.4	15	12	-1785.2	2259.5	-236.5	-192.3	173.3
3RD	30.00	-90.4	116.5	2282	3996	-39.6	29.2	24	19	-1682.7	2133.3	-210.1	-171.5	170.1
4TH	42.00	-102.2	129.5	2047	3899	-49.9	33.2	37	29	-1592.3	2016.8	-185.2	-151.8	165.6
5TH	54.00	-97.4	124.4	1762	3423	-55.3	36.3	44	34	-1490.1	1887.3	-161.8	-133.3	157.9
6TH	66.00	-99.8	128.5	1762	3517	-56.7	36.5	49	38	-1392.7	1762.9	-139.9	-116.1	149.1
7TH	78.00	-100.4	127.5	1762	3517	-57.0	36.3	51	41	-1292.9	1634.4	-119.5	-99.9	139.0
8TH	90.00	-101.0	126.5	1762	3517	-57.3	36.0	54	43	-1192.4	1506.9	-100.6	-85.0	128.4
9TH	102.00	-101.6	126.0	1762	3517	-57.7	35.8	56	45	-1091.4	1380.4	-83.3	-71.3	117.2
10TH	114.00	-101.6	129.9	1762	3517	-57.6	36.9	58	45	-989.9	1254.4	-67.5	-58.8	105.5
11TH	126.00	-101.6	133.8	1762	3517	-57.6	38.0	59	45	-888.3	1124.5	-53.2	-47.6	93.4
12TH	138.00	-101.5	137.7	1762	3517	-57.6	39.2	60	45	-786.7	990.7	-40.5	-37.5	80.9
13TH	150.00	-101.6	141.3	1762	3517	-57.6	40.2	61	44	-685.2	853.0	-29.5	-28.7	68.1
14TH	162.00	-101.6	144.7	1762	3517	-57.6	41.1	60	42	-583.6	711.7	-20.1	-21.1	55.1
15TH	174.00	-101.6	148.0	1762	3517	-57.7	42.1	60	41	-482.1	567.0	-12.4	-14.7	42.0
16TH	186.00	-101.4	150.9	1762	3517	-57.6	42.9	59	40	-380.5	419.0	-6.5	-9.5	29.0
17TH	198.00	-93.1	131.4	1762	3517	-52.8	37.4	55	39	-279.1	268.1	-2.4	-5.5	16.0
18TH	210.00	-84.8	111.9	1762	3517	-48.1	31.8	49	37	-186.0	136.7	.0	-2.8	5.2
19TH	222.00	-76.5	92.4	1762	3517	-43.4	26.3	41	34	-101.2	24.8	1.0	-1.0	-3.4
MECH	234.00	-24.7	-67.6	2262	3733	-10.9	-18.1	127	-46	-24.7	-67.6	.8	-.3	-9.7
TOP	256.25									0.0	0.0	0.0	0.0	0.0

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00	-47.1	72.6	1649	2872	-28.6	25.3	-6	-4	-1915.0	2402.0	-286.8	-231.7	169.3
MEZZ	9.00	-57.7	76.4	1687	2921	-34.2	26.1	7	5	-1867.9	2329.4	-265.5	-214.7	169.9
PONT	18.00	-97.9	112.4	2351	4025	-41.6	27.9	16	14	-1810.2	2253.1	-244.9	-198.1	169.1
3RD	30.00	-87.4	103.8	2282	3996	-38.3	26.0	23	20	-1712.3	2140.7	-218.5	-177.0	166.0
4TH	42.00	-100.6	122.3	2047	3899	-49.2	31.4	37	31	-1624.9	2036.9	-193.4	-156.9	161.9
5TH	54.00	-100.7	123.4	1762	3423	-57.2	36.1	44	36	-1524.3	1914.6	-169.7	-138.0	154.3
6TH	66.00	-101.2	125.0	1762	3517	-57.5	35.5	49	40	-1423.5	1791.2	-147.5	-120.4	145.1
7TH	78.00	-101.3	123.6	1762	3517	-57.5	35.1	51	42	-1322.3	1666.2	-126.8	-103.9	134.9
8TH	90.00	-101.4	122.2	1762	3517	-57.5	34.7	53	44	-1221.0	1542.5	-107.5	-88.6	124.3
9TH	102.00	-101.4	121.3	1762	3517	-57.6	34.5	55	46	-1119.6	1420.3	-89.7	-74.6	113.3
10TH	114.00	-101.4	125.9	1762	3517	-57.6	35.8	56	45	-1018.2	1299.0	-73.4	-61.8	102.0
11TH	126.00	-101.5	130.5	1762	3517	-57.6	37.1	57	44	-916.8	1173.2	-58.6	-50.1	90.4
12TH	138.00	-101.5	135.1	1762	3517	-57.6	38.4	58	43	-815.3	1042.7	-45.3	-39.8	78.5
13TH	150.00	-101.9	140.1	1762	3517	-57.9	39.8	58	42	-713.9	907.6	-33.6	-30.6	66.3
14TH	162.00	-102.8	145.3	1762	3517	-58.3	41.3	57	40	-611.9	767.5	-23.5	-22.6	54.0
15TH	174.00	-103.6	150.6	1762	3517	-58.8	42.8	56	38	-509.2	622.2	-15.2	-15.9	41.6
16TH	186.00	-104.2	155.4	1762	3517	-59.2	44.2	55	37	-405.6	471.6	-8.6	-10.4	29.2
17TH	198.00	-97.1	138.3	1762	3517	-55.1	39.3	50	35	-301.3	316.2	-3.9	-6.2	16.8
18TH	210.00	-90.0	121.2	1762	3517	-51.1	34.5	44	33	-204.2	177.8	-.9	-3.1	6.5
19TH	222.00	-82.9	104.1	1762	3517	-47.1	29.6	37	30	-114.2	56.6	.5	-1.2	-1.9
MECH	234.00	-31.3	-47.4	2262	3733	-13.8	-12.7	121	-80	-31.3	-47.4	.5	-.3	-8.2
TOP	256.25									0.0	0.0	0.0	0.0	0.0

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00	-41.6	74.1	1649	2872	-25.2	25.8	10	5	-1852.3	2340.5	-293.8	-232.8	147.4
MEZZ	9.00	-48.1	71.8	1687	2921	-28.5	24.6	12	8	-1810.7	2266.4	-273.1	-216.3	146.5
PONT	18.00	-84.1	101.5	2351	4025	-36.6	25.2	11	10	-1762.6	2194.5	-253.0	-200.2	145.2
3RD	30.00	-73.4	92.5	2282	3996	-32.2	23.2	19	15	-1676.6	2093.0	-227.3	-179.6	143.2
4TH	42.00	-93.5	108.4	2047	3899	-45.7	27.8	29	25	-1603.1	2000.5	-202.7	-159.9	140.3
5TH	54.00	-93.4	109.1	1762	3423	-53.0	31.9	36	30	-1509.6	1892.0	-179.4	-141.2	134.8
6TH	66.00	-95.1	108.1	1762	3517	-54.0	30.7	41	36	-1416.2	1782.9	-157.3	-123.7	128.1
7TH	78.00	-95.9	107.9	1762	3517	-54.4	30.7	43	38	-1321.1	1674.8	-136.6	-107.2	120.2
8TH	90.00	-96.6	107.7	1762	3517	-54.8	30.6	46	41	-1225.2	1566.9	-117.1	-92.0	111.9
9TH	102.00	-97.3	108.2	1762	3517	-55.3	30.8	48	43	-1128.6	1459.1	-99.0	-77.8	103.0
10TH	114.00	-97.7	115.3	1762	3517	-55.4	32.8	49	42	-1031.2	1351.0	-82.1	-64.9	93.7
11TH	126.00	-98.0	122.5	1762	3517	-55.6	34.8	50	40	-933.6	1235.6	-66.6	-53.1	83.9
12TH	138.00	-98.3	129.7	1762	3517	-55.8	36.9	51	39	-835.6	1113.1	-52.5	-42.5	73.8
13TH	150.00	-99.3	137.2	1762	3517	-56.4	39.0	51	37	-737.3	983.4	-39.9	-33.0	63.4
14TH	162.00	-100.8	144.9	1762	3517	-57.2	41.2	51	36	-638.0	846.2	-28.9	-24.8	52.7
15TH	174.00	-102.3	152.7	1762	3517	-58.1	43.4	51	34	-537.2	701.2	-19.6	-17.7	41.7
16TH	186.00	-103.7	159.9	1762	3517	-58.9	45.5	50	33	-434.9	548.6	-12.1	-11.9	30.5
17TH	198.00	-98.7	145.5	1762	3517	-56.0	41.4	46	31	-331.2	388.7	-6.5	-7.3	19.1
18TH	210.00	-93.6	131.0	1762	3517	-53.1	37.3	41	29	-232.5	243.2	-2.7	-3.9	9.3
19TH	222.00	-88.6	116.6	1762	3517	-50.3	33.2	35	26	-138.9	112.1	-.6	-1.7	1.3
MECH	234.00	-50.3	-4.5	2262	3733	-22.2	-1.2	9	-101	-50.3	-4.5	.0	-.6	-5.1
TOP	256.25									0.0	0.0	0.0	0.0	0.0

WIND DIRECTION 70		CONFIGURATION A		REFERENCE PRESSURE 38.0 PSF		GUST FACTOR 1.32								
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00	-34.8	63.0	1649	2872	-21.1	21.9	13	7	-1688.1	2084.1	-272.1	-218.7	109.6
MEZZ	9.00	-37.7	58.8	1687	2921	-22.3	20.1	8	5	-1653.3	2021.0	-253.6	-203.7	108.5
PONT	18.00	-72.2	82.3	2351	4025	-30.7	20.5	2	2	-1615.6	1962.2	-235.7	-189.0	107.9
3RD	30.00	-59.4	76.1	2282	3996	-26.0	19.0	11	9	-1543.5	1879.9	-212.7	-170.0	107.5
4TH	42.00	-84.2	89.9	2047	3899	-41.1	23.1	17	16	-1484.1	1803.9	-190.6	-151.9	106.1
5TH	54.00	-82.5	89.7	1762	3423	-46.8	26.2	23	22	-1399.9	1713.9	-169.5	-134.6	103.3
6TH	66.00	-82.7	89.6	1762	3517	-46.9	25.5	30	28	-1317.4	1624.2	-149.4	-118.3	99.4
7TH	78.00	-83.4	89.0	1762	3517	-47.4	25.3	33	31	-1234.7	1534.6	-130.5	-102.9	94.5
8TH	90.00	-84.2	88.4	1762	3517	-47.8	25.1	36	34	-1151.3	1445.6	-112.6	-88.6	89.0
9TH	102.00	-85.1	88.7	1762	3517	-48.3	25.2	38	37	-1067.1	1357.2	-95.8	-75.3	83.0
10TH	114.00	-87.3	98.1	1762	3517	-49.6	27.9	40	36	-982.0	1268.5	-80.0	-63.0	76.5
11TH	126.00	-89.5	107.5	1762	3517	-50.8	30.6	42	35	-894.7	1170.4	-65.4	-51.8	69.4
12TH	138.00	-91.8	116.9	1762	3517	-52.1	33.2	44	34	-805.2	1062.9	-52.0	-41.6	61.7
13TH	150.00	-93.8	125.6	1762	3517	-53.2	35.7	44	33	-713.4	946.0	-39.9	-32.5	53.5
14TH	162.00	-95.6	133.7	1762	3517	-54.3	38.0	45	32	-619.7	820.5	-29.3	-24.5	44.8
15TH	174.00	-97.4	141.8	1762	3517	-55.3	40.3	45	31	-524.1	686.8	-20.3	-17.6	35.8
16TH	186.00	-99.1	149.6	1762	3517	-56.3	42.5	45	30	-426.6	544.9	-12.9	-11.9	26.4
17TH	198.00	-95.2	138.3	1762	3517	-54.0	39.3	41	28	-327.5	395.3	-7.3	-7.4	16.8
18TH	210.00	-91.3	127.1	1762	3517	-51.8	36.1	36	26	-232.3	257.0	-3.3	-4.0	8.5
19TH	222.00	-87.4	115.8	1762	3517	-49.6	32.9	31	23	-141.0	130.0	-1.0	-1.8	1.5
MECH	234.00	-53.7	14.2	2262	3733	-23.7	3.8	-19	-72	-53.7	14.2	-.2	-.6	-4.1
TOP	256.25									0.0	0.0	0.0	0.0	0.0

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									-1368.8	1567.8	-206.3	-179.1	82.0
MEZZ	9.00	-26.2	48.2	1649	2872	-15.9	16.8	12	7	-1342.6	1519.5	-192.5	-166.9	81.3
PONT	18.00	-28.9	44.1	1687	2921	-17.1	15.1	6	4	-1313.7	1475.4	-179.0	-154.9	80.9
3RD	30.00	-59.8	63.7	2351	4025	-25.4	15.8	2	2	-1254.0	1411.7	-161.7	-139.5	80.6
4TH	42.00	-50.2	54.9	2282	3996	-22.0	13.7	8	8	-1203.8	1356.8	-145.0	-124.8	79.8
5TH	54.00	-69.3	73.5	2047	3899	-33.9	18.8	17	16	-1134.5	1283.3	-129.2	-110.8	77.5
6TH	66.00	-68.8	71.7	1762	3423	-39.0	20.9	21	20	-1065.7	1211.6	-114.2	-97.5	74.6
7TH	78.00	-67.5	72.5	1762	3517	-38.3	20.6	27	25	-998.1	1139.1	-100.1	-85.2	70.9
8TH	90.00	-66.6	68.6	1762	3517	-37.8	19.5	29	28	-931.6	1070.5	-86.9	-73.6	67.1
9TH	102.00	-65.6	64.7	1762	3517	-37.2	18.4	31	32	-866.0	1005.8	-74.4	-62.8	62.9
10TH	114.00	-64.9	61.7	1762	3517	-36.8	17.5	34	35	-801.1	944.2	-62.7	-52.8	58.6
11TH	126.00	-66.9	67.4	1762	3517	-38.0	19.2	36	36	-734.2	876.8	-51.8	-43.6	53.7
12TH	138.00	-68.9	73.2	1762	3517	-39.1	20.8	39	36	-665.3	803.6	-41.7	-35.2	48.4
13TH	150.00	-70.9	78.9	1762	3517	-40.2	22.4	41	36	-594.4	724.7	-32.5	-27.6	42.6
14TH	162.00	-73.6	86.1	1762	3517	-41.8	24.5	42	36	-520.9	638.6	-24.4	-20.9	36.4
15TH	174.00	-76.8	94.6	1762	3517	-43.6	26.9	43	35	-444.1	544.0	-17.3	-15.2	29.6
16TH	186.00	-80.0	103.0	1762	3517	-45.4	29.3	44	34	-364.1	441.0	-11.3	-10.3	22.4
17TH	198.00	-83.1	111.1	1762	3517	-47.2	31.6	44	33	-281.0	330.0	-6.7	-6.4	14.7
18TH	210.00	-80.1	105.2	1762	3517	-45.5	29.9	41	31	-200.9	224.7	-3.4	-3.5	7.9
19TH	222.00	-77.2	99.4	1762	3517	-43.8	28.3	37	28	-123.8	125.3	-1.3	-1.6	2.1
MECH	234.00	-74.2	93.6	1762	3517	-42.1	26.6	32	25	-49.6	31.7	-.4	-.6	-2.8
TOP	256.25	-49.6	31.7	2262	3733	-21.9	8.5	-26	-40	0.0	0.0	0.0	0.0	0.0

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00													
MEZZ	9.00	-17.2	27.9	1649	2872	-10.5	9.7	0	0	-944.7	821.0	-108.7	-124.0	41.0
PONT	18.00	-18.3	24.4	1687	2921	-10.9	8.4	-8	-6	-927.5	793.1	-101.4	-115.6	41.0
3RD	30.00	-41.1	35.1	2351	4025	-17.5	8.7	-8	-10	-909.2	768.7	-94.4	-107.3	41.4
4TH	42.00	-34.5	24.3	2282	3996	-15.1	6.1	-4	-6	-868.1	733.6	-85.4	-96.7	42.0
5TH	54.00	-46.0	32.8	2047	3899	-22.5	8.4	8	11	-833.6	709.3	-76.7	-86.5	42.3
6TH	66.00	-47.5	35.9	1762	3423	-26.9	10.5	11	15	-787.5	676.5	-68.4	-76.7	41.5
7TH	78.00	-47.0	38.2	1762	3517	-26.7	10.9	17	21	-740.1	640.6	-60.5	-67.6	40.4
8TH	90.00	-46.5	35.9	1762	3517	-26.4	10.2	19	25	-693.1	602.4	-53.1	-59.0	38.8
9TH	102.00	-46.0	33.5	1762	3517	-26.1	9.5	22	30	-646.6	566.6	-46.1	-50.9	37.0
10TH	114.00	-45.6	31.7	1762	3517	-25.9	9.0	24	35	-600.6	533.0	-39.5	-43.4	34.9
11TH	126.00	-47.0	35.4	1762	3517	-26.7	10.1	28	37	-555.0	501.3	-33.2	-36.5	32.5
12TH	138.00	-48.4	39.1	1762	3517	-27.5	11.1	31	39	-508.0	465.9	-27.4	-30.1	29.8
13TH	150.00	-49.8	42.7	1762	3517	-28.3	12.2	34	40	-459.5	426.8	-22.1	-24.3	26.7
14TH	162.00	-51.4	46.5	1762	3517	-29.2	13.2	36	40	-409.7	384.1	-17.2	-19.1	23.2
15TH	174.00	-53.0	50.3	1762	3517	-30.1	14.3	38	40	-358.3	337.6	-12.9	-14.5	19.5
16TH	186.00	-54.6	54.1	1762	3517	-31.0	15.4	39	39	-305.3	287.3	-9.1	-10.5	15.5
17TH	198.00	-56.2	57.7	1762	3517	-31.9	16.4	40	39	-250.7	233.2	-6.0	-7.2	11.2
18TH	210.00	-54.5	55.5	1762	3517	-30.9	15.8	35	34	-194.5	175.5	-3.6	-4.5	6.7
19TH	222.00	-52.8	53.2	1762	3517	-30.0	15.1	30	29	-140.0	120.0	-1.8	-2.5	2.9
MECH	234.00	-51.1	50.9	1762	3517	-29.0	14.5	24	24	-87.2	66.9	-.7	-1.1	-.2
TOP	256.25	-36.1	16.0	2262	3733	-15.9	4.3	-27	-61	-36.1	16.0	-.2	-.4	-2.7
										0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS : TWO LAKEWAY CENTER														
WIND DIRECTION 100 CONFIGURATION A REFERENCE PRESSURE 38.0 PSF GUST FACTOR 1.32														
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00													
		-6.5	9.7	1649	2872	-3.9	3.4	-51	-34	-466.4	247.4	-35.1	-64.2	-17.1
MEZZ	9.00													
		-7.3	8.8	1687	2921	-4.3	3.0	-40	-33	-459.9	237.7	-32.9	-60.0	-16.4
PONT	18.00													
		-15.8	10.8	2351	4025	-6.7	2.7	-28	-42	-452.6	228.9	-30.8	-55.9	-15.8
3RD	30.00													
		-13.7	5.1	2282	3996	-6.0	1.3	-18	-50	-436.8	218.1	-28.1	-50.5	-14.8
4TH	42.00													
		-20.5	8.9	2047	3899	-10.0	2.3	-9	-21	-423.1	213.0	-25.5	-45.4	-14.1
5TH	54.00													
		-23.9	9.6	1762	3423	-13.6	2.8	-10	-25	-402.5	204.1	-23.0	-40.4	-13.5
6TH	66.00													
		-22.8	10.4	1762	3517	-12.9	3.0	-11	-24	-378.6	194.5	-20.6	-35.7	-12.8
7TH	78.00													
		-22.9	9.2	1762	3517	-13.0	2.6	-11	-26	-355.9	184.1	-18.3	-31.3	-12.2
8TH	90.00													
		-23.1	8.0	1762	3517	-13.1	2.3	-10	-28	-333.0	174.8	-16.2	-27.2	-11.5
9TH	102.00													
		-23.3	7.0	1762	3517	-13.2	2.0	-9	-30	-309.9	166.8	-14.1	-23.3	-10.7
10TH	114.00													
		-23.5	7.5	1762	3517	-13.3	2.1	-10	-30	-286.6	159.8	-12.2	-19.8	-10.0
11TH	126.00													
		-23.7	8.0	1762	3517	-13.4	2.3	-10	-30	-263.1	152.3	-10.3	-16.5	-9.2
12TH	138.00													
		-23.9	8.5	1762	3517	-13.6	2.4	-11	-30	-239.4	144.3	-8.5	-13.5	-8.4
13TH	150.00													
		-24.5	10.5	1762	3517	-13.9	3.0	-12	-27	-215.5	135.8	-6.8	-10.7	-7.6
14TH	162.00													
		-25.4	13.6	1762	3517	-14.4	3.9	-12	-23	-191.0	125.3	-5.3	-8.3	-6.8
15TH	174.00													
		-26.4	16.7	1762	3517	-15.0	4.7	-12	-20	-165.6	111.7	-3.9	-6.1	-6.0
16TH	186.00													
		-27.3	19.7	1762	3517	-15.5	5.6	-12	-17	-139.2	95.0	-2.6	-4.3	-5.3
17TH	198.00													
		-27.8	21.2	1762	3517	-15.8	6.0	-12	-16	-111.9	75.3	-1.6	-2.8	-4.6
18TH	210.00													
		-28.3	22.8	1762	3517	-16.1	6.5	-13	-16	-84.1	54.1	-.8	-1.6	-3.9
19TH	222.00													
		-28.8	24.3	1762	3517	-16.3	6.9	-13	-15	-55.8	31.3	-.3	-.8	-3.2
MECH	234.00													
		-27.0	7.0	2262	3733	-12.0	1.9	-22	-84	-27.0	7.0	-.1	-.3	-2.4
TOP	256.25									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS : TWO LAKEWAY CENTER													
WIND DIRECTION 110		CONFIGURATION A				REFERENCE PRESSURE 38.0 PSF				GUST FACTOR 1.32			
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)	
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y
GRND	0.00									-132.5	-81.2	1.3	-18.8
MEZZ	9.00	-3.5	-4.9	1649	2872	-2.1	-1.7	233	-166	-129.0	-76.3	.6	-17.7
PONT	18.00	-3.7	-5.1	1687	2921	-2.2	-1.7	211	-155	-125.3	-71.2	-.1	-16.5
3RD	30.00	-7.9	-10.7	2351	4025	-3.4	-2.7	147	-109	-117.3	-60.5	-.9	-15.1
4TH	42.00	-6.8	-16.8	2282	3996	-3.0	-4.2	123	-50	-110.6	-43.7	-1.5	-13.7
5TH	54.00	-2.5	-14.9	2047	3899	-1.2	-3.8	136	-22	-108.1	-28.8	-1.9	-12.4
6TH	66.00	-6.0	-8.3	1762	3423	-3.4	-2.4	138	-114	-102.1	-20.5	-2.2	-11.1
7TH	78.00	-5.1	-7.4	1762	3517	-2.9	-2.1	184	-127	-97.0	-13.1	-2.4	-9.9
8TH	90.00	-5.2	-7.7	1762	3517	-3.0	-2.2	192	-131	-91.8	-5.4	-2.5	-8.8
9TH	102.00	-5.3	-8.0	1762	3517	-3.0	-2.3	200	-134	-86.4	2.6	-2.5	-7.7
10TH	114.00	-5.4	-8.1	1762	3517	-3.1	-2.3	208	-139	-81.0	10.7	-2.5	-6.7
11TH	126.00	-5.1	-7.2	1762	3517	-2.9	-2.0	223	-159	-75.9	17.9	-2.3	-5.8
12TH	138.00	-4.8	-6.2	1762	3517	-2.7	-1.8	239	-185	-71.1	24.1	-2.0	-4.9
13TH	150.00	-4.5	-5.3	1762	3517	-2.6	-1.5	257	-219	-66.6	29.4	-1.7	-4.1
14TH	162.00	-4.6	-3.1	1762	3517	-2.6	-.9	229	-335	-62.0	32.5	-1.3	-3.3
15TH	174.00	-4.9	-.0	1762	3517	-2.8	-.0	3	-427	-57.1	32.5	-1.0	-2.6
16TH	186.00	-5.3	3.0	1762	3517	-3.0	.9	-160	-277	-51.8	29.5	-.6	-1.9
17TH	198.00	-5.7	6.1	1762	3517	-3.2	1.7	-159	-147	-46.2	23.4	-.3	-1.3
18TH	210.00	-8.0	8.1	1762	3517	-4.5	2.3	-108	-107	-38.2	15.3	-.0	-.8
19TH	222.00	-10.3	10.1	1762	3517	-5.8	2.9	-80	-82	-27.9	5.2	.1	-.4
MECH	234.00	-12.6	12.1	1762	3517	-7.2	3.4	-62	-65	-15.3	-6.8	.1	-.2
TOP	256.25	-15.3	-6.8	2262	3733	-6.8	-1.8	76	-169	0.0	0.0	0.0	0.0

		CONFIGURATION A				TWO LAKEWAY CENTER				REFERENCE PRESSURE 38.0 PSF		GUST FACTOR 1.32		
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									22.9	-267.2	21.9	3.9	-52.1
MEZZ	9.00	-2.5	-13.9	1649	2872	-1.5	-4.9	152	-27	25.4	-253.2	19.5	3.6	-49.9
PONT	18.00	-1.0	-14.5	1687	2921	-.6	-5.0	150	-10	26.4	-238.7	17.3	3.4	-47.7
3RD	30.00	-2.3	-24.4	2351	4025	-1.0	-6.1	125	-12	28.7	-214.3	14.6	3.1	-44.6
4TH	42.00	-3.3	-29.3	2282	3996	-1.5	-7.3	109	-12	32.0	-185.0	12.2	2.7	-41.4
5TH	54.00	3.3	-25.5	2047	3899	1.6	-6.5	107	14	28.7	-159.6	10.1	2.3	-38.6
6TH	66.00	.6	-16.9	1762	3423	.3	-4.9	167	6	28.2	-142.7	8.3	2.0	-35.8
7TH	78.00	.9	-14.9	1762	3517	.5	-4.2	174	11	27.3	-127.8	6.7	1.7	-33.2
8TH	90.00	1.1	-15.8	1762	3517	.6	-4.5	169	12	26.2	-112.1	5.2	1.4	-30.5
9TH	102.00	1.3	-16.7	1762	3517	.7	-4.7	164	13	24.9	-95.4	4.0	1.0	-27.8
10TH	114.00	1.5	-17.4	1762	3517	.9	-4.9	161	14	23.4	-78.0	3.0	.8	-25.0
11TH	126.00	2.2	-16.3	1762	3517	1.2	-4.6	166	22	21.2	-61.7	2.1	.5	-22.2
12TH	138.00	2.9	-15.1	1762	3517	1.6	-4.3	170	32	18.3	-46.6	1.5	.3	-19.5
13TH	150.00	3.5	-14.0	1762	3517	2.0	-4.0	174	44	14.8	-32.6	1.0	.1	-17.0
14TH	162.00	4.0	-11.8	1762	3517	2.3	-3.3	187	64	10.7	-20.9	.7	-.1	-14.5
15TH	174.00	4.4	-8.7	1762	3517	2.5	-2.5	209	105	6.4	-12.2	.5	-.2	-12.2
16TH	186.00	4.7	-5.6	1762	3517	2.7	-1.6	219	182	1.7	-6.6	.4	-.2	-10.1
17TH	198.00	5.0	-2.6	1762	3517	2.8	-.7	158	303	-3.3	-4.0	.3	-.2	-8.2
18TH	210.00	2.7	-.3	1762	3517	1.5	-.1	82	684	-5.9	-3.6	.3	-.2	-6.4
19TH	222.00	.4	2.0	1762	3517	.2	.6	-882	167	-6.3	-5.6	.2	-.1	-4.6
MECH	234.00	-1.9	4.2	1762	3517	-1.1	1.2	-337	-153	-4.4	-9.8	.1	-.0	-2.9
TOP	256.25	-4.4	-9.8	2262	3733	-1.9	-2.6	246	-109	0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS : WIND DIRECTION 130		CONFIGURATION A		TWO LAKEWAY CENTER		REFERENCE PRESSURE 38.0 PSF		GUST FACTOR 1.32						
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									248.4	-314.3	31.9	36.9	-43.0
MEZZ	9.00	-.8	-15.6	1649	2872	-.5	-5.4	143	-7	249.2	-298.8	29.1	34.7	-40.7
PONT	18.00	-.3	-14.6	1687	2921	-.2	-5.0	146	-3	249.5	-284.1	26.5	32.4	-38.6
3RD	30.00	-1.1	-22.1	2351	4025	-.5	-5.5	123	-6	250.6	-262.0	23.2	29.4	-35.9
4TH	42.00	-2.7	-24.1	2282	3996	-1.2	-6.0	123	-14	253.3	-238.0	20.2	26.4	-32.9
5TH	54.00	12.1	-18.7	2047	3899	5.9	-4.8	84	54	253.3	-238.0	20.2	26.4	-32.9
5TH	54.00	12.1	-12.4	1762	3423	6.9	-3.6	86	83	241.3	-219.2	17.5	23.4	-30.6
6TH	66.00	12.8	-14.0	1762	3517	7.3	-4.0	83	76	229.2	-206.8	14.9	20.6	-28.6
7TH	78.00	11.8	-16.1	1762	3517	6.7	-4.6	88	65	216.4	-192.8	12.5	17.9	-26.4
8TH	90.00	10.9	-18.1	1762	3517	6.2	-5.1	90	54	204.6	-176.7	10.3	15.4	-24.3
9TH	102.00	10.2	-19.9	1762	3517	5.8	-5.7	89	46	193.7	-158.7	8.3	13.0	-22.0
10TH	114.00	10.2	-19.9	1762	3517	5.8	-5.7	89	46	183.4	-138.8	6.5	10.8	-19.8
11TH	126.00	13.1	-19.8	1762	3517	7.5	-5.6	75	50	170.3	-118.9	5.0	8.6	-17.6
12TH	138.00	16.0	-19.8	1762	3517	9.1	-5.6	62	50	154.3	-99.1	3.7	6.7	-15.6
13TH	150.00	18.9	-19.7	1762	3517	10.7	-5.6	51	49	135.4	-79.4	2.6	4.9	-13.7
14TH	162.00	20.9	-18.4	1762	3517	11.8	-5.2	43	49	114.5	-61.1	1.7	3.4	-11.9
15TH	174.00	22.1	-16.0	1762	3517	12.5	-4.6	36	50	92.5	-45.0	1.1	2.2	-10.2
16TH	186.00	23.3	-13.7	1762	3517	13.2	-3.9	29	50	69.2	-31.3	.6	1.2	-8.6
17TH	198.00	24.4	-11.4	1762	3517	13.9	-3.2	23	48	44.7	-19.9	.3	.6	-7.2
18TH	210.00	20.6	-8.8	1762	3517	11.7	-2.5	26	61	24.2	-11.2	.2	.1	-5.7
19TH	222.00	16.8	-6.1	1762	3517	9.5	-1.7	30	81	7.4	-5.1	.1	-.1	-4.2
MECH	234.00	12.9	-3.5	1762	3517	7.3	-1.0	31	114	-5.6	-1.5	.0	-.1	-2.6
TOP	256.25	-5.6	-1.5	2262	3733	-2.5	-.4	119	-433	0.0	0.0	0.0	0.0	0.0

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									445.0	-356.4	47.4	69.0	-41.3
MEZZ	9.00	-1.8	-13.0	1649	2872	-1.5	-4.5	165	-10	445.8	-343.4	44.3	65.0	-39.2
PONT	18.00	-1.9	-10.0	1687	2921	-1.5	-3.4	206	-18	446.6	-333.4	41.2	60.9	-37.1
3RD	30.00	-2.7	-13.1	2351	4025	-1.1	-3.3	191	-39	449.3	-320.2	37.3	55.6	-34.5
4TH	42.00	-3.4	-15.0	2282	3996	-1.5	-3.8	184	-42	452.7	-305.2	33.6	50.2	-31.6
5TH	54.00	16.3	-13.1	2047	3899	7.9	-3.3	68	85	436.5	-292.2	30.0	44.8	-29.3
6TH	66.00	17.0	-8.3	1762	3423	9.7	-2.4	42	85	419.4	-283.8	26.5	39.7	-27.5
7TH	78.00	20.2	-11.0	1762	3517	11.5	-3.1	39	72	399.2	-272.8	23.2	34.8	-25.6
8TH	90.00	19.4	-13.5	1762	3517	11.0	-3.8	47	68	379.9	-259.3	20.0	30.1	-23.7
9TH	102.00	18.5	-16.0	1762	3517	10.5	-4.5	54	62	361.4	-243.3	17.0	25.6	-21.7
10TH	114.00	18.1	-18.4	1762	3517	10.3	-5.2	57	56	343.3	-224.9	14.2	21.4	-19.6
11TH	126.00	22.5	-19.7	1762	3517	12.8	-5.6	42	48	320.8	-205.2	11.6	17.4	-17.7
12TH	138.00	26.9	-21.0	1762	3517	15.3	-6.0	32	41	293.9	-184.2	9.2	13.7	-15.9
13TH	150.00	31.3	-22.3	1762	3517	17.8	-6.3	25	35	262.6	-161.9	7.2	10.4	-14.3
14TH	162.00	35.2	-22.8	1762	3517	20.0	-6.5	20	31	227.4	-139.1	5.4	7.5	-12.7
15TH	174.00	38.8	-22.6	1762	3517	22.0	-6.4	16	28	188.6	-116.5	3.8	5.0	-11.3
16TH	186.00	42.4	-22.4	1762	3517	24.0	-6.4	13	24	146.2	-94.1	2.6	3.0	-10.0
17TH	198.00	45.8	-22.2	1762	3517	26.0	-6.3	11	22	100.5	-71.9	1.6	1.5	-8.8
18TH	210.00	40.8	-21.4	1762	3517	23.2	-6.1	14	27	59.7	-50.4	.8	.5	-7.3
19TH	222.00	35.8	-20.6	1762	3517	20.3	-5.9	19	33	23.8	-29.8	.3	.0	-5.8
MECH	234.00	30.9	-19.8	1762	3517	17.5	-5.6	26	40	-7.1	-10.0	.1	-.1	-4.0
TOP	256.25	-7.1	-10.0	2262	3733	-3.1	-2.7	267	-190	0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS : TWO LAKEWAY CENTER														
WIND DIRECTION 150		CONFIGURATION A				REFERENCE PRESSURE 38.0 PSF				GUST FACTOR 1.32				
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									886.9	-808.5	113.6	124.6	-54.6
MEZZ	9.00	7.6	-16.9	1649	2872	4.6	-5.9	100	45	879.3	-791.6	106.4	116.6	-52.6
PONT	18.00	5.5	-16.5	1687	2921	3.2	-5.7	123	41	873.8	-775.1	99.4	108.8	-50.3
3RD	30.00	4.5	-24.6	2351	4025	1.9	-6.1	127	23	869.3	-750.5	90.2	98.3	-47.1
4TH	42.00	5.2	-32.6	2282	3996	2.3	-8.1	112	18	864.1	-717.9	81.4	87.9	-43.3
5TH	54.00	36.3	-32.6	2047	3899	17.8	-8.4	41	46	827.7	-685.3	73.0	77.8	-40.3
6TH	66.00	35.3	-25.6	1762	3423	20.0	-7.5	27	37	792.4	-659.7	64.9	68.0	-38.4
7TH	78.00	45.3	-28.1	1762	3517	25.7	-8.0	19	31	747.1	-631.5	57.2	58.8	-36.4
8TH	90.00	48.1	-30.9	1762	3517	27.3	-8.8	19	29	699.0	-600.7	49.8	50.1	-34.5
9TH	102.00	50.9	-33.6	1762	3517	28.9	-9.6	18	28	648.1	-567.1	42.8	42.0	-32.4
10TH	114.00	53.7	-36.4	1762	3517	30.5	-10.3	18	26	594.4	-530.7	36.2	34.6	-30.4
11TH	126.00	56.4	-39.9	1762	3517	32.0	-11.3	18	25	538.1	-490.8	30.1	27.8	-28.2
12TH	138.00	59.0	-43.4	1762	3517	33.5	-12.3	17	24	479.1	-447.5	24.4	21.7	-26.1
13TH	150.00	61.7	-46.9	1762	3517	35.0	-13.3	17	22	417.4	-400.6	19.4	16.3	-23.9
14TH	162.00	63.6	-48.9	1762	3517	36.1	-13.9	17	22	353.8	-351.7	14.8	11.7	-21.7
15TH	174.00	65.1	-49.9	1762	3517	36.9	-14.2	17	22	288.7	-301.9	10.9	7.8	-19.5
16TH	186.00	66.5	-50.8	1762	3517	37.7	-14.4	17	22	222.2	-251.0	7.6	4.8	-17.2
17TH	198.00	67.7	-51.7	1762	3517	38.4	-14.7	17	22	154.5	-199.3	4.9	2.5	-14.8
18TH	210.00	60.2	-51.5	1762	3517	34.2	-14.7	22	26	94.3	-147.8	2.8	1.0	-12.1
19TH	222.00	52.7	-51.3	1762	3517	29.9	-14.6	29	30	41.5	-96.4	1.4	.2	-9.0
MECH	234.00	45.3	-51.2	1762	3517	25.7	-14.5	38	33	-3.7	-45.3	.5	-.0	-5.6
TOP	256.25	-3.7	-45.3	2262	3733	-1.7	-12.1	123	-10	0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS : TWO LAKEWAY CENTER														
WIND DIRECTION 160		CONFIGURATION A		REFERENCE PRESSURE 38.0 PSF		GUST FACTOR 1.32								
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00	13.0	-15.7	1649	2872	7.9	-5.5	98	81	905.6	-614.7	86.3	124.6	-62.7
MEZZ	9.00	11.1	-14.0	1687	2921	6.6	-4.8	121	96	892.6	-599.0	80.8	116.5	-60.1
PONT	18.00	10.9	-19.2	2351	4025	4.7	-4.8	151	86	881.5	-585.0	75.5	108.5	-57.3
3RD	30.00	8.5	-23.9	2282	3996	3.7	-6.0	155	55	870.5	-565.8	68.6	98.0	-53.5
4TH	42.00	37.3	-24.5	2047	3899	18.2	-6.3	43	66	862.1	-541.9	61.9	87.6	-49.3
5TH	54.00	35.6	-19.5	1762	3423	20.2	-5.7	30	55	824.8	-517.4	55.6	77.5	-45.8
6TH	66.00	46.3	-22.8	1762	3517	26.3	-6.5	22	45	789.2	-497.9	49.5	67.8	-43.2
7TH	78.00	47.9	-24.2	1762	3517	27.2	-6.9	21	42	742.9	-475.1	43.7	58.6	-40.7
8TH	90.00	49.6	-25.5	1762	3517	28.1	-7.2	20	39	695.0	-450.9	38.1	50.0	-38.1
9TH	102.00	51.4	-26.9	1762	3517	29.2	-7.6	19	37	645.4	-425.4	32.8	41.9	-35.7
10TH	114.00	54.6	-29.1	1762	3517	31.0	-8.3	19	35	594.0	-398.5	27.9	34.5	-33.2
11TH	126.00	57.8	-31.3	1762	3517	32.8	-8.9	18	33	539.5	-369.4	23.3	27.7	-30.8
12TH	138.00	61.0	-33.5	1762	3517	34.6	-9.5	17	31	481.7	-338.2	19.0	21.6	-28.3
13TH	150.00	63.7	-35.1	1762	3517	36.2	-10.0	17	30	420.7	-304.7	15.2	16.2	-25.9
14TH	162.00	66.0	-36.2	1762	3517	37.5	-10.3	16	30	357.0	-269.6	11.7	11.5	-23.3
15TH	174.00	68.4	-37.4	1762	3517	38.8	-10.6	16	29	290.9	-233.4	8.7	7.6	-20.8
16TH	186.00	70.5	-38.5	1762	3517	40.0	-11.0	16	28	222.6	-196.0	6.1	4.5	-18.2
17TH	198.00	62.1	-38.7	1762	3517	35.2	-11.0	21	33	152.1	-157.5	4.0	2.3	-15.6
18TH	210.00	53.6	-38.9	1762	3517	30.4	-11.1	28	39	90.0	-118.7	2.4	.8	-12.8
19TH	222.00	45.2	-39.1	1762	3517	25.7	-11.1	38	44	36.4	-79.8	1.2	.1	-9.6
MECH	234.00	-8.8	-40.7	2262	3733	-3.9	-10.9	144	-31	-8.8	-40.7	.5	-.1	-6.1
TOP	256.25									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS : TWO LAKEWAY CENTER														
WIND DIRECTION 170		CONFIGURATION A				REFERENCE PRESSURE 38.0 PSF						BUST FACTOR 1.32		
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									946.4	-289.3	45.0	129.0	-59.8
MEZZ	9.00	15.6	-9.8	1649	2872	9.4	-3.4	78	125	930.9	-279.5	42.4	120.5	-57.1
PONT	18.00	14.3	-4.3	1687	2921	8.5	-1.5	55	183	916.6	-275.2	39.9	112.2	-54.3
3RD	30.00	13.5	-3.9	2351	4025	5.7	-1.0	80	279	916.6	-275.2	39.9	112.2	-54.3
		11.5	-10.3	2282	3996	5.7	-1.0	80	279	903.0	-271.3	36.7	101.3	-50.2
4TH	42.00	11.5	-10.3	2282	3996	5.1	-2.6	193	216	903.0	-271.3	36.7	101.3	-50.2
		40.3	-11.3	2047	3899	19.7	-2.9	23	82	891.5	-261.0	33.5	90.5	-45.7
5TH	54.00	40.3	-11.3	2047	3899	19.7	-2.9	23	82	891.5	-261.0	33.5	90.5	-45.7
		36.5	-3.5	1762	3423	20.7	-1.0	7	71	851.2	-249.7	30.4	80.1	-42.1
6TH	66.00	36.5	-3.5	1762	3423	20.7	-1.0	7	71	851.2	-249.7	30.4	80.1	-42.1
		46.1	-6.2	1762	3517	26.2	-1.8	7	53	814.7	-246.2	27.4	70.1	-39.5
7TH	78.00	46.1	-6.2	1762	3517	26.2	-1.8	7	53	814.7	-246.2	27.4	70.1	-39.5
		48.3	-7.5	1762	3517	27.4	-2.1	8	49	768.6	-240.0	24.5	60.6	-37.0
8TH	90.00	48.3	-7.5	1762	3517	27.4	-2.1	8	49	768.6	-240.0	24.5	60.6	-37.0
		50.4	-8.8	1762	3517	28.6	-2.5	8	45	720.3	-232.5	21.7	51.6	-34.6
9TH	102.00	50.4	-8.8	1762	3517	28.6	-2.5	8	45	720.3	-232.5	21.7	51.6	-34.6
		52.7	-10.2	1762	3517	29.9	-2.9	8	42	669.9	-223.7	18.9	43.3	-32.2
10TH	114.00	52.7	-10.2	1762	3517	29.9	-2.9	8	42	669.9	-223.7	18.9	43.3	-32.2
		56.5	-12.0	1762	3517	32.1	-3.4	8	37	617.3	-213.5	16.3	35.6	-30.0
11TH	126.00	56.5	-12.0	1762	3517	32.1	-3.4	8	37	617.3	-213.5	16.3	35.6	-30.0
		60.4	-13.8	1762	3517	34.3	-3.9	7	33	560.7	-201.5	13.8	28.5	-27.8
12TH	138.00	60.4	-13.8	1762	3517	34.3	-3.9	7	33	560.7	-201.5	13.8	28.5	-27.8
		64.3	-15.5	1762	3517	36.5	-4.4	7	29	500.3	-187.7	11.5	22.1	-25.7
13TH	150.00	64.3	-15.5	1762	3517	36.5	-4.4	7	29	500.3	-187.7	11.5	22.1	-25.7
		67.2	-16.8	1762	3517	38.1	-4.8	7	28	436.1	-172.2	9.3	16.5	-23.7
14TH	162.00	67.2	-16.8	1762	3517	38.1	-4.8	7	28	436.1	-172.2	9.3	16.5	-23.7
		69.4	-17.8	1762	3517	39.4	-5.0	7	27	368.9	-155.4	7.4	11.7	-21.8
15TH	174.00	69.4	-17.8	1762	3517	39.4	-5.0	7	27	368.9	-155.4	7.4	11.7	-21.8
		71.5	-18.7	1762	3517	40.6	-5.3	7	27	299.5	-137.6	5.6	7.7	-19.7
16TH	186.00	71.5	-18.7	1762	3517	40.6	-5.3	7	27	299.5	-137.6	5.6	7.7	-19.7
		73.5	-19.6	1762	3517	41.7	-5.6	7	27	228.0	-118.9	4.1	4.5	-17.7
17TH	198.00	73.5	-19.6	1762	3517	41.7	-5.6	7	27	228.0	-118.9	4.1	4.5	-17.7
		64.6	-21.0	1762	3517	36.6	-6.0	12	36	154.5	-99.3	2.8	2.2	-15.5
18TH	210.00	64.6	-21.0	1762	3517	36.6	-6.0	12	36	154.5	-99.3	2.8	2.2	-15.5
		55.6	-22.3	1762	3517	31.6	-6.3	18	45	89.9	-78.4	1.7	.7	-13.0
19TH	222.00	55.6	-22.3	1762	3517	31.6	-6.3	18	45	89.9	-78.4	1.7	.7	-13.0
		46.7	-23.6	1762	3517	26.5	-6.7	28	56	34.3	-56.1	.9	-.0	-10.0
MECH	234.00	46.7	-23.6	1762	3517	26.5	-6.7	28	56	34.3	-56.1	.9	-.0	-10.0
		-12.4	-32.4	2262	3733	-5.5	-8.7	181	-69	-12.4	-32.4	.4	-.1	-6.7
TOP	256.25	-12.4	-32.4	2262	3733	-5.5	-8.7	181	-69	-12.4	-32.4	.4	-.1	-6.7
										0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS : TWO LAKEWAY CENTER														
WIND DIRECTION 180		CONFIGURATION A				REFERENCE PRESSURE 38.0 PSF				GUST FACTOR 1.32				
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									1060.2	-243.3	38.9	141.7	-79.2
MEZZ	9.00	20.7	-12.9	1649	2872	12.5	-4.5	69	111	1039.6	-230.4	36.8	132.3	-76.0
PONT	18.00	19.7	-5.8	1687	2921	11.7	-2.0	45	155	1019.9	-224.6	34.8	123.0	-72.7
3RD	30.00	20.1	-5.0	2351	4025	8.6	-1.2	57	228	999.8	-219.6	32.1	110.9	-67.8
4TH	42.00	15.5	-8.5	2282	3996	6.8	-2.1	147	268	984.3	-211.1	29.5	99.0	-62.4
5TH	54.00	45.9	-10.5	2047	3899	22.4	-2.7	21	90	938.3	-200.6	27.0	87.5	-58.1
6TH	66.00	40.6	2.6	1762	3423	23.0	.8	-5	79	897.8	-203.2	24.6	76.4	-54.9
7TH	78.00	51.0	-2.2	1762	3517	28.9	-.6	3	67	846.8	-201.0	22.2	66.0	-51.4
8TH	90.00	53.5	-3.5	1762	3517	30.4	-1.0	4	62	793.3	-197.5	19.8	56.1	-48.1
9TH	102.00	56.0	-4.8	1762	3517	31.8	-1.4	5	56	737.3	-192.7	17.5	47.0	-45.0
10TH	114.00	58.7	-6.1	1762	3517	33.3	-1.7	5	52	678.6	-186.7	15.2	38.5	-41.9
11TH	126.00	63.2	-8.0	1762	3517	35.9	-2.3	6	47	615.4	-178.7	13.0	30.7	-38.8
12TH	138.00	67.7	-9.9	1762	3517	38.4	-2.8	6	43	547.7	-168.7	10.9	23.7	-35.8
13TH	150.00	72.2	-11.9	1762	3517	41.0	-3.4	7	40	475.4	-156.8	9.0	17.6	-32.9
14TH	162.00	75.4	-13.4	1762	3517	42.8	-3.8	7	39	400.1	-143.4	7.2	12.3	-29.8
15TH	174.00	77.4	-14.6	1762	3517	43.9	-4.2	7	39	322.7	-128.8	5.5	8.0	-26.7
16TH	186.00	79.5	-15.9	1762	3517	45.1	-4.5	8	39	243.2	-112.9	4.1	4.6	-23.4
17TH	198.00	81.3	-17.1	1762	3517	46.1	-4.9	8	40	161.9	-95.8	2.8	2.2	-20.1
18TH	210.00	70.4	-18.5	1762	3517	40.0	-5.2	13	49	91.4	-77.3	1.8	.6	-16.4
19TH	222.00	59.6	-19.8	1762	3517	33.8	-5.6	20	61	31.8	-57.5	1.0	-.1	-12.3
MECH	234.00	48.7	-21.1	1762	3517	27.7	-6.0	33	75	-16.9	-36.4	.4	-.2	-8.0
TOP	256.25	-16.9	-36.4	2262	3733	-7.5	-9.8	180	-84	0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS : TWO LAKEWAY CENTER														
WIND DIRECTION 190		CONFIGURATION A				REFERENCE PRESSURE 38.0 PSF				GUST FACTOR 1.32				
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00													
		26.5	-22.7	1649	2872	16.1	-7.9	61	72	1107.7	-473.3	63.5	143.4	-97.8
MEZZ	9.00													
		26.5	-17.1	1687	2921	15.7	-5.8	60	93	1081.2	-450.7	59.3	133.5	-94.5
PONT	18.00													
		29.8	-21.6	2351	4025	12.7	-5.4	84	116	1054.7	-433.6	55.3	123.9	-91.0
3RD	30.00													
		24.4	-24.2	2282	3996	10.7	-6.1	121	121	1024.9	-412.0	50.2	111.4	-85.7
4TH	42.00													
		47.4	-25.5	2047	3899	23.1	-6.5	45	83	1000.5	-387.8	45.4	99.3	-79.8
5TH	54.00													
		43.6	-9.3	1762	3423	24.7	-2.7	19	88	953.1	-362.3	40.9	87.6	-74.8
6TH	66.00													
		53.4	-13.6	1762	3517	30.3	-3.9	20	78	909.6	-353.0	36.6	76.4	-70.7
7TH	78.00													
		56.3	-15.3	1762	3517	32.0	-4.3	19	71	856.2	-339.5	32.5	65.8	-66.3
8TH	90.00													
		59.3	-17.0	1762	3517	33.7	-4.8	19	66	799.8	-324.2	28.5	55.8	-62.0
9TH	102.00													
		62.3	-18.7	1762	3517	35.4	-5.3	18	61	740.5	-307.1	24.7	46.6	-57.8
10TH	114.00													
		65.9	-20.1	1762	3517	37.4	-5.7	18	57	678.2	-288.4	21.2	38.1	-53.6
11TH	126.00													
		69.5	-21.6	1762	3517	39.5	-6.1	17	54	612.3	-268.3	17.8	30.3	-49.5
12TH	138.00													
		73.1	-23.0	1762	3517	41.5	-6.5	16	52	542.7	-246.7	14.7	23.4	-45.4
13TH	150.00													
		75.5	-23.9	1762	3517	42.9	-6.8	16	51	469.6	-223.7	11.9	17.3	-41.2
14TH	162.00													
		77.0	-24.5	1762	3517	43.7	-7.0	16	52	394.1	-199.8	9.4	12.2	-37.0
15TH	174.00													
		78.5	-25.0	1762	3517	44.6	-7.1	17	52	317.1	-175.3	7.1	7.9	-32.6
16TH	186.00													
		79.7	-25.5	1762	3517	45.3	-7.3	17	53	238.6	-150.3	5.2	4.6	-28.1
17TH	198.00													
		68.7	-26.5	1762	3517	39.0	-7.5	24	62	158.9	-124.8	3.5	2.2	-23.4
18TH	210.00													
		57.8	-27.5	1762	3517	32.8	-7.8	34	71	90.1	-98.3	2.2	.7	-18.5
19TH	222.00													
		46.8	-28.4	1762	3517	26.5	-8.1	49	81	32.4	-70.8	1.2	-.1	-13.5
MECH	234.00													
		-14.4	-42.4	2262	3733	-6.4	-11.4	175	-60	-14.4	-42.4	.5	-.2	-8.3
TOP	256.25													
										0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS : TWO LAKEWAY CENTER														
WIND DIRECTION 200		CONFIGURATION A				REFERENCE PRESSURE 38.0 PSF				GUST FACTOR 1.32				
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									1149.1	-930.8	119.4	145.0	-114.1
MEZZ	9.00	34.1	-35.4	1649	2872	20.7	-12.3	46	44	1114.9	-895.4	111.2	134.8	-111.0
PONT	18.00	33.3	-31.4	1687	2921	19.7	-10.8	50	53	1081.6	-864.0	103.2	124.9	-107.6
3RD	30.00	39.9	-43.6	2351	4025	17.0	-10.8	64	59	1041.7	-820.4	93.1	112.2	-102.5
4TH	42.00	34.3	-46.6	2282	3996	15.0	-11.7	82	60	1007.5	-773.8	83.6	99.9	-96.6
5TH	54.00	49.9	-46.1	2047	3899	24.4	-11.8	54	58	957.6	-727.7	74.6	88.1	-91.2
6TH	66.00	46.6	-31.8	1762	3423	26.4	-9.3	44	65	911.0	-695.9	66.0	76.9	-86.8
7TH	78.00	55.4	-37.0	1762	3517	31.4	-10.5	42	63	855.7	-658.9	57.9	66.3	-81.7
8TH	90.00	58.1	-39.7	1762	3517	33.0	-11.3	41	60	797.6	-619.2	50.2	56.4	-76.6
9TH	102.00	60.8	-42.4	1762	3517	34.5	-12.1	39	56	736.7	-576.8	43.1	47.2	-71.5
10TH	114.00	63.5	-45.0	1762	3517	36.1	-12.8	38	54	673.2	-531.9	36.4	38.7	-66.4
11TH	126.00	66.1	-45.5	1762	3517	37.5	-12.9	37	54	607.1	-486.4	30.3	31.0	-61.2
12TH	138.00	68.7	-46.1	1762	3517	39.0	-13.1	36	54	538.4	-440.3	24.7	24.2	-55.8
13TH	150.00	71.3	-46.6	1762	3517	40.5	-13.3	35	54	467.1	-393.7	19.7	18.1	-50.3
14TH	162.00	73.1	-47.1	1762	3517	41.5	-13.4	35	54	394.0	-346.6	15.3	13.0	-44.7
15TH	174.00	74.2	-47.4	1762	3517	42.1	-13.5	35	55	319.9	-299.2	11.4	8.7	-39.0
16TH	186.00	75.3	-47.8	1762	3517	42.7	-13.6	35	55	244.6	-251.4	8.1	5.3	-33.1
17TH	198.00	76.1	-48.2	1762	3517	43.2	-13.7	36	56	168.5	-203.2	5.4	2.8	-27.1
18TH	210.00	66.0	-48.1	1762	3517	37.4	-13.7	44	60	102.5	-155.1	3.2	1.2	-21.1
19TH	222.00	55.8	-48.0	1762	3517	31.7	-13.6	54	63	46.8	-107.1	1.7	.3	-15.0
MECH	234.00	45.6	-47.8	1762	3517	25.9	-13.6	67	64	1.2	-59.3	.7	.0	-8.8
TOP	256.25	1.2	-59.3	2262	3733	.5	-15.9	149	3	0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS : TWO LAKEWAY CENTER													
WIND DIRECTION 210		CONFIGURATION A				REFERENCE PRESSURE 38.0 PSF				GUST FACTOR 1.32			
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)	
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y
GRND	0.00									1182.9	-1504.6	187.5	145.5 -135.2
MEZZ	9.00	41.3	-51.8	1649	2872	25.0	-18.0	39	31	1141.6	-1452.8	174.2	135.0 -131.9
PONT	18.00	40.1	-50.9	1687	2921	23.8	-17.4	44	34	1101.5	-1401.9	161.3	124.9 -128.3
3RD	30.00	51.1	-73.8	2351	4025	21.8	-18.3	51	36	1050.4	-1328.1	145.0	112.0 -122.7
4TH	42.00	44.9	-78.9	2282	3996	19.7	-19.7	63	36	1005.5	-1249.2	129.5	99.7 -116.1
5TH	54.00	52.3	-77.8	2047	3899	25.5	-20.0	60	40	953.2	-1171.4	115.0	87.9 -109.3
6TH	66.00	50.6	-61.2	1762	3423	28.7	-17.9	52	43	902.6	-1110.2	101.3	76.8 -104.0
7TH	78.00	55.9	-67.0	1762	3517	31.8	-19.1	54	45	846.7	-1043.2	88.4	66.3 -97.9
8TH	90.00	58.3	-69.5	1762	3517	33.1	-19.8	52	44	788.3	-973.7	76.3	56.5 -91.7
9TH	102.00	60.7	-71.9	1762	3517	34.5	-20.4	51	43	727.6	-901.8	65.0	47.4 -85.4
10TH	114.00	63.1	-74.2	1762	3517	35.8	-21.1	50	42	664.4	-827.6	54.6	39.0 -79.0
11TH	126.00	65.2	-74.9	1762	3517	37.0	-21.3	50	43	599.2	-752.8	45.2	31.4 -72.4
12TH	138.00	67.4	-75.5	1762	3517	38.2	-21.5	50	44	531.8	-677.3	36.6	24.6 -65.7
13TH	150.00	69.5	-76.2	1762	3517	39.4	-21.7	50	45	462.4	-601.1	28.9	18.7 -58.8
14TH	162.00	70.8	-76.8	1762	3517	40.2	-21.8	49	46	391.6	-524.3	22.2	13.6 -51.8
15TH	174.00	71.4	-77.3	1762	3517	40.5	-22.0	50	46	320.2	-447.0	16.3	9.3 -44.7
16TH	186.00	72.0	-77.9	1762	3517	40.9	-22.2	50	46	248.2	-369.1	11.4	5.9 -37.5
17TH	198.00	72.5	-78.4	1762	3517	41.1	-22.3	50	46	175.7	-290.7	7.5	3.3 -30.3
18TH	210.00	63.3	-74.3	1762	3517	35.9	-21.1	55	47	112.4	-216.4	4.4	1.6 -23.2
19TH	222.00	54.1	-70.2	1762	3517	30.7	-20.0	62	48	58.3	-146.2	2.2	.6 -16.3
MECH	234.00	44.9	-66.1	1762	3517	25.5	-18.8	70	47	13.4	-80.1	.9	.1 -9.5
TOP	256.25	13.4	-80.1	2262	3733	5.9	-21.5	116	19	0.0	0.0	0.0	0.0 0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS : TWO LAKEWAY CENTER														
WIND DIRECTION 220		CONFIGURATION A				REFERENCE PRESSURE 38.0 PSF						GUST FACTOR 1.32		
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00	44.8	-66.7	1649	2872	27.2	-23.2	39	26	1186.3	-2014.9	251.0	143.4	-154.5
MEZZ	9.00	44.5	-68.1	1687	2921	26.4	-23.3	42	27	1141.5	-1948.2	233.2	132.9	-150.8
PONT	18.00	58.9	-98.7	2351	4025	25.0	-24.5	47	28	1097.0	-1880.1	215.9	122.9	-146.8
3RD	30.00	53.1	-105.4	2282	3996	23.2	-26.4	55	28	1038.1	-1781.4	194.0	110.1	-140.5
4TH	42.00	53.2	-102.8	2047	3899	26.0	-26.4	61	31	985.1	-1676.0	173.2	97.9	-133.2
5TH	54.00	51.9	-83.3	1762	3423	29.4	-24.3	54	34	931.9	-1573.2	153.7	86.4	-125.3
6TH	66.00	55.7	-91.8	1762	3517	31.6	-26.1	57	34	880.0	-1489.9	135.3	75.5	-119.1
7TH	78.00	57.6	-94.4	1762	3517	32.7	-26.8	56	34	824.3	-1398.1	118.0	65.3	-112.0
8TH	90.00	59.6	-97.0	1762	3517	33.8	-27.6	56	34	766.7	-1303.7	101.8	55.8	-104.7
9TH	102.00	61.5	-99.5	1762	3517	34.9	-28.3	55	34	707.1	-1206.7	86.7	46.9	-97.2
10TH	114.00	63.2	-100.6	1762	3517	35.9	-28.6	55	35	645.5	-1107.2	72.9	38.8	-89.7
11TH	126.00	64.8	-101.8	1762	3517	36.8	-28.9	55	35	582.4	-1006.5	60.2	31.4	-81.9
12TH	138.00	66.5	-102.9	1762	3517	37.7	-29.3	55	36	517.5	-904.8	48.7	24.8	-74.0
13TH	150.00	67.3	-103.7	1762	3517	38.2	-29.5	55	36	451.1	-801.8	38.5	19.0	-66.0
14TH	162.00	67.6	-104.0	1762	3517	38.4	-29.6	55	36	383.7	-698.2	29.5	14.0	-57.9
15TH	174.00	67.9	-104.4	1762	3517	38.5	-29.7	55	36	316.1	-594.1	21.7	9.8	-49.7
16TH	186.00	68.0	-104.7	1762	3517	38.6	-29.8	56	36	248.2	-489.7	15.2	6.4	-41.5
17TH	198.00	59.2	-98.2	1762	3517	33.6	-27.9	60	36	180.2	-385.0	10.0	3.9	-33.2
18TH	210.00	50.5	-91.8	1762	3517	28.7	-26.1	65	36	121.0	-286.7	5.9	2.1	-25.2
19TH	222.00	41.8	-85.4	1762	3517	23.7	-24.3	71	35	70.5	-194.9	3.0	.9	-17.4
MECH	234.00	28.7	-109.6	2262	3733	12.7	-29.3	85	22	28.7	-109.6	1.2	.3	-9.9
TOP	256.25									0.0	0.0	0.0	0.0	0.0

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00	43.6	-76.9	1649	2872	26.5	-26.8	39	22	1005.5	-2269.3	280.5	117.1	-157.1
MEZZ	9.00	43.9	-77.7	1687	2921	26.0	-26.6	41	23	961.8	-2192.4	260.4	108.3	-153.1
PONT	18.00	57.8	-110.2	2351	4025	24.6	-27.4	44	23	917.9	-2114.7	241.0	99.8	-148.9
3RD	30.00	51.6	-117.2	2282	3996	22.6	-29.3	52	23	860.1	-2004.5	216.3	89.1	-142.7
4TH	42.00	45.8	-114.6	2047	3899	22.4	-29.4	60	24	808.5	-1887.3	192.9	79.1	-135.4
5TH	54.00	46.1	-94.7	1762	3423	26.2	-27.7	55	27	762.7	-1772.8	171.0	69.7	-127.4
6TH	66.00	47.1	-104.8	1762	3517	26.7	-29.8	59	27	669.5	-1573.3	130.8	52.5	-113.5
7TH	78.00	48.5	-108.1	1762	3517	27.5	-30.8	59	26	621.0	-1465.2	112.5	44.8	-105.8
8TH	90.00	49.8	-111.5	1762	3517	28.3	-31.7	58	26	571.2	-1353.7	95.6	37.6	-98.1
9TH	102.00	51.1	-114.7	1762	3517	29.0	-32.6	58	26	520.1	-1239.0	80.1	31.1	-90.2
10TH	114.00	52.1	-115.5	1762	3517	29.6	-32.8	58	26	468.0	-1123.5	65.9	25.1	-82.1
11TH	126.00	53.1	-116.3	1762	3517	30.1	-33.1	58	26	414.9	-1007.2	53.1	19.8	-74.0
12TH	138.00	54.1	-117.2	1762	3517	30.7	-33.3	58	27	360.8	-890.0	41.7	15.2	-65.8
13TH	150.00	54.4	-117.9	1762	3517	30.9	-33.5	58	27	306.4	-772.1	31.7	11.2	-57.5
14TH	162.00	54.2	-118.4	1762	3517	30.8	-33.7	58	27	252.2	-653.7	23.2	7.8	-49.3
15TH	174.00	54.1	-119.0	1762	3517	30.7	-33.8	58	26	198.1	-534.7	16.1	5.1	-40.9
16TH	186.00	53.8	-119.4	1762	3517	30.5	-34.0	58	26	144.3	-415.2	10.4	3.1	-32.6
17TH	198.00	47.3	-111.3	1762	3517	26.8	-31.6	62	26	97.0	-303.9	6.0	1.6	-24.5
18TH	210.00	40.8	-103.1	1762	3517	23.1	-29.3	66	26	56.2	-200.9	3.0	.7	-16.7
19TH	222.00	34.3	-94.9	1762	3517	19.4	-27.0	70	25	22.0	-106.0	1.2	.2	-9.1
MECH	234.00	22.0	-106.0	2262	3733	9.7	-28.4	83	17	0.0	0.0	0.0	0.0	0.0
TOP	256.25													

TABLE 7. SHEAR AND MOMENT DIAGRAMS 1
WIND DIRECTION 240

CONFIGURATION A

TWO LAKEWAY CENTER

REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00	39.7	-82.3	1649	2872	24.1	-28.6	40	19	756.0	-2309.0	283.7	84.2	-150.2
MEZZ	9.00	39.9	-80.6	1687	2921	23.6	-27.6	41	20	716.3	-2226.8	263.3	77.6	-146.1
PONT	18.00	52.2	-112.0	2351	4025	22.2	-27.8	44	21	676.4	-2146.1	243.6	71.3	-142.0
3RD	30.00	45.8	-118.8	2282	3996	20.1	-29.7	50	19	624.2	-2034.2	218.5	63.5	-136.0
4TH	42.00	34.9	-115.7	2047	3899	17.1	-29.7	60	18	578.5	-1915.3	194.8	56.3	-129.1
5TH	54.00	34.4	-96.0	1762	3423	19.5	-28.0	57	20	543.5	-1799.6	172.6	49.6	-121.5
6TH	66.00	34.1	-106.4	1762	3517	19.4	-30.2	61	20	509.2	-1703.6	151.5	43.3	-115.4
7TH	78.00	34.8	-110.0	1762	3517	19.8	-31.3	60	19	475.1	-1597.3	131.7	37.4	-108.2
8TH	90.00	35.6	-113.6	1762	3517	20.2	-32.3	60	19	440.2	-1487.3	113.2	31.9	-100.9
9TH	102.00	36.3	-117.0	1762	3517	20.6	-33.3	59	18	404.7	-1373.7	96.1	26.8	-93.5
10TH	114.00	36.9	-118.2	1762	3517	20.9	-33.6	59	19	368.4	-1256.7	80.3	22.2	-85.9
11TH	126.00	37.4	-119.4	1762	3517	21.3	-34.0	60	19	331.5	-1138.5	65.9	18.0	-78.2
12TH	138.00	38.0	-120.6	1762	3517	21.6	-34.3	60	19	294.1	-1019.1	53.0	14.2	-70.4
13TH	150.00	38.2	-121.4	1762	3517	21.7	-34.5	60	19	256.1	-898.5	41.5	10.9	-62.5
14TH	162.00	38.1	-121.8	1762	3517	21.6	-34.6	60	19	217.8	-777.1	31.4	8.1	-54.5
15TH	174.00	38.0	-122.2	1762	3517	21.6	-34.8	60	19	179.7	-655.2	22.8	5.7	-46.5
16TH	186.00	37.8	-122.5	1762	3517	21.5	-34.8	60	18	141.7	-533.0	15.7	3.8	-38.5
17TH	198.00	33.3	-113.4	1762	3517	18.9	-32.2	63	18	103.9	-410.5	10.0	2.3	-30.5
18TH	210.00	28.7	-104.3	1762	3517	16.3	-29.7	67	18	70.6	-297.1	5.8	1.2	-22.7
19TH	222.00	24.1	-95.2	1762	3517	13.7	-27.1	71	18	41.9	-192.8	2.8	.6	-15.3
MECH	234.00	17.8	-97.6	2262	3733	7.9	-26.1	80	15	17.8	-97.6	1.1	.2	-8.1
TOP	256.25									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS : TWO LAKEWAY CENTER													
WIND DIRECTION 250		CONFIGURATION A				REFERENCE PRESSURE 38.0 PSF				GUST FACTOR 1.32			
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)	
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y
GRND	0.00	33.9	-83.2	1649	2872	20.5	-29.0	41	17	478.1	-2220.1	271.3	48.4 -139.3
MEZZ	9.00	34.7	-80.6	1687	2921	20.6	-27.6	42	18	444.2	-2136.9	251.7	44.2 -135.3
PONT	18.00	44.5	-109.9	2351	4025	18.9	-27.3	44	18	409.5	-2056.3	232.8	40.4 -131.3
3RD	30.00	37.1	-115.0	2282	3996	16.3	-28.8	51	16	365.0	-1946.4	208.8	35.8 -125.7
4TH	42.00	23.3	-111.7	2047	3899	11.4	-28.7	61	13	327.9	-1831.3	186.1	31.6 -119.2
5TH	54.00	19.9	-89.6	1762	3423	11.3	-26.2	59	13	304.6	-1719.6	164.8	27.8 -112.0
6TH	66.00	19.2	-100.8	1762	3517	10.9	-28.7	63	12	284.6	-1630.0	144.7	24.3 -106.5
7TH	78.00	19.7	-104.4	1762	3517	11.2	-29.7	63	12	265.5	-1529.2	125.8	21.0 -99.9
8TH	90.00	20.2	-108.0	1762	3517	11.4	-30.7	62	12	245.8	-1424.8	108.1	17.9 -93.1
9TH	102.00	20.6	-111.4	1762	3517	11.7	-31.7	62	11	225.7	-1316.8	91.6	15.1 -86.2
10TH	114.00	20.8	-113.1	1762	3517	11.8	-32.2	61	11	205.0	-1205.4	76.5	12.5 -79.1
11TH	126.00	20.9	-114.7	1762	3517	11.8	-32.6	61	11	184.3	-1092.3	62.7	10.2 -71.9
12TH	138.00	21.0	-116.4	1762	3517	11.9	-33.1	61	11	163.4	-977.6	50.3	8.1 -64.6
13TH	150.00	20.9	-117.4	1762	3517	11.9	-33.4	61	11	142.4	-861.2	39.2	6.2 -57.3
14TH	162.00	20.8	-118.0	1762	3517	11.8	-33.5	61	11	121.5	-743.8	29.6	4.7 -49.8
15TH	174.00	20.7	-118.5	1762	3517	11.8	-33.7	62	11	100.7	-625.8	21.4	3.3 -42.4
16TH	186.00	20.6	-118.9	1762	3517	11.7	-33.8	62	11	79.9	-507.2	14.6	2.2 -34.8
17TH	198.00	17.9	-110.2	1762	3517	10.2	-31.3	64	10	59.4	-388.3	9.2	1.4 -27.3
18TH	210.00	15.3	-101.6	1762	3517	8.7	-28.9	67	10	41.4	-278.1	5.2	.8 -20.0
19TH	222.00	12.6	-92.9	1762	3517	7.2	-26.4	70	10	26.1	-176.5	2.5	.4 -13.0
MECH	234.00	13.5	-83.6	2262	3733	6.0	-22.4	74	12	13.5	-83.6	.9	.2 -6.4
TOP	256.25									0.0	0.0	0.0	0.0 0.0

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									175.3	-2081.4	251.5	8.4	-130.2
MEZZ	9.00	28.2	-80.8	1649	2872	17.1	-28.1	43	15	147.1	-2000.6	233.1	6.9	-126.3
PONT	18.00	28.8	-77.7	1687	2921	17.1	-26.6	44	16	118.3	-1922.9	215.5	5.7	-122.4
3RD	30.00	36.7	-105.6	2351	4025	15.6	-26.2	46	16	81.5	-1817.3	193.0	4.5	-117.0
4TH	42.00	27.9	-108.8	2282	3996	12.2	-27.2	54	14	53.7	-1708.5	171.9	3.7	-110.8
5TH	54.00	11.6	-104.9	2047	3899	5.7	-26.9	64	7	42.1	-1603.6	152.0	3.2	-104.0
6TH	66.00	1.8	-83.0	1762	3423	1.0	-24.3	61	1	40.3	-1520.5	133.3	2.7	-98.9
7TH	78.00	2.1	-94.5	1762	3517	1.2	-26.9	64	1	38.2	-1426.0	115.6	2.2	-92.8
8TH	90.00	2.9	-98.2	1762	3517	1.7	-27.9	64	2	35.3	-1327.8	99.1	1.8	-86.6
9TH	102.00	3.7	-101.8	1762	3517	2.1	-29.0	63	2	31.6	-1226.0	83.7	1.4	-80.1
10TH	114.00	4.4	-105.3	1762	3517	2.5	-29.9	63	3	27.2	-1120.7	69.7	1.0	-73.5
11TH	126.00	4.1	-106.9	1762	3517	2.3	-30.4	63	2	23.1	-1013.8	56.8	.7	-66.8
12TH	138.00	3.7	-108.6	1762	3517	2.1	-30.9	63	2	19.3	-905.2	45.3	.4	-60.0
13TH	150.00	3.4	-110.2	1762	3517	1.9	-31.3	62	2	15.9	-795.0	35.1	.2	-53.2
14TH	162.00	3.4	-111.3	1762	3517	1.9	-31.6	63	2	12.5	-683.7	26.3	.1	-46.2
15TH	174.00	3.6	-111.9	1762	3517	2.1	-31.8	63	2	8.9	-571.8	18.7	-.1	-39.1
16TH	186.00	3.8	-112.6	1762	3517	2.2	-32.0	63	2	5.1	-459.2	12.5	-.1	-32.0
17TH	198.00	4.0	-113.0	1762	3517	2.3	-32.1	63	2	1.0	-346.2	7.7	-.2	-24.9
18TH	210.00	3.2	-104.6	1762	3517	1.8	-29.7	65	2	-2.2	-241.6	4.2	-.2	-18.0
19TH	222.00	2.4	-96.2	1762	3517	1.4	-27.4	68	2	-4.7	-145.4	1.9	-.1	-11.5
MECH	234.00	1.7	-87.8	1762	3517	.9	-25.0	70	1	-6.3	-57.6	.6	-.1	-5.3
TOP	256.25	-6.3	-57.6	2262	3733	-2.8	-15.4	91	-10	0.0	0.0	0.0	0.0	0.0

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00	24.5	-77.4	1649	2872	14.8	-27.0	15	14	-138.7	-2036.3	245.9	-33.5	-132.5
MEZZ	9.00	23.6	-74.8	1687	2921	14.0	-25.6	47	15	-163.1	-1958.8	227.9	-32.2	-128.7
PONT	18.00	29.0	-103.9	2351	4025	12.4	-25.8	49	14	-186.7	-1884.0	210.6	-30.6	-124.9
3RD	30.00	19.5	-107.4	2282	3996	8.6	-26.9	57	10	-215.8	-1780.2	188.6	-28.2	-119.4
4TH	42.00	-1.8	-101.6	2047	3899	-9	-26.1	66	-1	-235.3	-1672.8	167.9	-25.5	-113.0
5TH	54.00	-15.0	-79.7	1762	3423	-8.5	-23.3	60	-11	-233.5	-1571.2	148.4	-22.6	-106.3
6TH	66.00	-15.2	-91.4	1762	3517	-8.7	-26.0	64	-11	-218.5	-1491.5	130.0	-19.9	-101.3
7TH	78.00	-14.7	-95.3	1762	3517	-8.4	-27.1	64	-10	-203.3	-1400.0	112.7	-17.4	-95.3
8TH	90.00	-14.2	-99.1	1762	3517	-8.0	-28.2	64	-9	-188.6	-1304.8	96.5	-15.1	-89.1
9TH	102.00	-13.7	-102.8	1762	3517	-7.8	-29.2	64	-8	-174.4	-1205.7	81.4	-12.9	-82.7
10TH	114.00	-14.0	-105.3	1762	3517	-8.0	-29.9	64	-9	-160.7	-1102.9	67.5	-10.9	-76.0
11TH	126.00	-14.3	-107.8	1762	3517	-8.1	-30.6	64	-9	-146.7	-997.6	54.9	-9.0	-69.2
12TH	138.00	-14.6	-110.2	1762	3517	-8.3	-31.3	64	-9	-132.3	-889.9	43.6	-7.3	-62.2
13TH	150.00	-14.7	-111.7	1762	3517	-8.4	-31.8	64	-9	-117.7	-779.6	33.6	-5.8	-55.0
14TH	162.00	-14.7	-112.3	1762	3517	-8.3	-31.9	65	-8	-103.0	-668.0	24.9	-4.5	-47.6
15TH	174.00	-14.7	-113.0	1762	3517	-8.3	-32.1	65	-8	-88.3	-555.6	17.6	-3.4	-40.3
16TH	186.00	-14.6	-113.4	1762	3517	-8.3	-32.3	65	-8	-73.6	-442.6	11.6	-2.4	-32.8
17TH	198.00	-13.9	-104.5	1762	3517	-7.9	-29.7	67	-9	-59.0	-329.2	7.0	-1.6	-25.3
18TH	210.00	-13.2	-95.5	1762	3517	-7.5	-27.2	69	-10	-45.1	-224.7	3.6	-1.0	-18.2
19TH	222.00	-12.5	-86.5	1762	3517	-7.1	-24.6	72	-10	-31.8	-129.3	1.5	-.5	-11.5
MECH	234.00	-19.3	-42.8	2262	3733	-8.5	-11.5	101	-45	-19.3	-42.8	.5	-.2	-5.2
TOP	256.25									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS : TWO LAKEWAY CENTER														
WIND DIRECTION 280		CONFIGURATION A				REFERENCE PRESSURE 38.0 PSF				GUST FACTOR 1.32				
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00													
MEZZ	9.00	22.6	-73.0	1649	2872	13.7	-25.4	47	15	-326.2	-1883.8	227.6	-58.4	-135.4
PONT	18.00	20.5	-70.6	1687	2921	12.2	-24.2	49	14	-348.7	-1810.8	211.0	-55.4	-131.6
3RD	30.00	20.5	-94.8	2351	4025	8.7	-23.6	55	12	-369.2	-1740.2	195.0	-52.1	-127.9
4TH	42.00	12.9	-97.2	2282	3996	5.6	-24.3	63	8	-389.7	-1645.4	174.7	-47.6	-122.4
5TH	54.00	-9.8	-91.4	2047	3899	-4.8	-23.4	73	-8	-402.6	-1548.2	155.5	-42.8	-116.2
6TH	66.00	-24.4	-72.9	1762	3423	-13.8	-21.3	63	-21	-392.8	-1456.8	137.5	-38.0	-109.4
7TH	78.00	-25.4	-84.7	1762	3517	-14.4	-24.1	67	-20	-368.4	-1383.9	120.4	-33.5	-104.3
8TH	90.00	-24.9	-88.3	1762	3517	-14.1	-25.1	68	-19	-343.0	-1299.2	104.3	-29.2	-98.1
9TH	102.00	-24.4	-91.9	1762	3517	-13.9	-26.1	68	-18	-318.2	-1211.0	89.3	-25.2	-91.6
10TH	114.00	-24.0	-95.4	1762	3517	-13.6	-27.1	69	-17	-293.7	-1119.1	75.3	-21.6	-84.9
11TH	126.00	-23.9	-97.7	1762	3517	-13.6	-27.8	69	-17	-269.8	-1023.7	62.4	-18.2	-77.9
12TH	138.00	-23.9	-99.9	1762	3517	-13.6	-28.4	68	-16	-245.8	-926.0	50.7	-15.1	-70.8
13TH	150.00	-23.9	-102.2	1762	3517	-13.6	-29.1	68	-16	-221.9	-826.1	40.2	-12.3	-63.5
14TH	162.00	-23.9	-103.8	1762	3517	-13.6	-29.5	68	-16	-198.0	-723.9	30.9	-9.8	-56.2
15TH	174.00	-24.0	-103.8	1762	3517	-13.6	-29.5	68	-16	-174.0	-620.1	22.9	-7.5	-48.7
16TH	186.00	-24.1	-104.9	1762	3517	-13.7	-29.8	68	-16	-149.9	-515.2	16.0	-5.6	-41.2
17TH	198.00	-24.3	-106.1	1762	3517	-13.8	-30.2	68	-16	-125.6	-409.1	10.5	-3.9	-33.6
18TH	210.00	-24.5	-107.0	1762	3517	-13.9	-30.4	68	-16	-101.1	-302.1	6.2	-2.6	-25.9
19TH	222.00	-24.8	-98.1	1762	3517	-14.1	-27.9	70	-18	-76.3	-204.0	3.2	-1.5	-18.6
MECH	234.00	-25.1	-89.2	1762	3517	-14.2	-25.4	72	-20	-51.3	-114.8	1.3	-.8	-11.6
		-25.4	-80.3	1762	3517	-14.4	-22.8	75	-24	-25.9	-34.4	.4	-.3	-5.0
TOP	256.25	-25.9	-34.4	2262	3733	-11.4	-9.2	93	-70	0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS : WIND DIRECTION 290		CONFIGURATION A		TWO LAKEWAY CENTER		REFERENCE PRESSURE 38.0 PSF		GUST FACTOR 1.32						
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									-26.6	-2495.7	300.3	-15.8	-204.9
MEZZ	9.00	26.7	-93.3	1649	2872	16.2	-32.5	56	16	-53.3	-2402.3	278.3	-15.5	-199.2
PONT	18.00	23.9	-93.7	1687	2921	14.2	-32.1	59	15	-77.2	-2308.6	257.1	-14.9	-193.3
3RD	30.00	25.1	-127.7	2351	4025	10.7	-31.7	64	13	-102.3	-2181.0	230.1	-13.8	-184.8
4TH	42.00	17.5	-129.9	2282	3996	7.6	-32.5	72	10	-102.3	-2181.0	230.1	-13.8	-184.8
4TH	42.00	1.3	-122.4	2047	3899	.6	-31.4	84	1	-119.8	-2051.1	204.7	-12.5	-175.4
5TH	54.00	-12.4	-101.9	1762	3423	-7.0	-29.8	81	-10	-121.1	-1928.6	180.9	-11.0	-165.1
6TH	66.00	-10.4	-117.3	1762	3517	-5.9	-33.4	83	-7	-108.7	-1826.7	158.3	-9.7	-156.7
7TH	78.00	-9.3	-120.8	1762	3517	-5.3	-34.3	83	-6	-98.3	-1709.4	137.1	-8.4	-146.9
8TH	90.00	-8.1	-124.2	1762	3517	-4.6	-35.3	84	-5	-89.0	-1588.6	117.3	-7.3	-136.7
9TH	102.00	-7.0	-127.4	1762	3517	-4.0	-36.2	84	-5	-80.9	-1464.4	99.0	-6.3	-126.2
10TH	114.00	-6.8	-128.9	1762	3517	-3.8	-36.6	84	-4	-73.9	-1337.0	82.2	-5.3	-115.4
11TH	126.00	-6.5	-130.3	1762	3517	-3.7	-37.0	84	-4	-67.1	-1208.1	66.9	-4.5	-104.6
12TH	138.00	-6.3	-131.7	1762	3517	-3.6	-37.4	84	-4	-60.6	-1077.9	53.2	-3.7	-93.6
13TH	150.00	-6.0	-133.3	1762	3517	-3.4	-37.9	83	-4	-54.3	-946.2	41.1	-3.0	-82.6
14TH	162.00	-5.6	-135.0	1762	3517	-3.2	-38.4	83	-3	-48.4	-812.9	30.5	-2.4	-71.4
15TH	174.00	-5.2	-136.7	1762	3517	-3.0	-38.9	82	-3	-42.8	-677.9	21.6	-1.9	-60.2
16TH	186.00	-4.9	-138.2	1762	3517	-2.8	-39.3	82	-3	-37.5	-541.2	14.3	-1.4	-48.9
17TH	198.00	-5.8	-127.1	1762	3517	-3.3	-36.1	84	-4	-32.6	-403.0	8.6	-1.0	-37.6
18TH	210.00	-6.6	-116.0	1762	3517	-3.8	-33.0	87	-5	-26.9	-275.9	4.5	-.6	-26.8
19TH	222.00	-7.5	-105.0	1762	3517	-4.3	-29.8	90	-6	-20.2	-159.8	1.9	-.3	-16.7
MECH	234.00	-12.7	-54.9	2262	3733	-5.6	-14.7	126	-29	-12.7	-54.9	.6	-.1	-7.3
TOP	256.25									0.0	0.0	0.0	0.0	0.0

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									3.5	-2389.5	291.7	-6.1	-215.7
MEZZ	9.00	13.1	-72.8	1649	2872	7.9	-25.3	75	14	-9.6	-2316.6	270.5	-6.0	-210.0
PONT	18.00	10.7	-75.3	1687	2921	6.3	-25.8	80	11	-20.3	-2241.3	250.0	-5.9	-203.9
3RD	30.00	14.7	-113.8	2351	4025	6.2	-28.3	83	11	-35.0	-2127.5	223.8	-5.6	-194.3
4TH	42.00	16.2	-126.1	2282	3996	7.1	-31.5	80	10	-51.2	-2001.5	199.0	-5.1	-184.1
5TH	54.00	4.6	-122.0	2047	3899	2.2	-31.3	93	3	-55.8	-1879.5	175.7	-4.4	-172.8
6TH	66.00	-9.1	-102.7	1762	3423	-5.2	-30.0	91	-8	-46.7	-1776.7	153.8	-3.8	-163.4
7TH	78.00	-6.8	-114.7	1762	3517	-3.9	-32.6	91	-5	-39.8	-1662.0	133.1	-3.3	-152.9
8TH	90.00	-5.6	-117.8	1762	3517	-3.2	-33.5	91	-4	-34.2	-1544.2	113.9	-2.8	-142.2
9TH	102.00	-4.4	-120.8	1762	3517	-2.5	-34.4	91	-3	-29.8	-1423.4	96.1	-2.5	-131.2
10TH	114.00	-3.2	-123.8	1762	3517	-1.8	-35.2	91	-2	-26.6	-1299.6	79.8	-2.1	-119.9
11TH	126.00	-2.9	-125.3	1762	3517	-1.6	-35.6	91	-2	-23.7	-1174.3	64.9	-1.8	-108.5
12TH	138.00	-2.6	-126.8	1762	3517	-1.5	-36.1	90	-2	-21.1	-1047.5	51.6	-1.6	-97.1
13TH	150.00	-2.2	-128.3	1762	3517	-1.3	-36.5	90	-2	-18.9	-919.2	39.8	-1.3	-85.5
14TH	162.00	-1.8	-129.9	1762	3517	-1.0	-36.9	89	-1	-17.1	-789.3	29.5	-1.1	-73.9
15TH	174.00	-1.3	-131.6	1762	3517	-.7	-37.4	89	-1	-15.8	-657.7	20.9	-.9	-62.2
16TH	186.00	-.8	-133.3	1762	3517	-.5	-37.9	88	-1	-15.0	-524.5	13.8	-.7	-50.5
17TH	198.00	-.4	-134.7	1762	3517	-.2	-38.3	88	-0	-14.6	-389.8	8.3	-.5	-38.6
18TH	210.00	-1.1	-123.6	1762	3517	-.7	-35.1	90	-1	-13.4	-266.2	4.3	-.4	-27.5
19TH	222.00	-1.9	-112.5	1762	3517	-1.1	-32.0	93	-2	-11.5	-153.7	1.8	-.2	-17.0
MECH	234.00	-2.7	-101.4	1762	3517	-1.5	-28.8	97	-3	-8.8	-52.3	.6	-.1	-7.2
TDP	256.25	-8.8	-52.3	2262	3733	-3.9	-14.0	134	-23	0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS : TWO LAKEWAY CENTER														
WIND DIRECTION 310		CONFIGURATION A				REFERENCE PRESSURE 38.0 PSF				GUST FACTOR 1.32				
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00													
		-5.6	-41.8	1649	2872	-3.4	-14.6	92	-12	-235.2	-1810.2	228.3	-28.8	-169.8
MEZZ	9.00													
		-9.8	-43.1	1687	2921	-5.8	-14.8	96	-22	-229.6	-1768.4	212.2	-26.7	-165.9
PONT	18.00													
		-12.8	-70.8	2351	4025	-5.4	-17.6	98	-18	-219.8	-1725.2	196.5	-24.7	-161.6
3RD	30.00													
		-8.5	-81.5	2282	3996	-3.7	-20.4	92	-10	-207.0	-1654.5	176.2	-22.1	-154.4
4TH	42.00													
		-11.0	-82.7	2047	3899	-5.4	-21.2	96	-13	-198.5	-1573.0	156.8	-19.7	-146.8
5TH	54.00													
		-18.6	-74.1	1762	3423	-10.5	-21.7	88	-22	-187.5	-1490.2	138.5	-17.4	-138.7
6TH	66.00													
		-15.5	-86.6	1762	3517	-8.8	-24.6	91	-16	-168.9	-1416.1	121.0	-15.2	-131.8
7TH	78.00													
		-13.5	-92.3	1762	3517	-7.7	-26.2	90	-13	-153.4	-1329.5	104.6	-13.3	-123.7
8TH	90.00													
		-11.6	-98.0	1762	3517	-6.6	-27.9	90	-11	-139.8	-1237.3	89.2	-11.5	-115.2
9TH	102.00													
		-9.8	-103.3	1762	3517	-5.5	-29.4	89	-8	-128.3	-1139.2	74.9	-9.9	-106.3
10TH	114.00													
		-9.8	-104.4	1762	3517	-5.6	-29.7	89	-8	-118.5	-1035.9	61.8	-8.5	-97.0
11TH	126.00													
		-9.9	-105.4	1762	3517	-5.6	-30.0	89	-8	-108.7	-931.5	50.0	-7.1	-87.6
12TH	138.00													
		-10.0	-106.4	1762	3517	-5.7	-30.3	89	-8	-98.8	-826.2	39.5	-5.8	-78.1
13TH	150.00													
		-10.0	-106.9	1762	3517	-5.7	-30.4	88	-8	-88.8	-719.8	30.2	-4.7	-68.6
14TH	162.00													
		-9.9	-106.9	1762	3517	-5.6	-30.4	89	-8	-78.7	-612.9	22.2	-3.7	-59.1
15TH	174.00													
		-9.9	-107.0	1762	3517	-5.6	-30.4	89	-8	-68.8	-505.9	15.5	-2.8	-49.5
16TH	186.00													
		-9.8	-106.9	1762	3517	-5.6	-30.4	89	-8	-59.0	-398.9	10.1	-2.1	-40.0
17TH	198.00													
		-10.1	-96.9	1762	3517	-5.7	-27.5	92	-10	-49.2	-292.0	5.9	-1.4	-30.4
18TH	210.00													
		-10.4	-86.9	1762	3517	-5.9	-24.7	95	-11	-39.1	-195.1	3.0	-.9	-21.4
19TH	222.00													
		-10.7	-76.9	1762	3517	-6.1	-21.9	100	-14	-28.7	-108.3	1.2	-.5	-13.0
MECH	234.00													
		-18.0	-31.4	2262	3733	-8.0	-8.4	125	-72	-18.0	-31.4	.3	-.2	-5.2
TOP	256.25									0.0	0.0	0.0	0.0	0.0

		CONFIGURATION A		TWO LAKEWAY CENTER		REFERENCE PRESSURE 38.0 PSF				GUST FACTOR 1.32			
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)	
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Z
GRND	0.00												
		-22.4	-15.4	1649	2872	-13.6	-5.4	31	-44	-588.1	-1015.3	132.3	-70.7
MEZZ	9.00												
		-26.2	-16.3	1687	2921	-15.6	-5.6	30	-48	-565.7	-999.9	123.3	-65.5
PONT	18.00												
		-34.1	-31.0	2351	4025	-14.5	-7.7	46	-51	-539.5	-983.6	114.4	-60.5
3RD	30.00												
		-28.4	-43.4	2282	3996	-12.4	-10.9	62	-41	-505.4	-952.6	102.7	-54.2
4TH	42.00												
		-27.1	-41.3	2047	3899	-13.2	-10.6	59	-39	-477.0	-909.2	91.6	-48.4
5TH	54.00												
		-33.6	-37.9	1762	3423	-19.0	-11.1	40	-35	-449.9	-868.0	80.9	-42.8
6TH	66.00												
		-31.1	-45.5	1762	3517	-17.7	-12.9	50	-34	-416.3	-830.1	70.7	-37.6
7TH	78.00												
		-29.8	-51.1	1762	3517	-16.9	-14.5	55	-32	-385.2	-784.6	61.0	-32.8
8TH	90.00												
		-28.5	-56.7	1762	3517	-16.2	-16.1	60	-30	-355.3	-733.4	51.9	-28.3
9TH	102.00												
		-27.3	-61.9	1762	3517	-15.5	-17.6	63	-28	-326.8	-676.8	43.5	-24.2
10TH	114.00												
		-27.2	-62.8	1762	3517	-15.5	-17.9	64	-28	-299.5	-614.9	35.7	-20.5
11TH	126.00												
		-27.1	-63.8	1762	3517	-15.4	-18.1	66	-28	-272.2	-552.1	28.7	-17.1
12TH	138.00												
		-27.1	-64.7	1762	3517	-15.4	-18.4	67	-28	-245.1	-488.3	22.5	-14.0
13TH	150.00												
		-26.8	-65.2	1762	3517	-15.2	-18.6	69	-28	-218.0	-423.6	17.0	-11.2
14TH	162.00												
		-26.3	-65.5	1762	3517	-14.9	-18.6	71	-28	-191.3	-358.4	12.3	-8.7
15TH	174.00												
		-25.8	-65.7	1762	3517	-14.7	-18.7	72	-28	-165.0	-292.9	8.4	-6.6
16TH	186.00												
		-25.4	-65.8	1762	3517	-14.4	-18.7	74	-29	-139.1	-227.2	5.3	-4.8
17TH	198.00												
		-24.7	-58.6	1762	3517	-14.0	-16.7	75	-32	-113.8	-161.3	2.9	-3.2
18TH	210.00												
		-24.1	-51.4	1762	3517	-13.7	-14.6	76	-36	-89.0	-102.7	1.4	-2.0
19TH	222.00												
		-23.4	-44.2	1762	3517	-13.3	-12.6	77	-41	-65.0	-51.4	.4	-1.1
MECH	234.00												
		-41.5	-7.2	2262	3733	-18.4	-1.9	9	-52	-41.5	-7.2	.1	-.5
TOP	256.25									0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS : TWO LAKEWAY CENTER														
WIND DIRECTION 330		CONFIGURATION A		REFERENCE PRESSURE 38.0 PSF		GUST FACTOR 1.32								
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00													
MEZZ	9.00	-38.9	9.3	1649	2872	-23.6	3.2	-0	-1	-950.8	-397.9	66.9	-112.3	-13.6
PONT	18.00	-43.1	7.8	1687	2921	-25.6	2.7	-1	-3	-911.9	-407.2	63.3	-103.9	-13.6
3RD	30.00	-55.6	6.8	2351	4025	-23.6	1.7	1	6	-868.8	-415.0	59.6	-95.9	-13.4
4TH	42.00	-50.6	-5.0	2282	3996	-22.2	-1.2	0	-0	-813.2	-421.7	54.6	-85.8	-13.8
5TH	54.00	-43.8	-6.6	2047	3899	-21.4	-1.7	-2	13	-762.6	-416.8	49.5	-76.4	-13.8
6TH	66.00	-48.7	-6.0	1762	3423	-27.7	-1.7	-3	22	-718.7	-410.2	44.6	-67.5	-14.3
7TH	78.00	-46.4	-10.6	1762	3517	-26.3	-3.0	-5	20	-670.0	-404.2	39.7	-59.2	-15.4
8TH	90.00	-46.5	-16.0	1762	3517	-26.4	-4.5	-4	12	-623.6	-393.6	34.9	-51.4	-16.4
9TH	102.00	-46.6	-21.4	1762	3517	-26.5	-6.1	-2	5	-577.1	-377.6	30.3	-44.2	-17.0
10TH	114.00	-46.8	-26.5	1762	3517	-26.5	-7.5	0	-1	-530.5	-356.2	25.9	-37.6	-17.3
11TH	126.00	-46.7	-27.8	1762	3517	-26.5	-7.9	3	-6	-483.7	-329.7	21.7	-31.5	-17.2
12TH	138.00	-46.6	-29.0	1762	3517	-26.4	-8.3	7	-11	-437.0	-302.0	18.0	-25.9	-16.9
13TH	150.00	-46.5	-30.3	1762	3517	-26.4	-8.6	10	-15	-390.5	-272.9	14.5	-21.0	-16.2
14TH	162.00	-46.0	-31.2	1762	3517	-26.1	-8.9	12	-18	-344.0	-242.6	11.4	-16.6	-15.2
15TH	174.00	-45.1	-31.7	1762	3517	-25.6	-9.0	14	-20	-298.0	-211.4	8.7	-12.7	-14.0
16TH	186.00	-44.3	-32.1	1762	3517	-25.1	-9.1	16	-22	-252.9	-179.8	6.3	-9.4	-12.6
17TH	198.00	-43.4	-32.6	1762	3517	-24.6	-9.3	19	-25	-208.6	-147.6	4.4	-6.6	-11.1
18TH	210.00	-40.7	-31.1	1762	3517	-23.1	-8.8	22	-28	-165.3	-115.0	2.8	-4.4	-9.4
19TH	222.00	-38.0	-29.6	1762	3517	-21.6	-8.4	25	-33	-124.6	-83.9	1.6	-2.7	-7.6
MECH	234.00	-35.4	-28.1	1762	3517	-20.1	-8.0	30	-37	-86.5	-54.3	.8	-1.4	-5.6
TOP	256.25	-51.1	-26.2	2262	3733	-22.6	-7.0	27	-53	-51.1	-26.2	.3	-.6	-3.4
										0.0	0.0	0.0	0.0	0.0

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00	-45.1	30.9	1649	2872	-27.3	10.8	9	13	-1080.0	370.5	-20.5	-127.4	72.9
MEZZ	9.00	-48.1	28.9	1687	2921	-28.5	9.9	11	19	-1034.9	339.6	-17.3	-117.8	72.0
PONT	18.00	-62.6	41.3	2351	4025	-26.6	10.3	25	38	-986.8	310.6	-14.3	-108.7	70.8
3RD	30.00	-59.2	32.9	2282	3996	-25.9	8.2	27	48	-924.2	269.4	-10.9	-97.3	67.4
4TH	42.00	-50.9	32.6	2047	3899	-24.9	8.4	42	66	-865.1	236.4	-7.8	-86.5	63.7
5TH	54.00	-51.9	41.1	1762	3423	-29.5	12.0	56	71	-814.2	203.8	-5.2	-76.5	58.9
6TH	66.00	-50.3	30.7	1762	3517	-28.6	8.7	48	78	-762.2	162.7	-3.0	-67.0	52.9
7TH	78.00	-51.2	26.6	1762	3517	-29.1	7.6	42	81	-711.9	132.0	-1.2	-58.2	47.5
8TH	90.00	-52.1	22.5	1762	3517	-29.6	6.4	36	84	-660.7	105.4	.2	-49.9	42.3
9TH	102.00	-53.0	18.7	1762	3517	-30.1	5.3	30	85	-608.5	82.9	1.3	-42.3	37.1
10TH	114.00	-53.5	18.5	1762	3517	-30.4	5.3	28	82	-555.6	64.2	2.2	-35.3	32.0
11TH	126.00	-54.1	18.2	1762	3517	-30.7	5.2	27	80	-502.0	45.7	2.9	-29.0	27.1
12TH	138.00	-54.6	18.0	1762	3517	-31.0	5.1	26	77	-448.0	27.5	3.3	-23.3	22.3
13TH	150.00	-54.5	17.3	1762	3517	-30.9	4.9	24	75	-393.3	9.4	3.5	-18.2	17.6
14TH	162.00	-53.9	14.1	1762	3517	-30.6	4.6	22	73	-338.8	-7.8	3.5	-13.8	13.1
15TH	174.00	-53.3	14.9	1762	3517	-30.2	4.2	20	71	-284.9	-23.9	3.4	-10.1	8.8
16TH	186.00	-52.6	13.6	1762	3517	-29.8	3.9	18	69	-231.7	-38.8	3.0	-7.0	4.7
17TH	198.00	-48.0	5.4	1762	3517	-27.2	1.5	6	55	-179.1	-52.4	2.4	-4.5	.8
18TH	210.00	-43.4	-2.7	1762	3517	-24.6	-.8	-2	33	-131.1	-57.8	1.8	-2.7	-1.9
19TH	222.00	-38.8	-10.8	1762	3517	-22.0	-3.1	-2	6	-87.7	-55.1	1.1	-1.4	-3.3
MECH	234.00	-48.9	-44.4	2262	3733	-21.6	-11.9	36	-40	-48.9	-44.4	.5	-.5	-3.6
TOP	256.25									0.0	0.0	0.0	0.0	0.0

		CONFIGURATION A		TWO LAKEWAY CENTER		REFERENCE PRESSURE 38.0 PSF				GUST FACTOR 1.32					
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)			
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z	
GRND	0.00	-42.3	53.4	1649	2872	-25.6	18.6	18	14	-1148.2	1173.5	-113.0	-134.8	151.1	
MEZZ	9.00	-46.2	53.2	1687	2921	-27.4	18.2	30	26	-1105.9	1120.0	-102.7	-124.7	149.6	
PONT	18.00	-64.8	79.5	2351	4025	-27.6	19.7	48	39	-1059.8	1066.9	-92.9	-114.9	146.8	
3RD	30.00	-62.4	71.6	2282	3996	-27.3	17.9	53	46	-994.9	987.4	-80.6	-102.6	140.5	
4TH	42.00	-55.8	74.8	2047	3899	-27.3	19.2	73	54	-932.5	915.8	-69.1	-91.0	133.8	
5TH	54.00	-57.0	81.5	1762	3423	-32.4	23.8	78	54	-876.7	841.0	-58.6	-80.2	125.3	
6TH	66.00	-55.4	76.6	1762	3517	-31.4	21.8	82	60	-819.7	759.6	-49.0	-70.0	115.9	
7TH	78.00	-56.2	72.6	1762	3517	-31.9	20.7	83	64	-764.3	683.0	-40.3	-60.5	106.3	
8TH	90.00	-57.0	68.7	1762	3517	-32.4	19.5	84	69	-708.1	610.3	-32.6	-51.6	96.6	
9TH	102.00	-57.8	65.1	1762	3517	-32.8	18.5	83	74	-651.1	541.7	-25.7	-43.5	86.9	
10TH	114.00	-58.9	65.2	1762	3517	-33.4	18.5	82	74	-593.2	476.6	-19.6	-36.0	77.2	
11TH	126.00	-59.9	65.3	1762	3517	-34.0	18.6	81	74	-534.4	411.4	-14.2	-29.3	67.5	
12TH	138.00	-60.9	65.4	1762	3517	-34.6	18.6	79	74	-474.5	346.1	-9.7	-23.2	57.8	
13TH	150.00	-61.1	64.5	1762	3517	-34.7	18.4	78	74	-413.6	280.7	-5.9	-17.9	48.1	
14TH	162.00	-60.6	62.9	1762	3517	-34.4	17.9	77	74	-352.5	216.2	-2.9	-13.3	38.5	
15TH	174.00	-60.2	61.3	1762	3517	-34.2	17.4	76	75	-291.8	153.2	-.7	-9.4	29.1	
16TH	186.00	-59.6	59.4	1762	3517	-33.8	16.9	75	75	-231.6	92.0	.8	-6.3	20.0	
17TH	198.00	-53.3	45.1	1762	3517	-30.2	12.8	66	78	-172.0	32.6	1.5	-3.9	11.1	
18TH	210.00	-46.9	30.8	1762	3517	-26.6	8.8	53	80	-118.8	-12.5	1.6	-2.1	4.0	
19TH	222.00	-40.6	16.6	1762	3517	-23.0	4.7	31	76	-71.9	-43.3	1.3	-1.0	-1.4	
MECH	234.00	-31.3	-59.9	2262	3733	-13.8	-16.0	66	-34	-31.3	-59.9	.7	-.3	-5.0	
TOP	256.25									0.0	0.0	0.0	0.0	0.0	

TABLE 7. THREE LAKEWAY CENTER . PROJECT #6013
 PROJECT 6013 CONFIGURATION A
 SCALE = 300 REF. PRESSURE = 38.0
 GUST FACTOR = 1.32 STANDARD FLOOR HEIGHT = 12.00
 NUMBER OF SIDES = 12 NO. OF FLOORS = 34

SIDE	ANGLE	Z-AXIS	SHFACT
1	45.0	.269	1.0
2	90.0	.240	1.0
3	180.0	4.660	1.0
4	225.0	.269	1.0
5	270.0	.240	1.0
6	0.0	4.660	1.0
7	45.0	.269	1.0
8	90.0	.240	0.0
9	180.0	4.660	0.0
10	225.0	.269	0.0
11	270.0	.240	0.0
12	0.0	4.660	0.0

FLOOR #	LABEL	HEIGHT-FT	WIND AZIMUTH	LOAD FACTOR
1	GRND	21.33	0	.71
2	PAR2	9.67	10	.77
3	PAR3	9.67	20	.83
4	PAR4	9.67	30	.89
5	PAR5	9.67	40	.96
6	PAR6	9.67	50	.98
7	PAR7	9.67	60	1.00
8	PAR8	9.67	70	1.00
9	CLUB	12.00	80	.93
10	CLUB	14.00	90	.89
11	HO11	9.67	100	.83
12	HO12	9.67	110	.85
13	HO13	9.67	120	.87
14	HO14	9.67	130	.89
15	HO15	9.67	140	.96
16	HO16	14.00	150	.93
17	OF17	12.00	160	.96
18	OF18	12.00	170	.98
19	OF19	12.00	180	1.00
20	OF20	12.00	190	.96
21	OF21	12.00	200	.89
22	OF22	12.00	210	.85
23	OF23	12.00	220	.81
24	OF24	12.00	230	.75
25	OF25	12.00	240	.71
26	OF26	12.00	250	.66
27	OF27	12.00	260	.64
28	OF28	12.00	270	.66
29	OF29	12.00	280	.66
30	OF30	12.00	290	.66
31	OF31	12.00	300	.68
32	OF32	12.00	310	.68
33	MEC1	14.00	320	.68
34	MEC2	18.00	330	.83
			340	.83
			350	.83

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									-1959.4	-946.4	247.8	-473.2	-7.4
PAR2	21.33	1.0	1.0	5698	3751	.2	.3	-72	72	-1960.5	-947.4	227.6	-431.4	-7.3
PAR3	31.00	1.1	1.1	2583	1701	.4	.6	-47	47	-1961.6	-948.5	218.4	-412.4	-7.2
PAR4	40.67	1.5	1.5	2583	1701	.6	.9	-42	42	-1963.1	-950.0	209.2	-393.4	-7.0
PAR5	50.34	1.9	1.9	2583	1701	.7	1.1	-39	39	-1965.0	-951.9	200.0	-374.5	-6.9
PAR6	60.01	2.3	2.3	2583	1701	.9	1.3	-37	37	-1967.3	-954.2	190.8	-355.4	-6.7
PAR7	69.68	2.7	2.7	2583	1701	1.0	1.6	-36	36	-1969.9	-956.9	181.6	-336.4	-6.5
PAR8	79.35	3.1	3.1	2583	1701	1.2	1.8	-35	35	-1973.0	-960.0	172.3	-317.3	-6.3
CLUB	89.02	3.3	3.4	2583	1700	1.3	2.0	-36	35	-1976.4	-963.4	163.0	-298.2	-6.1
CLUB	101.02	-75.8	-24.9	2945	1733	-25.7	-14.3	5	-16	-1900.6	-938.5	151.6	-275.0	-4.8
HO11	115.02	-79.7	-20.3	3443	2029	-23.1	-10.0	6	-23	-1820.9	-918.2	138.6	-248.9	-2.8
HO12	124.69	-55.7	-15.7	2368	1391	-23.5	-11.3	5	-17	-1765.2	-902.5	129.8	-231.6	-1.8
HO13	134.36	-60.1	-21.9	2323	1347	-25.9	-16.3	2	-6	-1705.1	-880.6	121.2	-214.8	-1.4
HO14	144.03	-63.3	-25.2	2264	1287	-28.0	-19.6	1	-4	-1641.7	-855.4	112.8	-198.6	-1.1
HO15	153.70	-63.8	-25.7	2253	1276	-28.3	-20.1	2	-4	-1578.0	-829.7	104.6	-183.1	-.8
HO16	163.37	-62.6	-25.4	2253	1276	-27.8	-19.9	2	-6	-1515.4	-804.3	96.7	-168.1	-.3
OF17	177.37	-88.4	-36.2	3261	1847	-27.1	-19.6	3	-8	-1427.0	-768.1	85.7	-147.5	.5
OF18	189.37	-73.7	-30.6	2795	1583	-26.4	-19.3	4	-11	-1353.2	-737.5	76.7	-130.8	1.4
OF19	201.37	-75.7	-33.1	2795	1583	-27.1	-20.9	4	-8	-1277.5	-704.5	68.0	-115.0	2.2
OF20	213.37	-78.0	-35.8	2795	1583	-27.9	-22.6	3	-6	-1199.5	-668.7	59.8	-100.2	2.7
OF21	225.37	-80.3	-38.5	2795	1583	-28.7	-24.3	2	-4	-1119.2	-630.2	52.0	-86.3	3.1
OF22	237.37	-82.6	-41.2	2795	1583	-29.5	-26.0	1	-1	-1036.6	-589.1	44.7	-73.3	3.2
OF23	249.37	-84.5	-43.3	2795	1583	-30.2	-27.4	-0	0	-952.1	-545.7	37.9	-61.4	3.2
OF24	261.37	-85.9	-44.8	2795	1583	-30.7	-28.3	-1	1	-866.2	-501.0	31.6	-50.5	3.1
OF25	273.37	-87.3	-46.2	2795	1583	-31.2	-29.2	-1	2	-778.9	-454.8	25.9	-40.6	2.8
		-88.7	-47.6	2795	1583	-31.7	-30.1	-2	3					

TABLE 7. SHEAR AND MOMENT DIAGRAMS : WIND DIRECTION 0														
CONFIGURATION A				THREE LANEWAY CENTER				REFERENCE PRESSURE 38.0 PSF				GUST FACTOR 1.32		
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
OF26	285.37	-89.6	-48.6	2795	1583	-32.1	-30.7	-2	4	-690.3	-407.2	20.7	-31.8	2.5
OF27	297.37	-89.9	-48.8	2795	1583	-32.2	-30.8	-2	4	-600.6	-358.6	16.1	-24.1	2.1
OF28	309.37	-90.1	-49.0	2795	1583	-32.2	-31.0	-2	4	-510.7	-309.8	12.1	-17.4	1.6
OF29	321.37	-90.3	-49.2	2795	1583	-32.3	-31.1	-2	4	-420.6	-260.8	8.7	-11.8	1.1
OF30	333.37	-89.3	-48.7	2795	1583	-32.0	-30.8	-2	4	-330.3	-211.5	5.8	-7.3	.7
OF31	345.37	-86.4	-47.2	2795	1583	-30.9	-29.8	-2	4	-241.0	-162.8	3.6	-3.9	.2
OF32	357.37	-84.1	-46.3	2795	1583	-30.1	-29.2	-3	5	-154.6	-115.6	1.9	-1.5	-.3
MEC1	369.37	-92.0	-49.7	3261	1847	-28.2	-26.9	-2	3	-70.5	-69.3	.8	-.1	-.9
MEC2	383.37													
		21.5	-19.6	2985	1355	7.2	-14.5	30	33	21.5	-19.6	.2	.2	-1.3
TOP	401.37													
										0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS : THREE LANEWAY CENTER												
WIND DIRECTION 10		CONFIGURATION A				REFERENCE PRESSURE 38.0 PSF				GUST FACTOR 1.32		
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)
		X	Y	X	Y	X	Y	X	Y	X	Y	X
GRND	0.00									-2501.4	-759.4	204.3
PAR2	21.33	-5.9	-5.9	5698	3751	-1.0	-1.6	-10	10	-2495.5	-753.4	188.2
PAR3	31.00	-2.1	-2.1	2583	1701	-.8	-1.2	-4	4	-2493.4	-751.4	180.9
PAR4	40.67	-1.7	-1.7	2583	1701	-.7	-1.0	2	-2	-2491.7	-749.7	173.7
PAR5	50.34	-1.3	-1.3	2583	1701	-.5	-.8	11	-11	-2490.4	-748.3	166.4
PAR6	60.01	-1.0	-1.0	2583	1701	-.4	-.6	28	-28	-2489.4	-747.4	159.2
PAR7	69.68	-.6	-.6	2583	1701	-.2	-.3	66	-66	-2488.8	-746.8	152.0
PAR8	79.35	-.2	-.2	2583	1701	-.1	-.1	238	-238	-2488.6	-746.6	144.7
CLUB	89.02	.0	.1	2583	1700	.0	.1	-845	97	-2488.6	-746.6	137.5
CLUB	101.02	-90.1	-5.2	2945	1733	-30.6	-3.0	1	-25	-2398.6	-741.5	128.6
H011	115.02	-106.7	-2.2	3443	2029	-31.0	-1.1	0	-23	-2291.9	-739.3	118.2
H012	124.69	-76.5	-4.6	2368	1391	-32.3	-3.3	1	-17	-2215.3	-734.7	111.1
H013	134.36	-76.1	-8.2	2323	1347	-32.8	-6.1	2	-16	-2139.2	-726.5	104.0
H014	144.03	-79.2	-15.1	2264	1287	-35.0	-11.8	3	-15	-2060.0	-711.4	97.1
H015	153.70	-81.0	-16.7	2253	1276	-36.0	-13.1	3	-16	-1979.0	-694.7	90.3
H016	163.37	-81.4	-17.3	2253	1276	-36.1	-13.5	3	-16	-1897.6	-677.4	83.6
OF17	177.37	-118.4	-25.9	3261	1847	-36.3	-14.0	4	-17	-1779.1	-651.5	74.3
OF18	189.37	-102.1	-23.1	2795	1583	-36.5	-14.6	4	-17	-1677.1	-628.3	66.7
OF19	201.37	-103.1	-25.6	2795	1583	-36.9	-16.2	4	-15	-1574.0	-602.7	59.3
OF20	213.37	-104.1	-28.3	2795	1583	-37.2	-17.9	4	-14	-1469.9	-574.4	52.2
OF21	225.37	-105.1	-30.9	2795	1583	-37.6	-19.5	4	-12	-1364.7	-543.5	45.5
OF22	237.37	-106.2	-33.6	2795	1583	-38.0	-21.2	3	-11	-1258.5	-509.9	39.2
OF23	249.37	-107.1	-35.7	2795	1583	-38.3	-22.6	3	-9	-1151.4	-474.2	33.3
OF24	261.37	-107.8	-37.3	2795	1583	-38.6	-23.6	3	-9	-1043.6	-436.8	27.8
OF25	273.37	-108.6	-38.9	2795	1583	-38.9	-24.6	3	-8	-935.0	-397.9	22.8
		-109.4	-40.5	2795	1583	-39.1	-25.6	3	-7			

TABLE 7. SHEAR AND MOMENT DIAGRAMS 1														
WIND DIRECTION 10		THREE LAKEWAY CENTER								GUST FACTOR 1.32				
		CONFIGURATION A				REFERENCE PRESSURE 38.0 PSF								
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
OF26	285.37	-109.8	-41.7	2795	1583	-39.3	-26.3	3	-7	-825.7	-357.4	18.3	-37.3	-8.8
OF27	297.37	-109.6	-42.3	2795	1583	-39.2	-26.7	3	-7	-715.9	-315.7	14.2	-28.1	-8.0
OF28	309.37	-109.4	-42.9	2795	1583	-39.1	-27.1	3	-7	-606.3	-273.4	10.7	-20.2	-7.1
OF29	321.37	-109.2	-43.5	2795	1583	-39.1	-27.5	3	-7	-496.9	-230.5	7.7	-13.5	-6.3
OF30	333.37	-107.5	-43.1	2795	1583	-38.5	-27.2	3	-7	-387.7	-187.0	5.2	-8.2	-5.5
OF31	345.37	-103.5	-41.3	2795	1583	-37.0	-26.1	3	-7	-280.2	-144.0	3.2	-4.2	-4.6
OF32	357.37	-101.3	-41.2	2795	1583	-36.2	-26.0	2	-5	-176.7	-102.7	1.7	-1.5	-3.8
MEC1	369.37	-109.9	-43.3	3261	1847	-33.7	-23.5	3	-7	-75.4	-61.5	.7	.0	-3.3
MEC2	383.37	34.5	-18.1	2985	1355	11.6	-13.4	29	55	34.5	-18.1	.2	.3	-2.4
TOP	401.37									0.0	0.0	0.0	0.0	0.0

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									-2858.0	-488.5	125.8	-662.7	-67.0
PAR2	21.33	-13.9	-13.9	5698	3751	-2.4	-3.7	-18	18	-2844.1	-474.6	115.5	-601.8	-67.5
PAR3	31.00	-5.7	-5.7	2583	1701	-2.2	-3.4	-16	16	-2838.4	-468.9	111.0	-574.4	-67.7
PAR4	40.67	-5.3	-5.3	2583	1701	-2.1	-3.1	-15	15	-2833.0	-463.5	106.5	-546.9	-67.8
PAR5	50.34	-5.0	-5.0	2583	1701	-1.9	-2.9	-14	14	-2828.1	-458.5	102.0	-519.6	-68.0
PAR6	60.01	-4.6	-4.6	2583	1701	-1.8	-2.7	-12	12	-2823.5	-453.9	97.6	-492.3	-68.1
PAR7	69.68	-4.2	-4.2	2583	1701	-1.6	-2.5	-11	11	-2819.2	-449.7	93.2	-465.0	-68.2
PAR8	79.35	-3.9	-3.9	2583	1701	-1.5	-2.3	-9	9	-2815.4	-445.9	88.9	-437.7	-68.2
PAR8	79.35	-3.6	-3.5	2583	1700	-1.4	-2.0	-5	5	-2811.8	-442.4	84.6	-410.5	-68.3
CLUB	89.02	-103.7	1.2	2945	1733	-35.2	.7	-0	-29	-2708.0	-443.6	79.3	-377.4	-65.3
CLUB	101.02	-131.4	-.6	3443	2029	-38.2	-.3	0	-21	-2576.6	-443.0	73.1	-340.4	-62.6
HO11	115.02	-92.5	-1.7	2368	1391	-39.1	-1.2	0	-18	-2484.1	-441.3	68.8	-315.9	-60.9
HO12	124.69	-88.8	-1.1	2323	1347	-38.2	-.8	0	-24	-2395.3	-440.1	64.6	-292.3	-58.7
HO13	134.36	-89.7	-7.8	2264	1287	-39.6	-6.1	2	-25	-2305.5	-432.3	60.3	-269.6	-56.5
HO14	144.03	-91.3	-9.7	2253	1276	-40.6	-7.6	3	-25	-2214.2	-422.7	56.2	-247.8	-54.2
HO15	153.70	-92.2	-10.4	2253	1276	-40.9	-8.2	3	-25	-2122.0	-412.3	52.2	-226.8	-51.8
HO16	163.37	-134.9	-16.4	3261	1847	-41.4	-8.9	3	-25	-1987.1	-395.9	46.5	-198.0	-48.4
OF17	177.37	-117.0	-15.3	2795	1583	-41.8	-9.7	3	-25	-1870.2	-380.6	41.9	-174.9	-45.5
OF18	189.37	-117.8	-16.1	2795	1583	-42.1	-10.2	3	-24	-1752.4	-364.5	37.4	-153.2	-42.6
OF19	201.37	-118.6	-16.9	2795	1583	-42.4	-10.7	3	-24	-1633.8	-347.6	33.1	-132.8	-39.8
OF20	213.37	-119.4	-17.7	2795	1583	-42.7	-11.2	3	-23	-1514.5	-329.8	29.0	-113.9	-36.9
OF21	225.37	-120.1	-18.5	2795	1583	-43.0	-11.7	3	-23	-1394.3	-311.3	25.2	-96.5	-34.2
OF22	237.37	-120.7	-19.3	2795	1583	-43.2	-12.2	4	-22	-1273.6	-292.0	21.6	-80.5	-31.4
OF23	249.37	-121.0	-20.2	2795	1583	-43.3	-12.7	4	-22	-1152.6	-271.8	18.2	-65.9	-28.7
OF24	261.37	-121.3	-21.0	2795	1583	-43.4	-13.2	4	-21	-1031.2	-250.8	15.1	-52.8	-26.1
OF25	273.37	-121.7	-21.8	2795	1583	-43.5	-13.8	4	-21					

TABLE 7. SHEAR AND MOMENT DIAGRAMS : THREE LAKEWAY CENTER															
WIND DIRECTION 20		CONFIGURATION A		REFERENCE PRESSURE 38.0 PSF									GUST FACTOR 1.32		
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)			
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z	
OF26	285.37	-121.6	-23.0	2795	1583	-43.5	-14.5	4	-21	-909.6	-229.1	12.2	-41.2	-23.5	
OF27	297.37	-121.1	-24.7	2795	1583	-43.3	-15.6	4	-20	-788.0	-206.1	9.6	-31.0	-20.9	
OF28	309.37	-120.5	-26.5	2795	1583	-43.1	-16.8	4	-20	-666.9	-181.4	7.2	-22.3	-18.3	
OF29	321.37	-119.9	-28.3	2795	1583	-42.9	-17.9	5	-20	-546.4	-154.8	5.2	-15.0	-15.7	
OF30	333.37	-117.7	-28.7	2795	1583	-42.1	-18.1	5	-20	-426.5	-126.5	3.5	-9.2	-13.2	
OF31	345.37	-112.6	-26.7	2795	1583	-40.3	-16.9	5	-22	-308.8	-97.8	2.2	-4.7	-10.7	
OF32	357.37	-110.6	-27.9	2795	1583	-39.6	-17.6	5	-19	-196.3	-71.1	1.2	-1.7	-8.1	
MEC1	369.37	-122.1	-31.0	3261	1847	-37.4	-16.8	5	-19	-85.6	-43.1	.5	-.0	-5.9	
MEC2	383.37	36.5	-12.2	2985	1355	12.2	-9.0	27	82	36.5	-12.2	.1	.3	-3.3	
TOP	401.37									0.0	0.0	0.0	0.0	0.0	

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00	-17.5	-17.5	3698	3751	-3.1	-4.7	-20	20	-3179.9	-326.1	72.8	-733.1	-101.7
PAR2	21.33	-7.5	-7.5	2583	1701	-2.9	-4.4	-19	19	-3162.4	-308.7	66.0	-665.5	-102.4
PAR3	31.00	-7.2	-7.2	2583	1701	-2.8	-4.2	-18	18	-3154.9	-301.2	63.1	-634.9	-102.6
PAR4	40.67	-6.9	-6.9	2583	1701	-2.7	-4.1	-17	17	-3147.7	-294.0	60.2	-604.4	-102.9
PAR5	50.34	-6.7	-6.7	2583	1701	-2.6	-3.9	-17	17	-3140.8	-287.1	57.4	-574.0	-103.1
PAR6	60.01	-6.4	-6.4	2583	1701	-2.5	-3.7	-16	16	-3134.1	-280.4	54.6	-543.7	-103.4
PAR7	69.68	-6.1	-6.1	2583	1701	-2.4	-3.6	-15	15	-3127.8	-274.0	51.9	-513.4	-103.6
PAR8	79.35	-6.0	-5.8	2583	1700	-2.3	-3.4	-13	14	-3121.7	-267.9	49.3	-483.2	-103.7
CLUB	89.02	-117.9	4.3	2945	1733	-40.0	2.5	-1	-34	-3115.7	-262.1	46.8	-453.0	-103.9
CLUB	101.02	-146.8	-1.1	3443	2029	-42.7	-1.1	0	-26	-2997.7	-266.4	43.6	-416.4	-99.9
H011	115.02	-103.7	-2.5	2368	1391	-43.8	-1.8	1	-22	-2850.9	-266.3	39.9	-375.4	-96.2
H012	124.69	-99.9	-1.4	2323	1347	-43.0	-1.1	0	-27	-2747.2	-263.7	37.3	-348.4	-93.9
H013	134.36	-99.6	-7.7	2264	1287	-44.0	-6.0	2	-30	-2647.3	-262.3	34.7	-322.3	-91.1
H014	144.03	-101.1	-9.1	2253	1276	-44.9	-7.2	3	-31	-2547.7	-254.6	32.3	-297.2	-88.1
H015	153.70	-102.4	-9.4	2253	1276	-45.4	-7.4	3	-31	-2446.6	-245.5	29.8	-273.0	-84.9
H016	163.37	-150.5	-14.1	3261	1847	-46.1	-7.6	3	-31	-2344.2	-236.1	27.5	-249.8	-81.7
OF17	177.37	-131.1	-12.5	2795	1583	-46.9	-7.9	3	-31	-2193.7	-222.0	24.3	-218.1	-77.0
OF18	189.37	-131.5	-12.3	2795	1583	-47.1	-7.8	3	-31	-2062.6	-209.6	21.7	-192.5	-72.9
OF19	201.37	-131.8	-12.1	2795	1583	-47.2	-7.6	3	-31	-1931.0	-197.2	19.3	-168.6	-68.8
OF20	213.37	-132.1	-11.9	2795	1583	-47.3	-7.5	3	-31	-1799.2	-185.1	17.0	-146.2	-64.7
OF21	225.37	-132.4	-11.7	2795	1583	-47.4	-7.4	3	-31	-1667.1	-173.3	14.8	-125.4	-60.5
OF22	237.37	-132.7	-11.6	2795	1583	-47.5	-7.3	3	-31	-1534.8	-161.6	12.8	-106.2	-56.4
OF23	249.37	-133.2	-11.7	2795	1583	-47.7	-7.4	3	-32	-1402.0	-150.0	10.9	-88.6	-52.2
OF24	261.37	-133.7	-11.9	2795	1583	-47.8	-7.5	3	-32	-1268.8	-138.3	9.2	-72.5	-47.9
OF25	273.37	-134.2	-12.0	2795	1583	-48.0	-7.6	3	-32	-1135.0	-126.4	7.6	-58.1	-43.6

TABLE 7. SHEAR AND MOMENT DIAGRAMS : THREE LAKEWAY CENTER															
WIND DIRECTION 30		CONFIGURATION A		REFERENCE PRESSURE 38.0 PSF									GUST FACTOR 1.32		
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)			
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z	
OF26	285.37	-134.3	-12.2	2795	1583	-48.0	-7.7	3	-32	-1000.8	-114.4	6.2	-45.3	-39.3	
OF27	297.37	-133.7	-12.5	2795	1583	-47.8	-7.9	3	-33	-866.5	-102.2	4.9	-34.1	-34.9	
OF28	309.37	-133.1	-12.8	2795	1583	-47.6	-8.1	3	-33	-732.8	-89.7	3.7	-24.5	-30.5	
OF29	321.37	-132.4	-13.2	2795	1583	-47.4	-8.3	3	-33	-599.7	-76.9	2.7	-16.5	-26.1	
OF30	333.37	-129.6	-13.0	2795	1583	-46.4	-8.2	3	-34	-467.3	-63.7	1.9	-10.1	-21.7	
OF31	345.37	-122.3	-11.6	2795	1583	-43.7	-7.3	3	-37	-337.7	-50.7	1.2	-5.3	-17.2	
OF32	357.37	-119.1	-14.3	2795	1583	-42.6	-9.0	4	-34	-215.5	-39.1	.7	-2.0	-12.7	
MEC1	369.37	-132.9	-18.4	3261	1847	-40.8	-9.9	4	-33	-96.4	-24.8	.3	-.1	-8.6	
MEC2	383.37	36.6	-6.5	2985	1355	12.3	-4.8	20	112	36.6	-6.5	.1	.3	-4.2	
TOP	401.37									0.0	0.0	0.0	0.0	0.0	

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									-3659.3	-387.7	81.0	-839.8	-136.3
PAR2	21.33	-19.1	-19.1	5698	3751	-3.3	-5.1	-20	20	-3640.2	-368.6	73.0	-762.0	-137.1
PAR3	31.00	-8.2	-8.2	2583	1701	-3.2	-4.8	-20	20	-3632.0	-360.4	69.4	-726.8	-137.4
PAR4	40.67	-7.9	-7.9	2583	1701	-3.1	-4.7	-19	19	-3624.1	-352.5	66.0	-691.7	-137.7
PAR5	50.34	-7.6	-7.6	2583	1701	-3.0	-4.5	-19	19	-3616.4	-344.8	62.6	-656.7	-138.0
PAR6	60.01	-7.4	-7.4	2583	1701	-2.9	-4.3	-18	18	-3609.1	-337.5	59.3	-621.8	-138.2
PAR7	69.68	-7.1	-7.1	2583	1701	-2.7	-4.2	-17	17	-3602.0	-330.4	56.1	-586.9	-138.5
PAR8	79.35	-6.8	-6.8	2583	1701	-2.6	-4.0	-17	17	-3595.2	-323.6	52.9	-552.1	-138.7
PAR8	79.35	-6.7	-6.5	2583	1700	-2.6	-3.8	-15	15	-3588.4	-317.1	49.8	-517.4	-138.9
CLUB	89.02	-140.4	3.5	2945	1733	-47.7	2.0	-1	-36	-3448.0	-320.5	46.0	-475.2	-133.9
CLUB	101.02	-173.6	-3.6	3443	2029	-50.4	-1.8	1	-29	-3274.4	-317.0	41.5	-428.1	-128.8
H011	115.02	-122.9	-6.7	2368	1391	-51.9	-4.8	1	-27	-3151.5	-310.3	38.5	-397.0	-125.5
H012	124.69	-119.6	-7.3	2323	1347	-51.5	-5.4	2	-31	-3031.8	-303.0	35.6	-367.1	-121.7
H013	134.36	-117.8	-13.0	2264	1287	-52.1	-10.1	4	-34	-2914.0	-290.1	32.7	-338.4	-117.6
H014	144.03	-118.3	-14.0	2253	1276	-52.5	-11.0	4	-35	-2795.7	-276.1	29.9	-310.8	-113.4
H015	153.70	-119.0	-13.9	2253	1276	-52.8	-10.9	4	-35	-2676.7	-262.2	27.3	-284.3	-109.2
H016	163.37	-173.7	-19.8	3261	1847	-53.2	-10.7	4	-35	-2503.0	-242.4	23.8	-248.1	-103.0
OF17	177.37	-150.1	-16.8	2795	1583	-53.7	-10.6	4	-35	-2352.9	-225.6	21.0	-218.9	-97.7
OF18	189.37	-150.7	-16.4	2795	1583	-53.9	-10.4	4	-35	-2202.2	-209.2	18.4	-191.6	-92.3
OF19	201.37	-151.2	-16.0	2795	1583	-54.1	-10.1	4	-35	-2051.0	-193.2	16.0	-166.1	-86.9
OF20	213.37	-151.8	-15.6	2795	1583	-54.3	-9.8	4	-36	-1899.2	-177.6	13.8	-142.4	-81.5
OF21	225.37	-152.4	-15.1	2795	1583	-54.5	-9.6	4	-36	-1746.8	-162.5	11.7	-120.5	-76.0
OF22	237.37	-152.7	-14.8	2795	1583	-54.6	-9.3	3	-36	-1594.1	-147.7	9.9	-100.5	-70.4
OF23	249.37	-152.9	-14.4	2795	1583	-54.7	-9.1	3	-36	-1441.2	-133.3	8.2	-82.2	-64.8
OF24	261.37	-153.0	-14.1	2795	1583	-54.7	-8.9	3	-37	-1288.1	-119.2	6.7	-65.9	-59.2
OF25	273.37	-153.2	-13.8	2795	1583	-54.8	-8.7	3	-37					

TABLE 7. SHEAR AND MOMENT DIAGRAMS : THREE LAKEWAY CENTER														
WIND DIRECTION 40		CONFIGURATION A				REFERENCE PRESSURE 38.0 PSF						GUST FACTOR 1.32		
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
OF26	285.37	-152.9	-13.5	2795	1583	-54.7	-8.5	3	-37	-1135.0	-105.3	5.3	-51.3	-53.5
OF27	297.37	-152.1	-13.2	2795	1583	-54.4	-8.4	3	-38	-982.1	-91.8	4.1	-38.6	-47.7
OF28	309.37	-151.2	-13.0	2795	1583	-54.1	-8.2	3	-39	-830.0	-78.6	3.1	-27.8	-41.9
OF29	321.37	-150.4	-12.7	2795	1583	-53.8	-8.0	3	-40	-678.8	-65.6	2.2	-18.7	-36.0
OF30	333.37	-147.1	-11.9	2795	1583	-52.6	-7.5	3	-41	-528.4	-52.9	1.5	-11.5	-30.0
OF31	345.37	-138.1	-9.4	2795	1583	-49.4	-5.9	3	-45	-381.3	-41.0	1.0	-6.0	-23.9
OF32	357.37	-133.6	-11.2	2795	1583	-47.8	-7.1	4	-44	-243.2	-31.6	.5	-2.3	-17.6
MEC1	369.37	-148.9	-15.9	3261	1847	-45.7	-8.6	5	-43	-109.6	-20.3	.2	-.1	-11.7
MEC2	383.37									39.3	-4.4	.0	.4	-5.2
		39.3	-4.4	2985	1355	13.2	-3.3	15	131					
TOP	401.37									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 50

THREE LAKEWAY CENTER

CONFIGURATION A

REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00	-15.5	-15.5	5698	3751	-2.7	-4.1	-20	20	-3868.2	-485.1	104.1	-884.0	-176.6
PAR2	21.33	-6.7	-6.7	2583	1701	-2.6	-3.9	-19	19	-3852.8	-469.7	94.0	-801.7	-177.2
PAR3	31.00	-6.4	-6.4	2583	1701	-2.5	-3.8	-19	19	-3846.1	-463.0	89.4	-764.4	-177.4
PAR4	40.67	-6.2	-6.2	2583	1701	-2.4	-3.7	-18	18	-3839.7	-456.6	85.0	-727.3	-177.7
PAR5	50.34	-6.0	-6.0	2583	1701	-2.3	-3.5	-17	17	-3833.5	-450.4	80.6	-690.2	-177.9
PAR6	60.01	-5.8	-5.8	2583	1701	-2.2	-3.4	-17	17	-3827.5	-444.4	76.3	-653.1	-178.1
PAR7	69.68	-5.5	-5.5	2583	1701	-2.1	-3.3	-16	16	-3821.7	-438.6	72.0	-616.1	-178.3
PAR8	79.35	-5.6	-5.3	2583	1700	-2.2	-3.1	-13	14	-3816.2	-433.1	67.8	-579.2	-178.5
CLUB	89.02	-154.8	3.2	2945	1733	-52.6	1.9	-1	-40	-3810.6	-427.8	63.6	-542.3	-178.6
CLUB	101.02	-189.1	-7.5	3443	2029	-54.9	-3.7	1	-35	-3655.8	-431.0	58.5	-497.5	-172.5
H011	115.02	-133.6	-10.7	2368	1391	-56.4	-7.7	3	-34	-3466.7	-423.5	52.5	-447.7	-165.8
H012	124.69	-130.8	-14.3	2323	1347	-56.3	-10.6	4	-38	-3333.1	-412.9	48.5	-414.8	-161.3
H013	134.36	-129.8	-19.8	2264	1287	-57.3	-15.4	6	-39	-3202.3	-398.6	44.5	-383.2	-156.2
H014	144.03	-130.1	-20.3	2253	1276	-57.7	-15.9	6	-40	-3072.5	-378.8	40.8	-352.9	-151.0
H015	153.70	-129.8	-19.7	2253	1276	-57.6	-15.4	6	-41	-2942.5	-358.5	37.2	-323.8	-145.7
H016	163.37	-187.3	-27.4	3261	1847	-57.4	-14.8	6	-42	-2812.7	-338.7	33.8	-296.0	-140.2
OF17	177.37	-160.0	-22.5	2795	1583	-57.2	-14.2	6	-43	-2625.4	-311.3	29.3	-257.9	-132.2
OF18	189.37	-160.4	-21.9	2795	1583	-57.4	-13.8	6	-43	-2465.4	-288.8	25.7	-227.3	-125.1
OF19	201.37	-160.8	-21.4	2795	1583	-57.5	-13.5	6	-44	-2305.0	-266.9	22.4	-198.7	-118.0
OF20	213.37	-161.2	-20.8	2795	1583	-57.7	-13.2	6	-44	-2144.2	-245.6	19.3	-172.0	-110.9
OF21	225.37	-161.6	-20.3	2795	1583	-57.8	-12.8	6	-44	-1983.0	-224.7	16.5	-147.3	-103.7
OF22	237.37	-161.8	-19.9	2795	1583	-57.9	-12.6	5	-44	-1821.4	-204.4	13.9	-124.4	-96.5
OF23	249.37	-161.8	-19.6	2795	1583	-57.9	-12.4	5	-44	-1659.6	-184.5	11.5	-103.6	-89.3
OF24	261.37	-161.7	-19.3	2795	1583	-57.8	-12.2	5	-44	-1497.9	-165.0	9.5	-84.6	-82.0
OF25	273.37	-161.7	-19.0	2795	1583	-57.8	-12.0	5	-45	-1336.2	-145.7	7.6	-67.6	-74.7

TABLE 7. SHEAR AND MOMENT DIAGRAMS : THREE LAKEWAY CENTER														
WIND DIRECTION 50°		CONFIGURATION A				REFERENCE PRESSURE 38.0 PSF				GUST FACTOR 1.32				
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
OF26	285.37	-161.1	-18.5	2795	1583	-57.6	-11.7	5	-45	-1174.5	-126.7	6.0	-52.5	-67.4
OF27	297.37	-159.6	-17.8	2795	1583	-57.1	-11.2	5	-46	-1013.4	-108.2	4.5	-39.4	-60.1
OF28	309.37	-158.1	-17.0	2795	1583	-56.6	-10.8	5	-46	-853.9	-90.4	3.4	-28.2	-52.7
OF29	321.37	-156.6	-16.3	2795	1583	-56.0	-10.3	5	-47	-695.7	-73.3	2.4	-18.9	-45.3
OF30	333.37	-152.2	-14.5	2795	1583	-54.5	-9.2	5	-49	-539.1	-57.0	1.6	-11.5	-37.8
OF31	345.37	-141.7	-10.3	2795	1583	-50.7	-6.5	4	-55	-386.8	-42.5	1.0	-5.9	-30.2
OF32	357.37	-136.3	-11.1	2795	1583	-48.8	-7.0	5	-55	-245.1	-32.2	.5	-2.2	-22.4
MEC1	369.37	-134.4	-16.5	3261	1847	-47.3	-8.9	6	-54	-108.8	-21.1	.2	-.0	-14.8
MEC2	383.37	45.6	-4.6	2985	1355	15.3	-3.4	14	137	45.6	-4.6	.0	.4	-6.3
TOP	401.37									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS : WIND DIRECTION 60														
CONFIGURATION A				THREE LAKEWAY CENTER				REFERENCE PRESSURE 38.0 PSF				GUST FACTOR 1.32		
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00													
PAR2	21.33	-10.5	-10.5	5698	3751	-1.8	-2.8	-16	16	-3705.6	-823.6	188.6	-840.9	-225.4
PAR3	31.00	-4.3	-4.3	2583	1701	-1.6	-2.5	-15	15	-3695.1	-813.1	171.1	-762.0	-225.7
PAR4	40.67	-4.0	-4.0	2583	1701	-1.5	-2.3	-14	14	-3690.9	-808.8	163.3	-726.3	-225.8
PAR5	50.34	-3.7	-3.7	2583	1701	-1.4	-2.2	-13	13	-3686.9	-804.9	155.5	-690.6	-226.0
PAR6	60.01	-3.4	-3.4	2583	1701	-1.3	-2.0	-12	12	-3683.3	-801.2	147.7	-655.0	-226.1
PAR7	69.68	-3.1	-3.1	2583	1701	-1.2	-1.8	-11	11	-3679.9	-797.9	140.0	-619.4	-226.1
PAR8	79.35	-2.8	-2.8	2583	1701	-1.1	-1.6	-9	9	-3676.8	-794.8	132.3	-583.8	-226.2
CLUB	89.02	-2.7	-2.4	2583	1700	-1.0	-1.4	-4	5	-3674.1	-792.0	124.6	-548.3	-226.3
CLUB	101.02	-153.1	-4.3	2945	1733	-52.0	-2.5	1	-43	-3671.4	-789.6	117.0	-512.7	-226.3
H011	115.02	-187.7	-22.7	3443	2029	-54.5	-11.2	5	-42	-3518.3	-785.3	107.5	-469.6	-219.7
H012	124.69	-133.2	-23.9	2368	1391	-56.3	-17.1	8	-43	-3330.6	-762.6	96.7	-421.7	-211.7
H013	134.36	-130.2	-29.3	2323	1347	-56.0	-21.7	11	-49	-3197.4	-738.8	89.4	-390.1	-205.9
H014	144.03	-129.8	-34.2	2264	1287	-57.3	-26.6	13	-50	-3067.3	-709.5	82.4	-359.8	-199.1
H015	153.70	-130.2	-34.4	2253	1276	-57.8	-27.0	13	-51	-2937.4	-675.3	75.7	-330.8	-192.1
H016	163.37	-129.5	-33.6	2253	1276	-57.5	-26.3	13	-52	-2807.3	-640.9	69.4	-303.0	-185.1
OF17	177.37	-186.2	-47.1	3261	1847	-57.1	-25.5	13	-53	-2677.8	-607.3	63.3	-276.5	-177.9
OF18	189.37	-158.4	-38.9	2795	1583	-56.7	-24.6	14	-55	-2491.6	-560.2	55.2	-240.3	-167.4
OF19	201.37	-157.6	-37.8	2795	1583	-56.4	-23.9	13	-55	-2333.1	-521.3	48.7	-211.3	-158.1
OF20	213.37	-156.8	-36.6	2795	1583	-56.1	-23.1	13	-56	-2175.5	-483.5	42.6	-184.3	-148.9
OF21	225.37	-156.0	-35.4	2795	1583	-55.8	-22.4	13	-56	-2018.8	-446.9	37.1	-159.1	-139.7
OF22	237.37	-155.1	-34.3	2795	1583	-55.5	-21.7	13	-57	-1862.8	-411.4	31.9	-135.8	-130.5
OF23	249.37	-154.6	-33.4	2795	1583	-55.3	-21.1	12	-57	-1707.6	-377.1	27.2	-114.4	-121.3
OF24	261.37	-154.4	-32.9	2795	1583	-55.2	-20.8	12	-57	-1553.0	-343.7	22.9	-94.9	-112.0
OF25	273.37	-154.3	-32.4	2795	1583	-55.2	-20.4	12	-58	-1398.6	-310.8	18.9	-77.1	-102.8
		-154.1	-31.9	2795	1583	-55.1	-20.1	12	-58	-1244.3	-278.5	15.4	-61.3	-93.5

TABLE 7. SHEAR AND MOMENT DIAGRAMS : WIND DIRECTION 60 CONFIGURATION A THREE LANEWAY CENTER REFERENCE PRESSURE 38.0 PSF GUST FACTOR 1.32														
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
OF26	285.37	-153.4	-31.5	2795	1583	-54.9	-19.9	12	-59	-1090.2	-246.6	12.2	-47.3	-84.1
OF27	297.37	-151.9	-31.4	2795	1583	-54.3	-19.8	12	-59	-936.8	-215.1	9.5	-35.1	-74.7
OF28	309.37	-150.4	-31.2	2795	1583	-53.8	-19.7	12	-60	-784.9	-183.7	7.1	-24.8	-65.3
OF29	321.37	-148.9	-31.1	2795	1583	-53.3	-19.7	13	-61	-634.5	-152.5	5.1	-16.3	-55.9
OF30	333.37	-144.4	-29.5	2795	1583	-51.7	-16.6	13	-63	-485.6	-121.4	3.4	-9.5	-46.4
OF31	345.37	-133.9	-24.6	2795	1583	-47.9	-15.6	13	-69	-341.1	-91.8	2.1	-4.6	-37.0
OF32	357.37	-126.5	-23.0	2795	1583	-45.2	-14.5	13	-72	-207.3	-67.2	1.2	-1.3	-27.4
MEC1	369.37	-143.2	-31.2	3261	1847	-43.9	-16.9	15	-71	-80.8	-44.2	.5	.4	-18.0
MEC2	383.37									62.4	-13.0	.1	.6	-7.4
		62.4	-13.0	2985	1355	20.9	-9.6	24	113					
TOP	401.37									0.0	0.0	0.0	0.0	0.0

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00	-6.9	-6.9	5698	3751	-1.2	-1.8	-12	12	-3161.0	-637.7	150.4	-710.5	-250.0
PAR2	21.33	-2.8	-2.8	2583	1701	-1.1	-1.7	-10	10	-3154.1	-630.8	136.9	-643.2	-250.2
PAR3	31.00	-2.6	-2.6	2583	1701	-1.0	-1.5	-9	9	-3151.3	-628.0	130.8	-612.7	-250.3
PAR4	40.67	-2.4	-2.4	2583	1701	-0.9	-1.4	-7	7	-3148.7	-625.4	124.8	-582.2	-250.3
PAR5	50.34	-2.2	-2.2	2583	1701	-0.9	-1.3	-6	6	-3146.3	-623.0	118.7	-551.8	-250.3
PAR6	60.01	-2.0	-2.0	2583	1701	-0.8	-1.2	-4	4	-3144.1	-620.8	112.7	-521.4	-250.4
PAR7	69.68	-1.8	-1.8	2583	1701	-0.7	-1.1	-1	1	-3142.1	-618.8	106.7	-491.0	-250.4
PAR8	79.35	-1.8	-1.6	2583	1700	-0.7	-0.9	5	-6	-3140.3	-617.0	100.7	-460.6	-250.4
CLUB	89.02	-134.6	6.0	2945	1733	-45.7	3.5	-2	-49	-3138.5	-615.5	94.8	-430.2	-250.4
CLUB	101.02	-167.1	-10.9	3443	2029	-48.5	-5.4	3	-51	-3003.9	-621.5	87.4	-393.4	-243.7
H011	115.02	-117.5	-13.9	2368	1391	-49.6	-10.0	7	-56	-2836.8	-610.7	78.7	-352.5	-235.2
H012	124.69	-113.6	-21.6	2323	1347	-48.9	-16.0	13	-66	-2719.3	-596.8	72.9	-325.6	-228.6
H013	134.36	-112.5	-26.2	2264	1287	-49.7	-20.4	16	-68	-2605.7	-575.2	67.2	-299.9	-220.8
H014	144.03	-112.7	-26.9	2253	1276	-50.0	-21.1	16	-69	-2493.2	-549.0	61.8	-275.2	-212.6
H015	153.70	-112.0	-26.5	2253	1276	-49.7	-20.7	16	-69	-2380.6	-522.1	56.6	-251.7	-204.5
H016	163.37	-160.9	-37.6	3261	1847	-49.4	-20.3	16	-70	-2268.6	-495.7	51.7	-229.2	-196.3
OF17	177.37	-136.8	-31.5	2795	1583	-49.0	-19.9	16	-70	-2107.6	-458.1	45.0	-198.6	-184.4
OF18	189.37	-136.1	-30.7	2795	1583	-48.7	-19.4	16	-71	-1970.8	-426.6	39.7	-174.1	-174.3
OF19	201.37	-135.4	-29.9	2795	1583	-48.4	-18.9	16	-72	-1834.7	-395.9	34.8	-151.2	-164.1
OF20	213.37	-134.6	-29.0	2795	1583	-48.2	-18.3	16	-72	-1699.4	-366.1	30.2	-130.0	-153.9
OF21	225.37	-133.9	-28.2	2795	1583	-47.9	-17.8	15	-73	-1564.7	-337.1	26.0	-110.5	-143.7
OF22	237.37	-133.3	-27.6	2795	1583	-47.7	-17.4	15	-74	-1430.9	-308.8	22.1	-92.5	-133.5
OF23	249.37	-132.9	-27.4	2795	1583	-47.5	-17.3	15	-74	-1297.6	-281.2	18.6	-76.1	-123.2
OF24	261.37	-132.4	-27.1	2795	1583	-47.4	-17.1	15	-74	-1164.7	-253.8	15.4	-61.3	-113.0
OF25	273.37	-132.0	-26.9	2795	1583	-47.2	-17.0	15	-74	-1032.3	-226.7	12.5	-48.2	-102.7

TABLE 7. SHEAR AND MOMENT DIAGRAMS : THREE LAKEWAY CENTER														
WIND DIRECTION 70		CONFIGURATION A		REFERENCE PRESSURE 38.0 PSF										
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		GUST FACTOR 1.32		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
OF26	285.37									-900.3	-199.9	9.9	-36.6	-92.5
OF27	297.37	-131.4	-26.4	2795	1583	-47.0	-16.7	15	-75	-768.9	-173.5	7.7	-26.6	-82.3
OF28	309.37	-130.3	-25.6	2795	1583	-46.6	-16.2	15	-76	-638.6	-147.9	5.7	-18.1	-72.0
OF29	321.37	-129.3	-24.8	2795	1583	-46.3	-15.7	15	-77	-509.2	-123.1	4.1	-11.2	-61.7
OF30	333.37	-128.3	-24.0	2795	1583	-45.9	-15.2	15	-78	-381.0	-99.1	2.8	-5.9	-51.4
OF31	345.37	-125.0	-22.9	2795	1583	-44.7	-14.5	15	-80	-256.0	-76.1	1.7	-2.1	-41.1
OF32	357.37	-117.3	-21.1	2795	1583	-42.0	-13.3	16	-86	-138.6	-55.0	1.0	.3	-30.6
MEC1	369.37	-109.8	-19.5	2795	1583	-39.3	-12.3	17	-94	-28.8	-35.5	.4	1.3	-19.9
MEC2	383.37	-123.7	-25.3	3261	1847	-37.9	-13.7	19	-92	94.9	-10.1	.1	.9	-8.1
TOP	401.37	94.9	-10.1	2985	1355	31.8	-7.5	9	84	0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS :		THREE LAKEWAY CENTER										GUST FACTOR 1.32		
WIND DIRECTION 80		CONFIGURATION A										REFERENCE PRESSURE 38.0 PSF		
		FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00													
PAR2	21.33	-2.8	-2.8	5698	3751	-1.5	-1.8	3	-3	-2422.1	533.1	-128.9	-543.5	-206.3
PAR3	31.00	-1.9	-1.9	2583	1701	-1.3	-1.5	19	-19	-2419.3	536.0	-117.5	-491.8	-206.3
PAR4	40.67	-1.6	-1.6	2583	1701	-1.2	-1.3	40	-40	-2418.4	536.8	-112.4	-468.4	-206.3
PAR5	50.34	-1.3	-1.3	2583	1701	-1.1	-1.2	97	-97	-2417.9	537.4	-107.2	-445.0	-206.2
PAR6	60.01	-1.0	-1.0	2583	1701	-1.0	-1.0	780	-780	-2417.5	537.7	-102.0	-421.7	-206.1
PAR7	69.68	.2	.2	2583	1701	.1	.1	-207	207	-2417.5	537.8	-96.8	-398.3	-206.1
PAR8	79.35	.5	.5	2583	1701	.2	.3	-108	108	-2417.7	537.6	-91.6	-374.9	-206.0
CLUB	89.02	.6	.8	2583	1700	.2	.5	-104	72	-2418.2	537.1	-86.4	-351.5	-205.9
CLUB	101.02	-110.3	42.6	2945	1733	-37.5	24.6	-16	-42	-2418.8	536.2	-81.2	-328.1	-205.7
H011	115.02	-137.1	34.8	3443	2029	-39.8	17.1	-12	-47	-2308.5	493.7	-75.0	-299.8	-200.4
H012	124.69	-94.1	19.5	2368	1391	-39.8	14.0	-12	-56	-2171.4	458.9	-68.3	-268.4	-193.6
H013	134.36	-89.4	14.0	2323	1347	-38.5	10.4	-11	-71	-2077.2	439.4	-64.0	-247.9	-188.1
H014	144.03	-87.3	10.5	2264	1287	-38.6	8.1	-9	-78	-1987.8	425.4	-59.8	-228.2	-181.6
H015	153.70	-86.8	10.2	2253	1276	-38.6	8.0	-9	-79	-1900.5	414.9	-55.7	-209.4	-174.7
H016	163.37	-85.8	10.9	2253	1276	-38.1	8.5	-10	-79	-1813.7	404.7	-51.8	-191.5	-167.8
OF17	177.37	-122.3	16.8	3261	1847	-37.5	9.1	-11	-80	-1728.0	393.9	-47.9	-174.3	-160.9
OF18	189.37	-103.1	15.5	2795	1583	-36.9	9.8	-12	-80	-1605.6	377.0	-42.5	-151.0	-150.9
OF19	201.37	-102.7	16.5	2795	1583	-36.7	10.4	-13	-81	-1502.5	361.6	-38.1	-132.4	-142.4
OF20	213.37	-102.3	17.5	2795	1583	-36.6	11.0	-14	-81	-1399.9	345.1	-33.8	-114.9	-133.9
OF21	225.37	-102.0	18.5	2795	1583	-36.5	11.7	-15	-81	-1297.5	327.6	-29.8	-98.8	-125.4
OF22	237.37	-101.6	19.5	2795	1583	-36.3	12.3	-15	-81	-1195.6	309.2	-26.0	-83.8	-116.9
OF23	249.37	-101.4	20.4	2795	1583	-36.3	12.9	-16	-81	-1094.0	289.7	-22.4	-70.1	-108.4
OF24	261.37	-101.5	21.3	2795	1583	-36.3	13.5	-17	-80	-992.5	269.2	-19.0	-57.5	-99.9
OF25	273.37	-101.6	22.2	2795	1583	-36.3	14.0	-17	-80	-891.0	247.9	-15.9	-46.2	-91.4
		-101.6	23.1	2795	1583	-36.4	14.6	-18	-79	-789.5	225.8	-13.1	-36.2	-83.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS : THREE LAKEWAY CENTER														
WIND DIRECTION 80		CONFIGURATION A				REFERENCE PRESSURE 38.0 PSF				GUST FACTOR 1.32				
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
OF26	285.37	-101.5	23.7	2795	1583	-36.3	15.0	-18	-79	-687.9	202.7	-10.5	-27.3	-74.5
OF27	297.37	-101.0	23.9	2795	1583	-36.1	15.1	-19	-78	-586.4	179.0	-8.2	-19.6	-66.2
OF28	309.37	-100.5	24.2	2795	1583	-35.9	15.3	-19	-78	-485.4	155.1	-6.2	-13.2	-57.8
OF29	321.37	-100.0	24.4	2795	1583	-35.8	15.4	-19	-78	-385.0	130.9	-4.5	-8.0	-49.5
OF30	333.37	-97.6	24.0	2795	1583	-34.9	15.1	-20	-79	-285.0	106.5	-3.1	-4.0	-41.3
OF31	345.37	-91.6	22.4	2795	1583	-32.8	14.1	-21	-87	-187.3	82.6	-2.0	-1.1	-33.1
OF32	357.37	-84.3	22.0	2795	1583	-30.1	13.9	-25	-97	-95.7	60.2	-1.1	.6	-24.7
MEC1	369.37	-91.6	22.9	3261	1847	-28.1	12.4	-25	-99	-11.4	38.2	-.5	1.2	-15.9
MEC2	383.37	80.1	15.2	2985	1355	26.8	11.2	-14	76	80.1	15.2	-.1	.7	-6.3
TOP	401.37									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS : THREE LAKEWAY CENTER														
WIND DIRECTION 90		CONFIGURATION A		REFERENCE PRESSURE 38.0 PSF		GUST FACTOR 1.32								
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00													
PAR2	21.33	-1.9	-1.9	5698	3751	-1.2	-1.2	33	-33	-2156.9	911.0	-214.0	-498.3	-159.5
PAR3	31.00	.3	.3	2583	1701	.1	.2	-105	105	-2156.0	911.9	-194.6	-452.3	-159.5
PAR4	40.67	.7	.7	2583	1701	.3	.4	-55	55	-2156.3	911.6	-185.8	-431.4	-159.4
PAR5	50.34	1.1	1.1	2583	1701	.4	.6	-43	43	-2157.0	910.9	-176.9	-410.6	-159.3
PAR6	60.01	1.5	1.5	2583	1701	.6	.9	-37	37	-2158.1	909.8	-168.1	-389.7	-159.2
PAR7	69.68	1.9	1.9	2583	1701	.7	1.1	-34	34	-2159.6	908.3	-159.3	-368.8	-159.1
PAR8	79.35	2.3	2.3	2583	1701	.9	1.4	-32	32	-2161.5	906.4	-150.6	-347.9	-159.0
CLUB	89.02	2.6	2.9	2583	1700	1.0	1.7	-33	30	-2163.9	904.0	-141.8	-327.0	-158.8
CLUB	101.02	-87.6	58.2	2945	1733	-29.8	33.6	-20	-31	-2166.5	901.2	-133.1	-306.1	-158.7
H011	115.02	-105.8	55.4	3443	2029	-30.7	27.3	-22	-42	-2078.9	843.0	-122.6	-280.6	-154.8
H012	124.69	-75.0	32.7	2368	1391	-31.7	23.5	-23	-53	-1973.1	787.6	-111.2	-252.2	-149.2
H013	134.36	-75.6	25.8	2323	1347	-32.5	19.2	-22	-65	-1898.1	754.9	-103.8	-233.5	-144.4
H014	144.03	-75.6	22.4	2264	1287	-33.4	17.4	-20	-68	-1822.5	729.1	-96.6	-215.5	-139.0
H015	153.70	-75.8	22.5	2253	1276	-33.6	17.7	-20	-68	-1746.9	706.6	-89.6	-198.3	-133.3
H016	163.37	-75.3	23.3	2253	1276	-33.4	18.3	-21	-67	-1671.1	684.1	-82.9	-181.8	-127.7
OF17	177.37	-108.3	35.2	3261	1847	-33.2	19.1	-21	-66	-1595.8	660.7	-76.4	-166.0	-122.2
OF18	189.37	-92.1	31.5	2795	1583	-32.9	19.9	-22	-64	-1487.5	625.5	-67.4	-144.4	-114.3
OF19	201.37	-91.9	32.4	2795	1583	-32.9	20.5	-22	-63	-1395.4	594.0	-60.1	-127.1	-107.7
OF20	213.37	-91.8	33.3	2795	1583	-32.9	21.0	-23	-63	-1303.5	561.6	-53.2	-110.9	-101.2
OF21	225.37	-91.8	34.2	2795	1583	-32.8	21.6	-23	-62	-1211.6	528.3	-46.6	-95.8	-94.7
OF22	237.37	-91.7	35.0	2795	1583	-32.8	22.1	-23	-61	-1119.9	494.1	-40.5	-81.8	-88.2
OF23	249.37	-91.8	35.8	2795	1583	-32.8	22.6	-24	-61	-1028.2	459.0	-34.8	-68.9	-81.7
OF24	261.37	-92.1	36.2	2795	1583	-32.9	22.9	-24	-60	-936.5	423.3	-29.5	-57.1	-75.3
OF25	273.37	-92.5	36.7	2795	1583	-33.1	23.2	-24	-59	-844.4	387.0	-24.6	-46.4	-69.0
		-92.8	37.2	2795	1583	-33.2	23.5	-23	-58	-751.9	350.3	-20.2	-36.9	-62.6

TABLE 7. SHEAR AND MOMENT DIAGRAMS : THREE LAKEWAY CENTER														
WIND DIRECTION 90		CONFIGURATION A								REFERENCE PRESSURE 38.0 PSF				
												GUST FACTOR 1.32		
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
OF26	285.37													
		-92.7	37.5	2795	1583	-33.2	23.7	-24	-58	-659.1	313.1	-16.2	-28.4	-56.3
OF27	297.37													
		-92.0	37.5	2795	1583	-32.9	23.7	-24	-58	-566.4	275.6	-12.7	-21.0	-50.1
OF28	309.37													
		-91.3	37.5	2795	1583	-32.7	23.7	-24	-58	-474.3	238.0	-9.6	-14.8	-43.8
OF29	321.37													
		-90.6	37.5	2795	1583	-32.4	23.7	-24	-58	-383.0	200.6	-7.0	-9.7	-37.6
OF30	333.37													
		-88.3	36.7	2795	1583	-31.6	23.2	-25	-59	-292.4	163.1	-4.8	-5.6	-31.4
OF31	345.37													
		-83.2	34.3	2795	1583	-29.8	21.7	-26	-63	-204.1	126.3	-3.0	-2.6	-25.2
OF32	357.37													
		-78.0	32.0	2795	1583	-27.9	20.2	-28	-69	-120.9	92.0	-1.7	-.7	-19.1
MEC1	369.37													
		-81.1	34.9	3261	1847	-24.9	18.9	-32	-75	-42.9	60.0	-.8	.3	-12.8
MEC2	383.37													
		38.2	25.1	2985	1355	12.8	16.5	-67	102	38.2	25.1	-.2	.3	-5.6
TOP	401.37													
										0.0	0.0	0.0	0.0	0.0

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00													
PAR2	21.33	.4	.4	5698	3751	.1	.1	-70	70	-1823.7	690.4	-155.3	-440.6	-113.5
PAR3	31.00	1.2	1.2	2583	1701	.5	.7	-30	30	-1824.1	690.0	-140.6	-401.7	-113.4
PAR4	40.67	1.9	1.9	2583	1701	.7	1.1	-28	28	-1825.4	688.8	-134.0	-384.1	-113.3
PAR5	50.34	2.5	2.5	2583	1701	1.0	1.5	-27	27	-1827.2	686.9	-127.3	-366.4	-113.2
PAR6	60.01	3.2	3.2	2583	1701	1.2	1.9	-26	26	-1829.8	684.4	-120.7	-348.7	-113.1
PAR7	69.68	3.8	3.8	2583	1701	1.5	2.3	-26	26	-1832.9	681.2	-114.1	-331.0	-112.9
PAR8	79.35	4.5	4.5	2583	1701	1.7	2.6	-25	25	-1836.8	677.4	-107.5	-313.3	-112.7
CLUB	89.02	5.0	5.2	2583	1700	1.9	3.1	-26	25	-1841.3	672.9	-101.0	-295.5	-112.5
CLUB	101.02	-66.5	47.6	2945	1733	-22.6	27.5	-15	-21	-1846.3	667.7	-94.5	-277.7	-112.3
H011	115.02	-81.4	45.7	3443	2029	-23.6	22.5	-19	-34	-1779.8	620.1	-86.8	-255.9	-110.1
H012	124.69	-58.0	26.4	2368	1391	-24.5	18.9	-21	-46	-1698.4	574.4	-78.4	-231.6	-106.4
H013	134.36	-59.1	20.1	2323	1347	-25.5	15.0	-20	-57	-1640.3	548.1	-73.0	-215.4	-103.2
H014	144.03	-59.8	17.2	2264	1287	-26.0	13.3	-18	-62	-1581.2	527.9	-67.8	-199.9	-99.4
H015	153.70	-59.0	17.3	2253	1276	-26.2	13.5	-18	-63	-1522.3	510.7	-62.8	-184.9	-95.5
H016	163.37	-59.6	18.0	2253	1276	-26.5	14.1	-18	-61	-1463.4	493.5	-57.9	-170.4	-91.5
OF17	177.37	-87.5	27.2	3261	1847	-26.8	14.7	-19	-60	-1403.7	475.5	-53.2	-156.6	-87.5
OF18	189.37	-76.2	24.5	2795	1583	-27.2	15.5	-19	-58	-1316.2	448.3	-46.8	-137.5	-81.8
OF19	201.37	-76.1	25.0	2795	1583	-27.2	15.8	-19	-57	-1240.1	423.8	-41.5	-122.2	-76.9
OF20	213.37	-75.9	25.5	2795	1583	-27.2	16.1	-19	-56	-1164.0	398.8	-36.6	-107.8	-72.1
OF21	225.37	-75.8	25.9	2795	1583	-27.1	16.4	-19	-55	-1088.0	373.3	-32.0	-94.2	-67.4
OF22	237.37	-75.6	26.4	2795	1583	-27.1	16.7	-19	-54	-1012.3	347.4	-27.6	-81.6	-62.8
OF23	249.37	-75.6	26.7	2795	1583	-27.1	16.9	-19	-53	-936.7	321.0	-23.6	-69.9	-58.2
OF24	261.37	-75.9	26.8	2795	1583	-27.2	16.9	-19	-52	-861.0	294.3	-19.9	-59.2	-53.7
OF25	273.37	-76.2	27.0	2795	1583	-27.2	17.0	-18	-52	-785.1	267.5	-16.6	-49.3	-49.2
		-76.4	27.1	2795	1583	-27.3	17.1	-18	-51	-708.9	240.5	-13.5	-40.3	-44.8

TABLE 7. SHEAR AND MOMENT DIAGRAMS : THREE LAKEWAY CENTER														
WIND DIRECTION 100		CONFIGURATION A				REFERENCE PRESSURE 38.0 PSF						GUST FACTOR 1.32		
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
OF26	285.37	-76.5	27.1	2795	1583	-27.4	17.1	-18	-50	-632.5	213.4	-10.8	-32.3	-40.4
OF27	297.37	-76.2	26.7	2795	1583	-27.3	16.9	-18	-50	-556.0	186.4	-8.4	-25.1	-36.0
OF28	309.37	-75.9	26.4	2795	1583	-27.1	16.7	-18	-50	-479.8	159.7	-6.3	-18.9	-31.7
OF29	321.37	-75.6	26.1	2795	1583	-27.0	16.5	-17	-51	-404.0	133.2	-4.5	-13.6	-27.4
OF30	333.37	-74.4	25.3	2795	1583	-26.6	16.0	-18	-52	-328.4	107.1	-3.1	-9.2	-23.1
OF31	345.37	-72.2	22.7	2795	1583	-25.8	14.3	-18	-56	-254.0	81.8	-2.0	-5.7	-18.8
OF32	357.37	-70.7	19.5	2795	1583	-25.3	12.3	-17	-61	-181.8	59.1	-1.1	-3.1	-14.4
MEC1	369.37	-74.6	23.6	3261	1847	-22.9	12.7	-20	-64	-111.1	39.6	-.5	-1.4	-9.7
MEC2	383.37	-36.5	16.1	2985	1355	-12.2	11.9	-45	-102	-36.5	16.1	-.1	-.3	-4.5
TOP	401.37									0.0	0.0	0.0	0.0	0.0

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00													
PAR2	21.33	1.9	1.9	5698	3751	.3	.5	-28	28	-1284.6	925.2	-205.7	-317.0	-63.9
PAR3	31.00	2.1	2.1	2583	1701	.8	1.3	-25	25	-1286.6	923.2	-186.0	-289.6	-63.7
PAR4	40.67	2.9	2.9	2583	1701	1.1	1.7	-24	24	-1288.7	921.1	-177.1	-277.1	-63.6
PAR5	50.34	3.7	3.7	2583	1701	1.4	2.2	-24	24	-1291.6	918.2	-168.2	-264.7	-63.5
PAR6	60.01	4.5	4.5	2583	1701	1.7	2.6	-24	24	-1295.3	914.5	-159.3	-252.1	-63.3
PAR7	69.68	5.3	5.3	2583	1701	2.0	3.1	-24	24	-1299.8	910.0	-150.5	-239.6	-63.1
PAR8	79.35	6.0	6.0	2583	1701	2.3	3.6	-24	24	-1305.0	904.8	-141.7	-227.0	-62.9
CLUB	89.02	6.7	6.9	2583	1700	2.6	4.1	-24	23	-1311.1	898.7	-133.0	-214.4	-62.6
CLUB	101.02	-49.5	53.4	2945	1733	-16.8	30.8	-12	-11	-1317.8	891.8	-124.4	-201.6	-62.3
H011	115.02	-59.4	55.6	3443	2029	-17.3	27.4	-19	-20	-1268.3	838.4	-114.0	-186.1	-61.1
H012	124.69	-42.5	33.7	2368	1391	-18.0	24.3	-22	-27	-1208.9	782.9	-102.6	-168.8	-58.8
H013	134.36	-42.7	28.8	2323	1347	-18.4	21.4	-24	-35	-1166.4	749.1	-95.2	-157.3	-57.0
H014	144.03	-45.2	26.3	2264	1287	-20.0	20.4	-21	-36	-1123.6	720.3	-88.1	-146.2	-54.8
H015	153.70	-45.8	26.6	2253	1276	-20.3	20.8	-21	-36	-1078.4	694.0	-81.3	-135.6	-52.6
H016	163.37	-44.6	27.3	2253	1276	-19.8	21.4	-22	-36	-1032.5	667.5	-74.7	-125.4	-50.4
OF17	177.37	-62.4	40.9	3261	1847	-19.1	22.2	-24	-37	-987.9	640.1	-68.4	-115.6	-48.2
OF18	189.37	-51.4	36.4	2795	1583	-18.4	23.0	-26	-37	-925.6	599.2	-59.7	-102.2	-44.9
OF19	201.37	-50.9	36.7	2795	1583	-18.2	23.2	-26	-37	-874.2	562.8	-52.7	-91.4	-42.1
OF20	213.37	-50.5	37.0	2795	1583	-18.1	23.3	-26	-36	-823.3	526.1	-46.2	-81.2	-39.3
OF21	225.37	-50.1	37.2	2795	1583	-17.9	23.5	-26	-36	-772.8	489.2	-40.1	-71.7	-36.5
OF22	237.37	-49.8	37.5	2795	1583	-17.8	23.7	-26	-35	-722.7	452.0	-34.5	-62.7	-33.7
OF23	249.37	-49.6	37.5	2795	1583	-17.7	23.7	-26	-34	-673.0	414.5	-29.3	-54.3	-31.0
OF24	261.37	-49.7	37.2	2795	1583	-17.8	23.5	-25	-34	-623.4	376.9	-24.5	-46.5	-28.3
OF25	273.37	-49.7	36.9	2795	1583	-17.8	23.3	-24	-33	-573.7	339.7	-20.2	-39.3	-25.7
		-49.8	36.6	2795	1583	-17.8	23.1	-23	-32	-524.0	302.9	-16.4	-32.8	-23.1

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 110

CONFIGURATION A

THREE LAKEMAY CENTER

REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
OF26	285.37	-50.0	36.0	2795	1583	-17.9	22.7	-23	-31	-474.2	266.3	-12.9	-26.8	-20.7
OF27	297.37	-50.4	35.0	2795	1583	-18.0	22.1	-22	-31	-424.1	230.3	-10.0	-21.4	-18.3
OF28	309.37	-50.8	34.0	2795	1583	-18.2	21.5	-21	-31	-373.7	195.3	-7.4	-16.6	-15.9
OF29	321.37	-51.2	33.1	2795	1583	-18.3	20.9	-20	-31	-322.9	161.3	-5.3	-12.4	-13.6
OF30	333.37	-51.2	31.6	2795	1583	-18.3	19.9	-20	-32	-271.7	128.2	-3.5	-8.8	-11.4
OF31	345.37	-51.2	28.5	2795	1583	-18.3	18.0	-19	-33	-220.5	96.6	-2.2	-5.9	-9.1
OF32	357.37	-51.6	25.0	2795	1583	-18.5	15.8	-17	-35	-169.3	68.1	-1.2	-3.6	-6.9
MEC1	369.37	-54.6	29.3	3261	1847	-16.7	15.9	-19	-36	-117.6	43.1	-.5	-1.8	-4.6
MEC2	383.37	-63.0	13.8	2985	1355	-21.1	10.1	-7	-32	-63.0	13.8	-.1	-.6	-2.1
TOP	401.37									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 120

THREE LAKEWAY CENTER
CONFIGURATION A

REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									-494.8	1143.5	-261.9	-124.5	10.7
PAR2	21.33	2.3	2.3	5698	3751	.4	.6	-24	24	-497.1	1141.2	-237.6	-113.9	10.8
PAR3	31.00	2.0	2.0	2583	1701	.8	1.2	-23	23	-499.1	1139.3	-226.5	-109.1	10.9
PAR4	40.67	2.5	2.5	2583	1701	1.0	1.5	-23	23	-501.6	1136.8	-215.5	-104.2	11.0
PAR5	50.34	3.1	3.1	2583	1701	1.2	1.8	-23	23	-504.7	1133.7	-204.5	-99.4	11.1
PAR6	60.01	3.7	3.7	2583	1701	1.4	2.2	-23	23	-508.4	1130.0	-193.6	-94.5	11.3
PAR7	69.68	4.2	4.2	2583	1701	1.6	2.5	-23	23	-512.6	1125.8	-182.7	-89.5	11.5
PAR8	79.35	4.8	4.8	2583	1701	1.9	2.8	-23	23	-517.4	1121.0	-171.8	-84.5	11.7
PAR8	79.35	5.3	5.5	2583	1700	2.1	3.2	-23	22	-522.7	1115.5	-161.0	-79.5	12.0
CLUB	89.02									-498.6	1060.4	-148.0	-73.4	11.5
CLUB	101.02	-24.1	55.1	2945	1733	-8.2	31.8	7	3	-470.9	999.8	-133.5	-66.6	11.1
H011	115.02	-27.7	60.6	3443	2029	-8.0	29.9	5	2	-451.9	960.5	-124.1	-62.1	11.0
H012	124.69	-19.0	39.3	2368	1391	-8.0	28.2	2	1	-433.7	924.8	-115.0	-57.9	11.1
H013	134.36	-18.2	35.7	2323	1347	-7.8	26.5	-1	-0	-413.8	891.3	-106.2	-53.8	11.0
H014	144.03	-19.9	33.5	2264	1287	-8.8	26.0	1	0	-393.7	857.6	-97.7	-49.9	11.0
H015	153.70	-20.1	33.6	2253	1276	-8.9	26.4	1	1	-374.7	823.4	-89.6	-46.1	10.9
H016	163.37	-19.0	34.3	2253	1276	-8.4	26.9	2	1	-349.2	772.6	-78.4	-41.1	10.6
OF17	177.37	-25.6	50.8	3261	1847	-7.8	27.5	4	2	-329.1	728.0	-69.4	-37.0	10.4
OF18	189.37	-20.1	44.6	2795	1583	-7.2	28.2	5	2	-309.7	682.7	-60.9	-33.2	10.0
OF19	201.37	-19.4	45.2	2795	1583	-6.9	28.6	6	3	-290.9	637.0	-53.0	-29.6	9.7
OF20	213.37	-18.8	45.8	2795	1583	-6.7	28.9	7	3	-272.8	590.6	-45.7	-26.2	9.3
OF21	225.37	-18.1	46.4	2795	1583	-6.5	29.3	8	3	-255.2	543.7	-38.9	-23.0	8.8
OF22	237.37	-17.5	46.9	2795	1583	-6.3	29.6	9	3	-238.3	496.5	-32.6	-20.1	8.3
OF23	249.37	-16.9	47.2	2795	1583	-6.1	29.8	10	4	-221.9	449.6	-26.9	-17.3	7.7
OF24	261.37	-16.4	46.9	2795	1583	-5.9	29.7	11	4	-206.0	402.8	-21.8	-14.7	7.0
OF25	273.37	-15.9	46.7	2795	1583	-5.7	29.5	13	4					
		-15.4	46.5	2795	1583	-5.5	29.4	15	5					

TABLE 7. SHEAR AND MOMENT DIAGRAMS : THREE LAKEWAY CENTER														
WIND DIRECTION 120		CONFIGURATION A				REFERENCE PRESSURE 38.0 PSF						GUST FACTOR 1.32		
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
OF26	285.37	-15.2	46.2	2795	1583	-5.4	29.2	16	5	-190.6	356.3	-17.3	-12.3	6.2
OF27	297.37	-15.7	45.8	2795	1583	-5.6	28.9	16	6	-175.4	310.1	-13.3	-10.2	5.4
OF28	309.37	-16.2	45.4	2795	1583	-5.8	28.7	16	6	-159.7	264.3	-9.8	-8.1	4.6
OF29	321.37	-16.6	45.0	2795	1583	-6.0	28.4	16	6	-143.5	218.8	-6.9	-6.3	3.7
OF30	333.37	-17.6	43.7	2795	1583	-6.3	27.6	16	6	-126.9	173.8	-4.6	-4.7	2.9
OF31	345.37	-19.9	40.2	2795	1583	-7.1	25.4	15	7	-109.3	130.2	-2.7	-3.3	2.1
OF32	357.37	-21.8	37.0	2795	1583	-7.8	23.4	16	9	-89.4	90.0	-1.4	-2.1	1.4
MEC1	369.37	-23.4	40.6	3261	1847	-7.8	22.0	6	4	-67.6	53.0	-.6	-1.1	.6
MEC2	383.37	-42.2	12.4	2985	1355	-14.2	9.2	1	5	-42.2	12.4	-.1	-.4	.2
TOP	401.37									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 130

THREE LANEWAY CENTER
CONFIGURATION A
REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00	3.8	3.8	5698	3751	.7	1.0	-22	22	358.7	1129.7	-264.0	77.4	70.6
PAR2	21.33	1.8	1.8	2583	1701	.7	1.1	-20	20	354.9	1125.9	-239.9	69.8	70.8
PAR3	31.00	1.9	1.9	2583	1701	.7	1.1	-19	19	353.1	1124.1	-229.0	66.4	70.8
PAR4	40.67	2.0	2.0	2583	1701	.8	1.2	-18	18	351.1	1122.1	-218.2	63.0	70.9
PAR5	50.34	2.1	2.1	2583	1701	.8	1.2	-18	18	349.1	1120.1	-207.3	59.6	71.0
PAR6	60.01	2.2	2.2	2583	1701	.8	1.3	-17	17	347.0	1118.0	-196.5	56.3	71.1
PAR7	69.68	2.3	2.3	2583	1701	.9	1.3	-16	16	344.9	1115.9	-185.7	52.9	71.1
PAR8	79.35	2.4	2.4	2583	1700	.9	1.4	-15	14	342.6	1113.6	-174.9	49.6	71.2
CLUB	89.02	12.3	49.4	2945	1733	4.2	28.5	42	-10	340.2	1111.2	-164.2	46.3	71.3
CLUB	101.02	13.8	55.4	3443	2029	4.0	27.3	43	-11	327.9	1061.7	-151.1	42.3	69.1
H011	115.02	9.4	37.6	2368	1391	4.0	27.0	43	-11	314.1	1006.3	-136.7	37.8	66.5
H012	124.69	9.4	35.3	2323	1347	4.0	26.2	46	-12	304.7	968.8	-127.1	34.8	64.8
H013	134.36	11.9	33.2	2264	1287	5.3	25.8	39	-14	295.3	933.4	-117.9	31.9	63.1
H014	144.03	13.4	33.3	2253	1276	5.9	26.1	36	-14	283.4	900.2	-109.0	29.1	61.6
H015	153.70	13.0	33.7	2253	1276	5.8	26.4	41	-16	270.0	867.0	-100.5	26.4	60.2
H016	163.37	18.2	49.6	3261	1847	5.6	26.8	47	-17	257.0	833.3	-92.3	23.9	58.6
OF17	177.37	15.0	43.2	2795	1583	5.4	27.3	54	-19	238.8	783.7	-81.0	20.4	56.0
OF18	189.37	15.3	43.9	2795	1583	5.5	27.8	56	-20	223.8	740.5	-71.8	17.6	53.4
OF19	201.37	15.8	44.7	2795	1583	5.7	28.2	58	-20	208.5	696.5	-63.2	15.0	50.6
OF20	213.37	16.2	45.4	2795	1583	5.8	28.7	59	-21	192.7	651.9	-55.1	12.6	47.7
OF21	225.37	16.7	46.1	2795	1583	6.0	29.1	61	-22	176.5	606.5	-47.6	10.4	44.7
OF22	237.37	17.1	46.6	2795	1583	6.1	29.5	62	-23	159.8	560.4	-40.6	8.4	41.5
OF23	249.37	17.5	46.9	2795	1583	6.3	29.6	62	-23	142.7	513.7	-34.1	6.6	38.2
OF24	261.37	17.9	47.2	2795	1583	6.4	29.8	63	-24	125.1	466.8	-28.2	5.0	34.9
OF25	273.37	18.3	47.5	2795	1583	6.6	30.0	63	-24	107.2	419.5	-22.9	3.6	31.5

TABLE 7. SHEAR AND MOMENT DIAGRAMS : WIND DIRECTION 130														
CONFIGURATION A					THREE LAKEWAY CENTER REFERENCE PRESSURE 38.0 PSF					GUST FACTOR 1.32				
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
0F26	285.37													
		18.3	47.6	2795	1583	6.6	30.0	64	-25	88.9	372.0	-18.2	2.4	28.0
0F27	297.37													
		17.7	47.1	2795	1583	6.3	29.8	65	-24	70.5	324.5	-14.0	1.4	24.5
0F28	309.37													
		17.0	46.7	2795	1583	6.1	29.5	66	-24	52.9	277.3	-10.4	.7	21.1
0F29	321.37													
		16.3	46.3	2795	1583	5.8	29.2	67	-23	35.9	230.6	-7.3	.2	17.6
0F30	333.37													
		14.1	45.2	2795	1583	5.1	28.6	68	-21	19.6	184.3	-4.8	-.2	14.1
0F31	345.37													
		8.9	42.8	2795	1583	3.2	27.0	73	-15	5.5	139.1	-2.9	-.3	10.7
0F32	357.37													
		4.3	40.9	2795	1583	1.6	25.9	79	-8	-3.5	96.3	-1.5	-.3	7.5
MEC1	369.37													
		5.1	44.2	3261	1847	1.6	23.9	65	-8	-7.8	55.4	-.6	-.3	4.2
MEC2	383.37													
		-12.9	11.2	2985	1355	-4.3	8.3	50	58	-12.9	11.2	-.1	-.1	1.3
TOP	401.37													
										0.0	0.0	0.0	0.0	0.0

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									965.0	1271.6	-300.7	215.7	66.4
PAR2	21.33	7.3	7.3	5698	3751	1.3	1.9	-21	21	957.7	1264.3	-273.7	195.2	66.7
PAR3	31.00	2.8	2.8	2583	1701	1.1	1.7	-19	19	954.9	1261.5	-261.4	185.9	66.8
PAR4	40.67	2.5	2.5	2583	1701	1.0	1.5	-17	17	952.3	1259.0	-249.3	176.7	66.9
PAR5	50.34	2.2	2.2	2583	1701	.9	1.3	-15	15	950.1	1256.7	-237.1	167.5	67.0
PAR6	60.01	1.9	1.9	2583	1701	.7	1.1	-12	12	948.2	1254.8	-225.0	158.3	67.0
PAR7	69.68	1.6	1.6	2583	1701	.6	1.0	-8	8	946.5	1253.1	-212.8	149.2	67.0
PAR8	79.35	1.3	1.3	2583	1701	.5	.8	-2	2	945.2	1251.8	-200.7	140.0	67.0
CLUB	89.02	1.1	1.1	2583	1700	.4	.7	9	-9	944.1	1250.7	-188.6	130.9	67.0
CLUB	101.02	46.3	51.0	2945	1733	15.7	29.5	28	-25	897.7	1199.6	-173.9	119.9	64.4
H011	115.02	53.0	57.7	3443	2029	15.4	28.5	26	-24	844.7	1141.9	-157.5	107.7	61.7
H012	124.69	35.5	40.3	2368	1391	15.0	29.0	24	-21	809.2	1101.6	-146.7	99.7	60.0
H013	134.36	31.8	38.0	2323	1347	13.7	28.2	28	-24	777.5	1063.6	-136.2	92.0	58.2
H014	144.03	37.0	36.1	2264	1287	16.3	28.1	16	-17	740.5	1027.5	-126.1	84.6	57.0
H015	153.70	39.6	36.3	2253	1276	17.6	28.4	12	-13	700.9	991.2	-116.3	77.7	56.0
H016	163.37	37.3	36.8	2253	1276	16.6	28.9	17	-17	663.6	954.4	-106.9	71.1	54.8
OF17	177.37	50.0	54.3	3261	1847	15.3	29.4	24	-22	613.6	900.1	-93.9	62.1	52.4
OF18	189.37	39.1	47.5	2795	1583	14.0	30.0	32	-26	574.6	852.6	-83.4	55.0	49.8
OF19	201.37	38.2	48.7	2795	1583	13.7	30.7	34	-26	536.4	803.9	-73.5	48.3	47.2
OF20	213.37	37.6	49.8	2795	1583	13.4	31.5	35	-26	498.8	754.1	-64.1	42.1	44.5
OF21	225.37	36.9	51.0	2795	1583	13.2	32.2	36	-26	461.9	703.0	-55.4	36.4	41.7
OF22	237.37	36.2	52.2	2795	1583	13.0	33.0	36	-25	425.7	650.8	-47.3	31.0	38.9
OF23	249.37	35.6	53.2	2795	1583	12.8	33.6	38	-25	390.0	597.6	-39.8	26.2	36.0
OF24	261.37	35.1	53.9	2795	1583	12.6	34.1	39	-25	354.9	543.7	-32.9	21.7	33.0
OF25	273.37	34.6	54.7	2795	1583	12.4	34.5	40	-26	320.3	489.0	-26.7	17.6	29.9
		34.1	55.4	2795	1583	12.2	35.0	42	-26					

TABLE 7. SHEAR AND MOMENT DIAGRAMS : WIND DIRECTION 140														
THREE LAKEWAY CENTER CONFIGURATION A REFERENCE PRESSURE 38.0 PSF GUST FACTOR 1.32														
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
OF26	285.37													
		34.1	55.6	2795	1583	12.2	35.1	43	-26	286.1	433.6	-21.2	14.0	26.7
OF27	297.37													
		34.8	55.0	2795	1583	12.5	34.7	43	-27	252.1	378.0	-16.3	10.8	23.4
OF28	309.37													
		35.5	54.4	2795	1583	12.7	34.4	43	-28	217.3	323.0	-12.1	7.9	20.1
OF29	321.37													
		36.3	53.8	2795	1583	13.0	34.0	43	-29	181.7	268.6	-8.6	5.6	16.8
OF30	333.37													
		36.5	52.4	2795	1583	13.0	33.1	42	-30	145.5	214.8	-5.7	3.6	13.4
OF31	345.37													
		35.5	49.3	2795	1583	12.7	31.1	40	-29	109.0	162.4	-3.4	2.1	10.1
OF32	357.37													
		35.6	47.3	2795	1583	12.7	29.9	40	-30	73.5	113.0	-1.8	1.0	7.1
MEC1	369.37													
		35.7	51.2	3261	1847	10.9	27.7	41	-28	37.9	65.8	-.7	.3	4.1
MEC2	383.37													
		2.2	14.6	2985	1355	.7	10.7	69	-11	2.2	14.6	-.1	.0	1.0
TOP	401.37													
										0.0	0.0	0.0	0.0	0.0

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00	21.2	21.2	5698	3751	3.7	5.7	-27	27	1530.9	1606.5	-370.5	341.5	49.5
PAR2	21.33	9.6	9.6	2583	1701	3.7	5.7	-27	27	1509.7	1585.3	-336.4	309.1	50.6
PAR3	31.00	9.7	9.7	2583	1701	3.7	5.7	-27	27	1500.0	1575.7	-321.2	294.5	51.1
PAR4	40.67	9.7	9.7	2583	1701	3.7	5.7	-28	28	1490.4	1566.0	-306.0	280.1	51.6
PAR5	50.34	9.7	9.7	2583	1701	3.7	5.7	-28	28	1480.7	1556.3	-290.9	265.7	52.2
PAR6	60.01	9.7	9.7	2583	1701	3.7	5.7	-28	28	1471.0	1546.6	-275.9	251.4	52.7
PAR7	69.68	9.7	9.7	2583	1701	3.8	5.7	-28	28	1461.3	1536.9	-261.0	237.2	53.3
PAR8	79.35	9.7	9.7	2583	1701	3.8	5.7	-29	29	1451.6	1527.2	-246.1	223.2	53.8
CLUB	89.02	9.8	9.8	2583	1700	3.8	5.9	-28	28	1441.8	1517.4	-231.4	209.2	54.4
CLUB	101.02	61.8	57.8	2945	1733	21.0	33.4	14	-15	1380.0	1459.6	-213.6	192.2	52.6
H011	115.02	76.2	68.1	3443	2029	22.1	33.6	12	-14	1303.8	1391.5	-193.6	173.4	50.7
H012	124.69	49.0	48.5	2368	1391	20.7	34.9	14	-15	1254.9	1343.0	-180.4	161.1	49.3
H013	134.36	42.8	46.7	2323	1347	18.4	34.7	20	-19	1212.1	1296.3	-167.6	149.2	47.6
H014	144.03	48.9	44.1	2264	1287	21.6	34.3	14	-16	1163.2	1252.2	-155.3	137.7	46.2
H015	153.70	52.7	44.3	2253	1276	23.4	34.7	12	-14	1110.5	1207.9	-143.4	126.7	44.9
H016	163.37	51.4	45.0	2253	1276	22.8	35.2	14	-16	1059.1	1163.0	-131.9	116.2	43.5
OF17	177.37	72.2	66.3	3261	1847	22.1	35.9	16	-18	986.9	1096.7	-116.1	101.9	41.2
OF18	189.37	59.8	58.0	2795	1583	21.4	36.6	19	-20	927.1	1038.7	-103.3	90.4	38.9
OF19	201.37	59.2	59.2	2795	1583	21.2	37.4	20	-20	867.9	979.6	-91.2	79.6	36.5
OF20	213.37	58.7	60.4	2795	1583	21.0	38.1	20	-20	809.2	919.2	-79.8	69.5	34.1
OF21	225.37	58.2	61.6	2795	1583	20.8	38.9	21	-20	751.1	857.7	-69.1	60.2	31.7
OF22	237.37	57.7	62.8	2795	1583	20.6	39.7	21	-19	693.4	794.9	-59.2	51.5	29.3
OF23	249.37	57.2	63.6	2795	1583	20.5	40.2	22	-19	636.2	731.2	-50.1	43.5	26.8
OF24	261.37	56.7	64.0	2795	1583	20.3	40.4	22	-19	579.5	667.2	-41.7	36.2	24.3
OF25	273.37	56.2	64.4	2795	1583	20.1	40.7	22	-19	523.3	602.8	-34.1	29.6	21.8
		55.7	64.8	2795	1583	19.9	40.9	22	-19					

TABLE 7. SHEAR AND MOMENT DIAGRAMS : WIND DIRECTION 150														
THREE LAKEWAY CENTER CONFIGURATION A REFERENCE PRESSURE 38.0 PSF GUST FACTOR 1.32														
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
OF26	285.37	55.3	65.1	2795	1583	19.8	41.1	22	-19	467.7	537.9	-27.2	23.7	19.3
OF27	297.37	55.2	65.1	2795	1583	19.8	41.1	22	-19	412.3	472.9	-21.2	18.4	16.9
OF28	309.37	55.1	65.1	2795	1583	19.7	41.1	22	-19	357.1	407.8	-15.9	13.8	14.4
OF29	321.37	55.0	65.1	2795	1583	19.7	41.1	22	-19	301.9	342.7	-11.4	9.8	11.9
OF30	333.37	55.7	64.2	2795	1583	19.9	40.6	21	-18	246.9	277.6	-7.6	6.5	9.4
OF31	345.37	57.6	61.5	2795	1583	20.6	38.9	19	-18	191.2	213.4	-4.7	3.9	7.1
OF32	357.37	60.7	60.1	2795	1583	21.7	37.9	18	-18	133.6	151.8	-2.5	2.0	4.9
MEC1	369.37	59.5	66.6	3261	1847	18.2	36.0	18	-16	72.8	91.8	-1.0	.7	2.7
MEC2	383.37	13.4	25.2	2985	1355	4.5	18.6	16	-9	13.4	25.2	-.2	.1	.5
TOP	401.37									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS : THREE LAKEWAY CENTER														
WIND DIRECTION 160		CONFIGURATION A				REFERENCE PRESSURE 28.0 PSF				CUST FACTOR 1.32				
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00	30.9	30.9	5698	3751	5.4	8.2	-26	26	2107.9	1873.6	-426.2	469.3	47.5
PAR2	21.33	14.2	14.2	2583	1701	5.5	8.3	-26	26	2077.0	1842.7	-386.6	424.7	49.1
PAR3	31.00	14.3	14.3	2583	1701	5.5	8.4	-26	26	2062.8	1828.5	-368.8	404.6	49.9
PAR4	40.67	14.5	14.5	2583	1701	5.6	8.5	-26	26	2048.5	1814.2	-351.2	384.8	50.6
PAR5	50.34	14.6	14.6	2583	1701	5.6	8.6	-27	27	2034.1	1799.8	-333.7	365.0	51.4
PAR6	60.01	14.7	14.7	2583	1701	5.7	8.6	-27	27	2019.5	1785.2	-316.4	345.4	52.2
PAR7	69.68	14.8	14.8	2583	1701	5.7	8.7	-27	27	2004.8	1770.5	-299.2	326.0	52.9
PAR8	79.35	15.0	15.0	2583	1700	5.8	8.8	-27	27	1989.9	1755.6	-282.2	306.6	53.7
CLUB	89.02	81.4	65.0	2945	1733	27.7	37.5	5	-7	1974.9	1740.6	-265.3	287.5	54.5
CLUB	101.02	103.3	79.0	3443	2029	30.0	38.9	5	-7	1893.5	1675.6	-244.8	264.3	53.6
H011	115.02	67.2	56.0	2368	1391	28.4	40.3	9	-11	1790.1	1596.6	-221.9	238.5	52.6
H012	124.69	61.2	54.3	2323	1347	26.4	40.3	15	-17	1722.9	1540.6	-206.7	221.5	51.3
H013	134.36	67.8	51.3	2264	1287	30.0	39.9	11	-14	1661.7	1486.3	-192.0	205.1	49.4
H014	144.03	71.8	51.5	2253	1276	31.9	40.4	8	-12	1593.9	1435.0	-177.9	189.4	48.0
H015	153.70	70.1	52.3	2253	1276	31.1	41.0	10	-13	1522.1	1383.5	-164.3	174.3	46.7
H016	163.37	98.5	77.2	3261	1847	30.2	41.8	12	-15	1452.0	1331.1	-151.2	159.9	45.2
OF17	177.37	81.6	67.5	2795	1583	29.2	42.7	14	-17	1353.5	1253.9	-133.1	140.3	42.8
OF18	189.37	80.7	68.3	2795	1583	28.9	43.2	15	-18	1271.9	1186.4	-118.4	124.6	40.4
OF19	201.37	80.0	69.1	2795	1583	28.6	43.7	15	-17	1191.2	1118.0	-104.6	109.8	37.9
OF20	213.37	79.2	69.9	2795	1583	28.3	44.1	15	-17	1111.2	1048.9	-91.6	96.0	35.5
OF21	225.37	78.5	70.7	2795	1583	28.1	44.6	16	-17	1032.0	979.0	-79.4	83.1	33.0
OF22	237.37	77.9	71.5	2795	1583	27.9	45.1	16	-17	953.5	908.4	-68.1	71.2	30.6
OF23	249.37	77.6	72.3	2795	1583	27.8	45.7	16	-17	875.5	836.9	-57.6	60.2	28.1
OF24	261.37	77.2	73.2	2795	1583	27.6	46.2	17	-18	797.9	764.6	-48.0	50.2	25.6
OF25	273.37	76.9	74.0	2795	1583	27.5	46.7	17	-18	720.7	691.5	-39.3	41.1	23.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS : THREE LAKEMAN CENTER														
WIND DIRECTION 160		CONFIGURATION A				REFERENCE PRESSURE 38.0 PSF				GUST FACTOR 1.32				
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
OF26	285.37									643.8	617.4	-31.4	32.9	20.3
OF27	297.37	76.6	74.5	2795	1583	27.4	47.0	17	-18	567.2	543.0	-24.5	25.6	17.7
OF28	309.37	76.3	74.3	2795	1583	27.3	46.9	17	-18	490.9	468.7	-18.4	19.3	15.1
OF29	321.37	76.1	74.1	2795	1583	27.2	46.8	17	-18	414.8	394.6	-13.2	13.8	12.4
OF30	333.37	75.9	73.9	2795	1583	27.1	46.7	17	-18	338.9	320.6	-8.9	9.3	9.8
OF31	345.37	75.8	72.8	2795	1583	27.1	46.0	17	-17	263.1	247.8	-5.5	5.7	7.3
OF32	357.37	76.3	70.3	2795	1583	27.3	44.4	15	-16	186.8	177.6	-3.0	3.0	5.0
MEC1	369.37	78.5	69.2	2795	1583	28.1	43.7	15	-17	108.3	108.3	-1.3	1.2	2.6
MEC2	383.37	78.9	76.9	3261	1847	24.2	41.6	14	-15	29.4	31.4	-.3	.3	.4
TOP	401.37	29.4	31.4	2985	1355	9.8	23.2	6	-6	0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS 1		THREE LAKEWAY CENTER PROJECT #6013								GUST FACTOR 1.32				
WIND DIRECTION 170		CONFIGURATION A								REFERENCE PRESSURE 38.0 PSF				
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									2662.5	1963.6	-443.8	598.3	35.5
PAR2	21.33	36.7	36.7	5698	3751	6.4	9.8	-25	25	2625.8	1926.9	-402.3	541.9	37.4
PAR3	31.00	16.8	16.8	2583	1701	6.5	9.9	-26	26	2609.0	1910.1	-383.7	516.6	38.2
PAR4	40.67	16.9	16.9	2583	1701	6.5	9.9	-26	26	2592.1	1893.2	-365.4	491.5	39.1
PAR5	50.34	17.0	17.0	2583	1701	6.6	10.0	-26	26	2575.2	1876.2	-347.1	466.5	40.0
PAR6	60.01	17.1	17.1	2583	1701	6.6	10.0	-26	26	2558.1	1859.2	-329.1	441.7	40.9
PAR7	69.68	17.2	17.2	2583	1701	6.6	10.1	-26	26	2540.9	1842.0	-311.2	417.0	41.8
PAR8	79.35	17.3	17.3	2583	1701	6.7	10.1	-26	26	2523.7	1824.8	-293.4	392.5	42.7
		17.4	17.4	2583	1700	6.8	10.2	-26	26	2506.2	1807.3	-275.9	368.2	43.6
CLUB	89.02	101.1	66.4	2945	1733	34.3	38.3	-1	2	2405.2	1740.9	-254.6	338.7	43.8
CLUB	101.02	129.7	82.4	3443	2029	37.7	40.6	-0	0	2275.5	1658.5	-230.8	306.0	43.8
H011	115.02	84.3	58.4	2368	1391	35.6	42.0	4	-6	2191.3	1600.1	-215.0	284.4	43.2
H012	124.69	77.2	57.0	2323	1347	33.2	42.4	9	-13	2114.1	1543.1	-199.9	263.5	41.7
H013	134.36	85.7	53.7	2264	1287	37.9	41.7	6	-9	2028.3	1489.4	-185.2	243.5	40.6
H014	144.03	90.4	53.7	2253	1276	40.1	42.1	4	-7	1938.0	1435.7	-171.0	224.3	39.8
H015	153.70	87.5	54.4	2253	1276	38.9	42.6	5	-8	1850.5	1381.3	-157.4	206.0	38.8
H016	163.37	121.7	79.9	3261	1847	37.3	43.2	7	-10	1728.8	1301.4	-138.6	181.0	37.0
OF17	177.37	99.6	69.6	2795	1583	35.6	43.9	9	-13	1629.2	1231.9	-123.4	160.8	35.1
OF18	189.37	99.3	70.5	2795	1583	35.5	44.5	9	-13	1529.9	1161.4	-109.1	141.9	33.1
OF19	201.37	99.4	71.3	2795	1583	35.6	45.1	10	-14	1430.5	1090.1	-95.6	124.1	31.0
OF20	213.37	99.5	72.2	2795	1583	35.6	45.6	10	-14	1331.0	1017.9	-82.9	107.5	28.9
OF21	225.37	99.6	73.1	2795	1583	35.6	46.2	10	-14	1231.4	944.8	-71.2	92.2	26.7
OF22	237.37	99.6	73.9	2795	1583	35.6	46.7	11	-14	1131.9	870.9	-60.3	78.0	24.5
OF23	249.37	99.5	74.7	2795	1583	35.6	47.2	11	-15	1032.4	796.2	-50.3	65.0	22.2
OF24	261.37	99.4	75.4	2795	1583	35.6	47.6	11	-15	932.9	720.8	-41.2	53.2	19.9
OF25	273.37	99.4	76.2	2795	1583	35.5	48.1	11	-15					

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 170

CONFIGURATION A

THREE LAKEWAY CENTER PROJECT #6013

REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
OF26	285.37	99.3	76.7	2795	1583	35.5	48.4	12	-15	833.6	644.6	-33.0	42.6	17.5
OF27	297.37	99.3	76.8	2795	1583	35.5	48.5	11	-15	734.2	568.0	-25.7	33.2	15.2
OF28	309.37	99.3	76.8	2795	1583	35.5	48.5	11	-15	634.9	491.2	-19.3	25.0	12.8
OF29	321.37	99.4	76.9	2795	1583	35.5	48.6	11	-14	535.5	414.4	-13.9	18.0	10.5
OF30	333.37	98.8	76.4	2795	1583	35.4	48.3	11	-14	436.2	337.4	-9.4	12.1	8.2
OF31	345.37	97.3	74.8	2795	1583	34.8	47.2	10	-13	337.4	261.0	-5.8	7.5	6.0
OF32	357.37	95.8	73.3	2795	1583	34.3	46.3	10	-13	240.1	186.2	-3.1	4.0	4.0
MEC1	369.37	100.1	79.9	3261	1847	30.7	43.2	10	-12	144.3	112.9	-1.3	1.7	2.0
MEC2	383.37	44.1	33.1	2985	1355	14.8	24.4	0	-1	44.2	33.1	-.3	.4	.0
TOP	401.37									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS ;
WIND DIRECTION 180

CONFIGURATION A

THREE LAKEWAY CENTER . PROJECT #6013
REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00	38.4	38.4	5698	3751	6.7	10.2	-25	25	3203.8	1853.3	-415.3	725.5	11.7
PAR2	21.33	17.6	17.6	2583	1701	6.8	10.4	-25	25	3165.4	1814.9	-376.2	657.6	13.7
PAR3	31.00	17.8	17.8	2583	1701	6.9	10.5	-25	25	3147.8	1797.3	-358.8	627.1	14.6
PAR4	40.67	18.0	18.0	2583	1701	7.0	10.6	-25	25	3130.0	1779.5	-341.5	596.7	15.5
PAR5	50.34	18.1	18.1	2583	1701	7.0	10.7	-25	25	3112.0	1761.5	-324.3	566.5	16.4
PAR6	60.01	18.3	18.3	2583	1701	7.1	10.8	-26	26	3093.9	1743.4	-307.4	536.5	17.3
PAR7	69.68	18.4	18.4	2583	1701	7.1	10.8	-26	26	3075.6	1725.1	-290.6	506.7	18.3
PAR8	79.35	18.7	18.7	2583	1700	7.3	11.0	-25	26	3057.1	1706.7	-274.0	477.0	19.2
CLUB	89.02	125.4	63.7	2945	1733	42.6	36.8	-4	8	3038.4	1688.0	-257.6	447.6	20.1
CLUB	101.02	156.6	78.0	3443	2029	45.5	38.5	-4	7	2913.0	1624.3	-237.7	411.9	21.4
H011	115.02	101.6	54.5	2368	1391	42.9	39.2	-0	1	2756.5	1546.3	-215.6	372.2	22.8
H012	124.69	93.9	53.0	2323	1347	40.4	39.3	4	-6	2654.9	1491.7	-200.9	346.0	22.9
H013	134.36	103.7	49.4	2264	1287	45.8	38.4	1	-2	2561.0	1438.8	-186.7	320.8	22.1
H014	144.03	108.8	49.3	2253	1276	48.3	38.7	-0	0	2457.3	1389.3	-173.0	296.5	21.8
H015	153.70	105.2	50.0	2253	1276	46.7	39.2	1	-2	2348.5	1340.0	-159.8	273.3	21.9
H016	163.37	146.1	73.6	3261	1847	44.8	39.9	2	-4	2243.2	1290.0	-147.1	251.1	21.7
OF17	177.37	119.2	64.3	2795	1583	42.7	40.6	4	-7	2097.2	1216.4	-129.6	220.7	20.9
OF18	189.37	118.8	65.3	2795	1583	42.5	41.2	4	-7	1977.9	1152.1	-115.4	196.3	19.9
OF19	201.37	118.8	66.3	2795	1583	42.5	41.9	4	-7	1859.1	1086.8	-101.9	173.2	18.8
OF20	213.37	118.8	67.3	2795	1583	42.5	42.5	4	-8	1740.3	1020.5	-89.3	151.6	17.6
OF21	225.37	118.8	68.3	2795	1583	42.5	43.1	5	-8	1621.5	953.2	-77.4	131.5	16.4
OF22	237.37	119.2	69.2	2795	1583	42.6	43.7	5	-8	1502.7	884.9	-66.4	112.7	15.1
OF23	249.37	120.2	70.0	2795	1583	43.0	44.2	5	-8	1383.5	815.7	-56.2	95.4	13.9
OF24	261.37	121.2	70.7	2795	1583	43.4	44.7	5	-8	1263.3	745.8	-46.8	79.5	12.5
OF25	273.37	122.2	71.5	2795	1583	43.7	45.1	5	-8	1142.1	675.0	-38.3	65.1	11.2

TABLE 7. SHEAR AND MOMENT DIAGRAMS : THREE LAKEWAY CENTER . PROJECT #6013
WIND DIRECTION 180 CONFIGURATION A REFERENCE PRESSURE 38.0 PSF

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
OF26	285.37	122.7	72.0	2795	1583	43.9	45.5	5	-9	1019.8	603.6	-30.6	52.1	9.8
OF27	297.37	122.4	72.3	2795	1583	43.8	45.7	5	-9	897.1	531.5	-23.8	40.6	8.4
OF28	309.37	122.1	72.6	2795	1583	43.7	45.9	5	-9	774.7	459.2	-17.9	30.6	6.9
OF29	321.37	121.8	72.9	2795	1583	43.6	46.1	5	-9	652.6	386.5	-12.8	22.0	5.5
OF30	333.37	120.3	72.4	2795	1583	43.0	45.8	5	-8	530.9	313.6	-8.6	14.9	4.1
OF31	345.37	116.7	70.4	2795	1583	41.7	44.4	4	-7	410.6	241.1	-5.3	9.3	2.7
OF32	357.37	113.2	68.5	2795	1583	40.5	43.2	4	-7	293.9	170.8	-2.8	5.1	1.6
MEC1	369.37	121.7	74.4	3261	1847	37.3	40.3	4	-7	180.7	102.3	-1.2	2.2	.5
MEC2	383.37	59.0	27.9	2985	1355	19.8	20.6	-4	8	59.0	27.9	-.3	.5	-.6
TOP	401.37									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 190

THREE LAKEWAY CENTER, PROJECT #6013
CONFIGURATION A REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									3421.3	1440.2	-317.2	780.9	-28.9
PAR2	21.33	37.0	37.0	5698	3751	6.5	9.9	-25	25	3384.2	1403.1	-286.9	708.3	-27.0
PAR3	31.00	17.1	17.1	2583	1701	6.6	10.0	-25	25	3367.2	1386.1	-273.4	675.7	-26.2
PAR4	40.67	17.2	17.2	2583	1701	6.7	10.1	-25	25	3349.9	1368.8	-260.1	643.2	-25.3
PAR5	50.34	17.4	17.4	2583	1701	6.7	10.2	-25	25	3332.5	1351.4	-246.9	610.9	-24.4
PAR6	60.01	17.6	17.6	2583	1701	6.8	10.3	-25	25	3314.9	1333.8	-233.9	578.8	-23.5
PAR7	69.68	17.8	17.8	2583	1701	6.9	10.5	-25	25	3297.1	1316.0	-221.1	546.8	-22.7
PAR8	79.35	18.0	18.0	2583	1701	7.0	10.6	-25	25	3279.1	1298.1	-208.5	515.0	-21.7
CLUB	89.02	18.3	18.2	2583	1700	7.1	10.7	-25	25	3260.9	1279.9	-196.0	483.4	-20.8
CLUB	101.02	130.7	49.5	2945	1733	44.4	28.5	-7	18	3130.2	1230.4	-181.0	445.0	-18.2
H011	115.02	162.3	61.3	3443	2029	47.1	30.2	-6	16	2967.9	1169.1	-164.2	402.3	-15.2
H012	124.69	106.3	42.8	2368	1391	44.9	30.8	-4	10	2861.6	1126.3	-153.1	374.2	-13.9
H013	134.36	93.1	41.2	2323	1347	42.6	30.6	-2	4	2762.6	1085.1	-142.4	347.0	-13.5
H014	144.03	110.0	37.5	2264	1287	48.6	29.2	-3	8	2652.6	1047.6	-132.1	320.8	-12.5
H015	153.70	115.7	37.1	2253	1276	51.4	29.1	-3	10	2536.9	1010.4	-122.1	295.7	-11.3
H016	163.37	112.4	37.5	2253	1276	49.9	29.4	-3	8	2424.5	972.9	-112.5	271.7	-10.2
OF17	177.37	156.9	54.9	3261	1847	48.1	29.7	-2	6	2267.6	918.0	-99.3	238.9	-9.1
OF18	189.37	129.0	47.7	2795	1583	46.1	30.1	-1	4	2138.7	870.4	-88.6	212.4	-8.6
OF19	201.37	128.7	48.1	2795	1583	46.0	30.4	-1	4	2010.0	822.3	-78.4	187.5	-8.1
OF20	213.37	129.9	48.5	2795	1583	46.1	30.6	-1	4	1881.1	773.8	-68.8	164.2	-7.5
OF21	225.37	129.0	48.9	2795	1583	46.1	30.9	-1	4	1752.1	724.9	-59.8	142.4	-6.9
OF22	237.37	129.2	49.3	2795	1583	46.2	31.2	-1	4	1623.0	675.5	-51.4	122.1	-6.4
OF23	249.37	129.5	50.0	2795	1583	46.3	31.6	-1	4	1493.4	625.5	-43.6	103.4	-5.8
OF24	261.37	130.3	51.1	2795	1583	46.6	32.3	-1	3	1363.1	574.4	-36.4	86.3	-5.3
OF25	273.37	131.0	52.1	2795	1583	46.9	32.9	-1	3	1232.1	522.3	-29.8	70.7	-4.9
		131.7	53.1	2795	1583	47.1	33.6	-1	2					

TABLE 7. SHEAR AND MOMENT DIAGRAMS : THREE LAKEWAY CENTER . PROJECT #6013														
WIND DIRECTION 190 CONFIGURATION A REFERENCE PRESSURE 38.0 PSF GUST FACTOR 1.32														
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
OF26	285.37									1100.4	469.1	-23.9	56.7	-4.6
OF27	297.37	132.0	54.2	2795	1583	47.2	34.2	-1	2	968.4	415.0	-18.6	44.3	-4.3
OF28	309.37	131.3	55.2	2795	1583	47.0	34.9	-1	2	837.1	359.7	-13.9	33.5	-4.0
OF29	321.37	130.7	56.3	2795	1583	46.8	35.6	-1	2	706.4	303.4	-10.0	24.2	-3.7
OF30	333.37	130.1	57.4	2795	1583	46.5	36.2	-1	2	576.3	246.1	-6.7	16.5	-3.5
OF31	345.37	128.1	57.3	2795	1583	45.8	36.2	-1	2	448.2	188.7	-4.1	10.4	-3.1
OF32	357.37	123.9	55.5	2795	1583	44.3	35.1	-2	4	324.3	133.2	-2.1	5.7	-2.6
MEC1	369.37	120.6	54.6	2795	1583	43.1	34.5	-2	4	203.6	78.6	-.9	2.6	-1.9
MEC2	383.37	132.3	59.2	3261	1847	40.6	32.0	-2	4	71.4	19.4	-.2	.6	-1.3
TOP	401.37	71.4	19.4	2985	1355	23.9	14.3	-5	17	0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS : THREE LAKEMAY CENTER, PROJECT #6013
WIND DIRECTION 200 CONFIGURATION A REFERENCE PRESSURE 38.0 PSF

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		GUST FACTOR 1.32 MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									3284.0	879.8	-180.7	748.8	-75.3
PAR2	21.33	36.0	36.0	5698	3751	6.3	9.6	-25	25	3248.0	843.8	-162.4	679.2	-73.5
PAR3	31.00	16.7	16.7	2583	1701	6.5	9.8	-25	25	3231.3	827.1	-154.3	647.8	-72.7
PAR4	40.67	16.9	16.9	2583	1701	6.5	9.9	-25	25	3214.4	810.2	-146.4	616.7	-71.8
PAR5	50.34	17.1	17.1	2583	1701	6.6	10.1	-25	25	3197.2	793.1	-138.6	585.7	-70.9
PAR6	60.01	17.4	17.4	2583	1701	6.7	10.2	-25	25	3179.8	775.7	-131.0	554.8	-70.1
PAR7	69.68	17.6	17.6	2583	1701	6.8	10.3	-25	25	3162.2	758.1	-123.6	524.2	-69.2
PAR8	79.35	17.8	17.8	2583	1701	6.9	10.5	-25	25	3144.4	740.3	-116.4	493.7	-68.3
CLUB	89.02	18.2	18.1	2583	1700	7.0	10.6	-25	26	3126.2	722.2	-109.3	463.4	-67.3
CLUB	101.02	127.1	30.5	2945	1733	43.2	17.6	-8	33	2999.1	691.7	-100.8	426.6	-62.9
H011	115.02	157.0	39.8	3443	2029	45.6	19.6	-8	31	2842.1	651.9	-91.4	385.7	-57.7
H012	124.69	103.1	27.9	2368	1391	43.5	20.1	-7	25	2739.0	623.9	-85.2	358.7	-54.9
H013	134.36	96.4	26.1	2323	1347	41.5	19.4	-5	19	2642.7	597.9	-79.3	332.7	-53.0
H014	144.03	104.4	22.3	2264	1287	46.1	17.3	-5	21	2538.3	575.6	-73.7	307.7	-50.6
H015	153.70	109.0	21.4	2253	1276	48.4	16.8	-4	23	2429.3	554.2	-68.2	283.7	-48.1
H016	163.37	106.8	21.3	2253	1276	47.4	16.7	-4	21	2322.5	532.9	-62.9	260.7	-45.7
OF17	177.37	150.6	30.6	3261	1847	46.2	16.6	-4	20	2171.9	502.3	-55.7	229.2	-42.6
OF18	189.37	125.4	26.0	2795	1583	44.9	16.4	-4	18	2046.5	476.3	-49.8	203.9	-40.3
OF19	201.37	124.5	26.0	2795	1583	44.5	16.4	-4	18	1922.0	450.3	-44.3	180.1	-38.0
OF20	213.37	123.9	26.0	2795	1583	44.3	16.4	-4	18	1798.1	424.3	-39.0	157.8	-35.6
OF21	225.37	123.2	25.9	2795	1583	44.1	16.4	-4	18	1674.9	398.4	-34.1	136.9	-33.2
OF22	237.37	122.5	25.9	2795	1583	43.8	16.4	-4	19	1552.4	372.5	-29.5	117.6	-30.8
OF23	249.37	122.4	26.0	2795	1583	43.8	16.4	-4	19	1430.0	346.5	-25.1	99.7	-28.4
OF24	261.37	123.1	26.2	2795	1583	44.0	16.5	-4	19	1306.8	320.3	-21.1	83.3	-26.0
OF25	273.37	123.8	26.3	2795	1583	44.3	16.6	-4	19	1183.0	294.0	-17.5	68.3	-23.6
		124.5	26.5	2795	1583	44.5	16.7	-4	19					

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 200

THREE LAKEWAY CENTER . PROJECT #6013
CONFIGURATION A REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
OF26	285.37									1058.5	267.5	-14.1	54.9	-21.2
OF27	297.37	124.9	27.3	2795	1583	44.7	17.2	-4	18	933.6	240.2	-11.0	42.9	-18.8
OF28	309.37	124.9	29.1	2795	1583	44.7	18.4	-4	18	808.7	211.1	-8.3	32.5	-16.4
OF29	321.37	125.0	30.9	2795	1583	44.7	19.5	-4	18	683.7	180.2	-6.0	23.5	-14.0
OF30	333.37	125.0	32.8	2795	1583	44.7	20.7	-5	17	558.7	147.4	-4.0	16.1	-11.7
OF31	345.37	123.5	33.6	2795	1583	44.2	21.2	-5	18	435.2	113.8	-2.5	10.1	-9.3
OF32	357.37	119.6	32.9	2795	1583	42.8	20.8	-5	19	315.6	80.9	-1.3	5.6	-6.9
MEC1	369.37	116.7	33.1	2795	1583	41.7	20.9	-5	18	198.9	47.8	-.5	2.5	-4.6
MEC2	383.37	129.8	36.3	3261	1847	39.8	19.7	-5	18	69.2	11.4	-.1	.6	-2.1
TOP	401.37	69.2	11.4	2985	1355	23.2	8.4	-5	29	0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS : THREE LAKEWAY CENTER, PROJECT #6013
WIND DIRECTION 210 CONFIGURATION A REFERENCE PRESSURE 38.0 PSF

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									3223.0	506.4	-86.9	733.3	-116.0
PAR2	21.33	35.5	35.5	5698	3751	6.2	9.5	-26	26	3187.5	470.8	-76.5	665.0	-114.2
PAR3	31.00	16.6	16.6	2583	1701	6.4	9.8	-26	26	3170.9	454.2	-72.0	634.2	-113.3
PAR4	40.67	16.9	16.9	2583	1701	6.5	9.9	-26	26	3154.0	437.3	-67.7	603.6	-112.4
PAR5	50.34	17.2	17.2	2583	1701	6.7	10.1	-26	26	3136.8	420.1	-63.5	573.2	-111.6
PAR6	60.01	17.5	17.5	2583	1701	6.8	10.3	-26	26	3119.3	402.6	-59.6	543.0	-110.7
PAR7	69.68	17.8	17.8	2583	1701	6.9	10.5	-26	26	3101.4	384.8	-55.7	512.9	-109.8
PAR8	79.35	18.1	18.1	2583	1701	7.0	10.7	-26	26	3083.3	366.7	-52.1	483.0	-108.8
CLUB	89.02	18.6	18.4	2583	1700	7.2	10.8	-26	26	3064.7	348.2	-48.7	453.3	-107.9
CLUB	101.02	126.6	18.9	2945	1733	43.0	10.9	-6	43	2938.1	329.3	-44.6	417.2	-102.3
H011	115.02	153.3	26.3	3443	2029	44.5	13.0	-7	41	2784.8	303.0	-40.2	377.2	-95.8
H012	124.69	100.6	17.9	2368	1391	42.5	12.9	-7	37	2664.3	285.1	-37.3	334.7	-91.7
H013	134.36	93.8	15.7	2323	1347	40.4	11.7	-6	33	2590.4	269.4	-34.6	325.2	-88.7
H014	144.03	100.5	11.6	2264	1287	44.4	9.0	-4	34	2489.9	257.7	-32.1	300.7	-85.3
H015	153.70	105.1	10.8	2253	1276	46.7	8.5	-4	34	2384.8	246.9	-29.7	277.1	-81.6
H016	163.37	104.0	10.7	2253	1276	46.2	8.4	-3	33	2280.8	236.2	-27.3	254.5	-78.1
OF17	177.37	148.6	15.3	3261	1647	45.6	8.3	-3	32	2132.3	220.8	-24.1	223.7	-73.3
OF18	189.37	125.5	13.0	2795	1583	44.9	8.2	-3	31	2006.8	207.9	-21.5	198.8	-69.3
OF19	201.37	124.4	12.6	2795	1583	44.5	8.0	-3	32	1882.4	195.2	-19.1	175.5	-65.4
OF20	213.37	123.3	12.3	2795	1583	44.1	7.7	-3	32	1759.1	183.0	-16.9	153.6	-61.4
OF21	225.37	122.3	11.9	2795	1583	43.7	7.5	-3	33	1636.8	171.1	-14.7	133.3	-57.3
OF22	237.37	121.2	11.6	2795	1583	43.4	7.3	-3	34	1515.6	159.5	-12.8	114.3	-53.2
OF23	249.37	120.8	11.4	2795	1583	43.2	7.2	-3	34	1394.8	148.1	-10.9	96.9	-49.0
OF24	261.37	121.2	11.4	2795	1583	43.3	7.2	-3	34	1273.6	136.8	-9.2	80.9	-44.8
OF25	273.37	121.5	11.3	2795	1583	43.5	7.2	-3	34	1152.1	125.4	-7.6	66.3	-40.6
		121.9	11.3	2795	1583	43.6	7.2	-3	34					

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 210

CONFIGURATION A

THREE LAKEMAY CENTER, PROJECT #6013
REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
OF26	285.37	122.1	11.5	2795	1583	43.7	7.3	-3	34	1030.2	114.1	-6.2	53.2	-36.4
OF27	297.37	121.9	11.9	2795	1583	43.6	7.5	-3	34	908.2	102.6	-4.9	41.6	-32.2
OF28	309.37	121.7	12.3	2795	1583	43.5	7.8	-3	35	786.3	90.7	-3.7	31.4	-28.0
OF29	321.37	121.5	12.7	2795	1583	43.5	8.0	-4	35	664.6	78.4	-2.7	22.7	-23.7
OF30	333.37	120.5	13.3	2795	1583	43.1	8.4	-4	35	543.0	65.8	-1.8	15.5	-19.5
OF31	345.37	117.7	14.2	2795	1583	42.1	9.0	-4	35	422.5	52.5	-1.1	9.7	-15.2
OF32	357.37	115.4	15.6	2795	1583	41.3	9.9	-5	33	304.8	38.3	-.6	5.3	-11.0
MEC1	369.37	125.7	18.5	3261	1847	38.5	10.0	-5	33	189.5	22.6	-.2	2.3	-7.1
MEC2	383.37	63.8	4.2	2985	1355	21.4	3.1	-3	44	63.8	4.2	-.0	.6	-2.8
TOP	401.37									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS
WIND DIRECTION 220

CONFIGURATION A

THREE LAKEWAY CENTER, PROJECT #6013
REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									3123.5	510.0	-86.5	707.9	-128.9
PAR2	21.33	35.9	35.9	5698	3751	6.3	9.6	-26	26	3087.7	474.1	-76.0	641.7	-127.0
PAR3	31.00	16.9	16.9	2583	1701	6.5	9.9	-26	26	3070.8	457.3	-71.5	611.9	-126.2
PAR4	40.67	17.2	17.2	2583	1701	6.7	10.1	-26	26	3053.6	440.1	-67.2	582.3	-125.3
PAR5	50.34	17.6	17.6	2583	1701	6.8	10.3	-26	26	3036.0	422.5	-63.0	552.8	-124.4
PAR6	60.01	18.0	18.0	2583	1701	7.0	10.6	-26	26	3018.0	404.5	-59.0	523.6	-123.4
PAR7	69.68	18.3	18.3	2583	1701	7.1	10.8	-26	26	2999.7	386.2	-55.2	494.5	-122.5
PAR8	79.35	18.7	18.7	2583	1701	7.2	11.0	-26	26	2981.0	367.5	-51.5	465.6	-121.5
CLUB	89.02	19.2	19.1	2583	1700	7.4	11.2	-25	26	2961.8	348.4	-48.1	436.8	-120.6
CLUB	101.02	127.6	18.7	2945	1733	43.3	10.8	-6	44	2834.2	329.7	-44.0	402.1	-114.8
H011	115.02	153.7	25.7	3443	2029	44.6	12.7	-7	44	2680.5	303.9	-39.6	363.5	-107.8
H012	124.69	109.1	16.2	2368	1391	42.3	11.7	-7	42	2580.4	287.7	-36.7	338.0	-103.5
H013	134.36	92.7	14.4	2323	1347	39.9	10.7	-6	40	2487.7	273.3	-34.0	313.5	-99.7
H014	144.03	97.3	10.7	2264	1287	43.0	8.3	-4	40	2390.4	262.6	-31.4	289.9	-95.8
H015	153.70	100.6	10.2	2253	1276	44.6	8.0	-4	40	2289.8	252.4	-28.9	267.3	-91.7
H016	163.37	98.7	10.4	2253	1276	43.8	8.1	-4	39	2191.1	242.0	-26.5	245.6	-87.8
OF17	177.37	139.6	15.4	3261	1847	42.8	8.3	-4	39	2051.4	226.6	-23.3	215.9	-82.3
OF18	189.37	116.6	13.5	2795	1583	41.7	8.5	-4	38	1934.8	213.1	-20.6	192.0	-77.9
OF19	201.37	116.7	13.5	2795	1583	41.8	8.6	-4	38	1818.1	199.6	-18.1	169.5	-73.4
OF20	213.37	117.1	13.5	2795	1583	41.9	8.5	-4	38	1701.0	186.0	-15.8	148.4	-68.9
OF21	225.37	117.4	13.5	2795	1583	42.0	8.5	-4	38	1583.6	172.5	-13.7	128.7	-64.4
OF22	237.37	117.8	13.5	2795	1583	42.1	8.5	-4	38	1465.9	159.0	-11.7	110.4	-59.9
OF23	249.37	117.8	13.4	2795	1583	42.2	8.5	-4	38	1348.0	145.6	-9.9	93.5	-55.4
OF24	261.37	117.6	13.2	2795	1583	42.1	8.3	-4	38	1230.4	132.4	-8.2	78.0	-50.8
OF25	273.37	117.3	13.0	2795	1583	42.0	8.2	-4	39	1113.2	119.3	-6.7	64.0	-46.3
		117.0	12.8	2795	1583	41.9	8.1	-4	39					

TABLE 7. SHEAR AND MOMENT DIAGRAMS : THREE LAKEMAN CENTER . PROJECT #6013														
WIND DIRECTION 220 CONFIGURATION A REFERENCE PRESSURE 38.0 PSF GUST FACTOR 1.32														
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
OF26	285.37									996.2	106.5	-5.3	51.3	-41.6
OF27	297.37	117.1	12.7	2795	1583	41.9	8.0	-4	39	879.0	93.8	-4.1	40.1	-37.0
OF28	309.37	117.8	12.8	2795	1583	42.2	8.1	-4	39	761.2	81.0	-3.1	30.2	-32.3
OF29	321.37	118.6	12.9	2795	1583	42.4	8.1	-4	39	642.6	68.1	-2.2	21.8	-27.6
OF30	333.37	119.3	13.0	2795	1583	42.7	8.2	-4	39	523.3	55.1	-1.4	14.8	-22.9
OF31	345.37	118.5	13.1	2795	1583	42.4	8.3	-4	39	404.8	42.0	- .9	9.2	-18.2
OF32	357.37	114.7	13.3	2795	1583	41.0	8.4	-5	41	290.1	28.7	- .4	5.1	-13.5
MEC1	369.37	109.9	12.4	2795	1583	39.3	7.9	-5	43	180.1	16.3	- .2	2.2	-8.7
MEC2	383.37	119.0	13.3	3261	1847	36.5	7.2	-5	44	61.1	3.0	- .0	.5	-3.4
TOP	401.37	61.1	3.0	2985	1355	20.5	2.2	-3	55	0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 230

THREE LAKEWAY CENTER PROJECT #6013
CONFIGURATION A REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									2701.8	528.5	-94.9	608.7	-142.2
PAR2	21.33	33.6	33.6	5698	3751	5.9	9.0	-26	26	2668.2	494.9	-84.0	551.5	-140.5
PAR3	31.00	15.9	15.9	2583	1701	6.2	9.4	-26	26	2652.3	479.0	-79.2	525.7	-139.6
PAR4	40.67	16.3	16.3	2583	1701	6.3	9.6	-26	26	2636.0	462.7	-74.7	500.2	-138.8
PAR5	50.34	16.7	16.7	2583	1701	6.5	9.8	-26	26	2619.2	445.9	-70.3	474.7	-137.9
PAR6	60.01	17.2	17.2	2583	1701	6.6	10.1	-26	26	2602.1	428.8	-66.1	449.5	-137.0
PAR7	69.68	17.6	17.6	2583	1701	6.8	10.3	-26	26	2584.5	411.2	-62.0	424.4	-136.1
PAR8	79.35	18.0	18.0	2583	1701	7.0	10.6	-26	26	2566.5	393.2	-58.1	399.5	-135.2
PAR8	79.35	18.6	18.4	2583	1700	7.2	10.8	-26	26	2547.9	374.8	-54.4	374.8	-134.2
CLUB	89.02	115.9	15.9	2945	1733	39.4	9.2	-6	47	2432.0	358.9	-50.0	344.9	-128.6
CLUB	101.02	133.8	21.3	3443	2029	38.9	10.5	-8	50	2298.2	337.6	-45.1	311.8	-121.8
HO11	115.02	85.8	12.7	2368	1391	36.3	9.1	-8	52	2212.4	324.8	-41.9	290.0	-117.3
HO12	124.69	78.5	13.4	2323	1347	33.8	9.9	-9	53	2133.9	311.4	-38.8	269.0	-113.0
HO13	134.36	83.1	10.6	2264	1287	36.7	8.3	-6	50	2050.8	300.8	-35.9	248.7	-108.8
HO14	144.03	86.3	10.5	2253	1276	38.3	8.2	-6	48	1964.5	290.3	-33.0	229.3	-104.6
HO15	153.70	84.9	11.0	2253	1276	37.7	8.6	-6	49	1879.6	279.2	-30.3	210.7	-100.4
HO16	163.37	120.2	16.9	3261	1847	36.9	9.1	-7	49	1759.4	262.4	-26.5	185.3	-94.3
OF17	177.37	100.6	15.3	2795	1583	36.0	9.7	-8	50	1658.8	247.1	-23.4	164.8	-89.2
OF18	189.37	100.3	15.5	2795	1583	35.9	9.8	-8	50	1558.5	231.6	-20.6	145.5	-84.0
OF19	201.37	100.2	15.6	2795	1583	35.8	9.9	-8	51	1458.3	215.9	-17.9	127.4	-78.8
OF20	213.37	100.0	15.8	2795	1583	35.8	10.0	-8	51	1358.2	200.2	-15.4	110.5	-73.6
OF21	225.37	99.9	15.9	2795	1583	35.7	10.0	-8	51	1258.4	184.3	-13.1	94.8	-68.3
OF22	237.37	99.9	16.0	2795	1583	35.8	10.1	-8	51	1158.4	168.3	-11.0	80.3	-63.0
OF23	249.37	100.3	16.0	2795	1583	35.9	10.1	-8	51	1058.2	152.3	-9.0	67.0	-57.8
OF24	261.37	100.6	16.0	2795	1583	36.0	10.1	-8	51	957.6	136.2	-7.3	54.9	-52.5
OF25	273.37	100.9	16.0	2795	1583	36.1	10.1	-8	51					

TABLE 7. SHEAR AND MOMENT DIAGRAMS : THREE LAKEMAN CENTER . PROJECT #6013														
WIND DIRECTION 230		CONFIGURATION A		REFERENCE PRESSURE 38.0 PSF								GUST FACTOR 1.32		
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
OF26	285.37									856.7	120.2	-5.8	44.0	-47.2
		101.2	16.0	2795	1583	36.2	10.1	-8	51					
OF27	297.37									755.5	104.2	-4.4	34.3	-42.0
		101.7	15.7	2795	1583	36.4	9.9	-8	51					
OF28	309.37									653.8	88.5	-3.3	25.9	-36.7
		102.2	15.4	2795	1583	36.6	9.8	-8	51					
OF29	321.37									551.6	73.1	-2.3	18.6	-31.4
		102.6	15.2	2795	1583	36.7	9.6	-8	51					
OF30	333.37									449.0	57.9	-1.5	12.6	-26.0
		102.2	15.0	2795	1583	36.6	9.5	-8	51					
OF31	345.37									346.8	42.9	-0.9	7.8	-20.7
		99.5	14.4	2795	1583	35.6	9.1	-8	53					
OF32	357.37									247.3	28.5	-0.5	4.3	-15.3
		94.7	11.7	2795	1583	33.9	7.4	-7	57					
MEC1	369.37									152.5	16.8	-0.2	1.9	-9.8
		101.7	12.1	3261	1847	31.2	6.5	-7	59					
MEC2	383.37									50.8	4.8	-0.0	.5	-3.7
		50.8	4.8	2985	1355	17.0	3.5	-7	72					
TOP	401.37									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS : THREE LAKEWAY CENTER, PROJECT #6013
WIND DIRECTION 240 CONFIGURATION A REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									2151.6	439.1	-83.2	482.2	-155.7
PAR2	21.33	29.1	29.1	5698	3751	5.1	7.8	-26	26	2122.5	410.0	-74.1	436.6	-154.2
PAR3	31.00	13.6	13.6	2583	1701	5.3	8.0	-26	26	2108.9	396.4	-70.2	416.2	-153.5
PAR4	40.67	13.9	13.9	2583	1701	5.4	8.2	-26	26	2095.0	382.5	-66.5	395.9	-152.7
PAR5	50.34	14.2	14.2	2583	1701	5.5	8.3	-26	26	2080.8	368.3	-62.8	375.7	-152.0
PAR6	60.01	14.4	14.4	2583	1701	5.6	8.5	-26	26	2066.4	353.8	-59.3	355.6	-151.3
PAR7	69.68	14.7	14.7	2583	1701	5.7	8.6	-26	26	2051.7	339.1	-56.0	335.7	-150.5
PAR8	79.35	15.0	15.0	2583	1701	5.8	8.8	-26	26	2036.7	324.2	-52.8	315.9	-149.7
CLUB	89.02	15.4	15.2	2583	1700	5.9	9.0	-26	26	2021.3	308.9	-49.7	296.3	-148.9
CLUB	101.02	96.4	10.1	2945	1733	32.7	5.8	-5	51	1924.9	298.8	-46.1	272.6	-144.0
H011	115.02	110.7	11.7	3443	2029	32.1	5.8	-6	58	1814.3	287.1	-42.0	246.5	-137.5
H012	124.69	68.1	4.9	2368	1391	28.8	3.5	-5	67	1746.2	282.2	-39.2	229.3	-132.9
H013	134.36	60.2	6.6	2323	1347	25.9	4.9	-9	78	1686.0	275.6	-36.5	212.7	-128.2
H014	144.03	65.5	5.5	2264	1287	28.9	4.3	-6	70	1620.5	270.0	-33.9	196.7	-123.6
H015	153.70	69.1	6.2	2253	1276	30.7	4.8	-6	67	1551.4	263.9	-31.3	181.3	-118.9
H016	163.37	67.5	7.4	2253	1276	30.0	5.8	-7	68	1483.9	256.5	-28.8	166.7	-114.3
OF17	177.37	95.0	12.8	3261	1847	29.1	6.9	-9	70	1388.9	243.7	-25.3	146.6	-107.6
OF18	189.37	78.8	13.0	2795	1583	28.2	8.2	-12	71	1310.2	230.7	-22.4	130.4	-101.8
OF19	201.37	78.6	13.4	2795	1583	28.1	8.5	-12	72	1231.6	217.3	-19.8	115.1	-96.0
OF20	213.37	78.5	13.7	2795	1583	28.1	8.7	-13	73	1153.1	203.5	-17.2	100.8	-90.1
OF21	225.37	78.5	14.1	2795	1583	28.1	8.9	-13	74	1074.6	189.5	-14.9	87.4	-84.1
OF22	237.37	78.5	14.4	2795	1583	28.1	9.1	-14	74	996.1	175.1	-12.7	75.0	-78.1
OF23	249.37	78.7	14.6	2795	1583	28.1	9.2	-14	75	917.4	160.5	-10.7	63.5	-72.0
OF24	261.37	79.2	14.7	2795	1583	28.3	9.3	-14	75	838.2	145.8	-8.8	53.0	-65.9
OF25	273.37	79.7	14.8	2795	1583	28.5	9.3	-14	74	758.6	131.0	-7.2	43.4	-59.8
		80.2	14.9	2795	1583	28.7	9.4	-14	74					

TABLE 7. SHEAR AND MOMENT DIAGRAMS : THREE LAKEWAY CENTER , PROJECT #6013													
WIND DIRECTION 240		CONFIGURATION A								REFERENCE PRESSURE 38.0 PSF		GUST FACTOR 1.32	
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)	
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y
OF26	285.37									678.4	116.1	-5.7	34.8
		80.6	14.9	2795	1583	28.8	9.4	-14	74			-53.6	
OF27	297.37									597.8	101.2	-4.4	27.1
		80.9	14.8	2795	1583	28.9	9.3	-13	74			-47.5	
OF28	309.37									516.9	86.4	-3.3	20.5
		81.2	14.7	2795	1583	29.1	9.3	-13	73			-41.3	
OF29	321.37									435.7	71.7	-2.3	14.7
		81.5	14.6	2795	1583	29.2	9.2	-13	73			-35.2	
OF30	333.37									354.1	57.2	-1.5	10.0
		81.0	14.4	2795	1583	29.0	9.1	-13	73			-29.1	
OF31	345.37									273.1	42.7	-0.9	6.2
		78.3	13.7	2795	1583	28.0	8.7	-13	75			-23.0	
OF32	357.37									194.8	29.0	-0.5	3.4
		73.5	10.8	2795	1583	26.3	6.8	-12	80			-17.0	
MEC1	369.37									121.3	18.2	-0.2	1.5
		78.7	11.9	3261	1847	24.1	6.5	-13	85			-11.0	
MEC2	383.37									42.6	6.3	-0.1	.4
		42.6	6.3	2985	1355	14.3	4.6	-14	95			-4.1	
TOP	401.37									0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 250

THREE LAKESWAY CENTER, PROJECT #6013
CONFIGURATION A REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00	21.8	21.8	5698	3751	3.8	5.8	-25	25	1600.0	26.8	11.3	359.9	-141.1
PAR2	21.33	10.4	10.4	2583	1701	4.0	6.1	-26	26	1578.2	5.0	11.6	326.0	-140.0
PAR3	31.00	10.6	10.6	2583	1701	4.1	6.3	-26	26	1567.9	-5.4	11.6	310.8	-139.5
PAR4	40.67	10.9	10.9	2583	1701	4.2	6.4	-26	26	1557.2	-16.0	11.5	295.7	-138.9
PAR5	50.34	11.2	11.2	2583	1701	4.4	6.6	-26	26	1546.3	-26.9	11.3	280.7	-138.4
PAR6	60.01	11.5	11.5	2583	1701	4.5	6.8	-26	26	1535.1	-38.2	11.0	265.8	-137.8
PAR7	69.68	11.8	11.8	2583	1701	4.6	7.0	-26	26	1523.5	-49.7	10.6	251.0	-137.2
PAR8	79.35	12.2	12.1	2583	1700	4.7	7.1	-26	26	1511.7	-61.6	10.0	236.3	-136.6
CLUB	89.02	75.5	1.3	2945	1733	25.6	.7	-1	52	1499.5	-73.7	9.4	221.8	-135.9
CLUB	101.02	84.5	-2.3	3443	2029	24.5	-1.1	2	64	1424.0	-75.0	8.5	204.2	-132.0
H011	115.02	47.5	-6.5	2368	1391	20.0	-4.7	12	84	1339.5	-72.7	7.4	184.9	-126.6
H012	124.69	38.4	-6.2	2323	1347	16.5	-4.6	18	112	1292.1	-66.2	6.8	172.2	-122.6
H013	134.36	46.4	-6.6	2264	1287	20.5	-5.1	13	90	1253.7	-60.0	6.2	159.8	-118.2
H014	144.03	51.2	-6.1	2253	1276	22.7	-4.8	10	81	1207.3	-53.4	5.6	147.9	-113.9
H015	153.70	49.6	-5.1	2253	1276	22.0	-4.0	9	84	1156.1	-47.3	5.1	136.5	-109.7
H016	163.37	68.9	-5.6	3261	1847	21.1	-3.0	7	88	1106.5	-42.2	4.7	125.6	-105.5
OF17	177.37	56.3	-3.1	2795	1583	20.1	-1.9	5	92	1037.6	-36.7	4.1	110.6	-99.4
OF18	189.37	56.7	-2.6	2795	1583	20.3	-1.7	4	93	981.3	-33.6	3.7	98.5	-94.2
OF19	201.37	57.3	-2.3	2795	1583	20.5	-1.4	4	93	924.7	-30.9	3.3	87.0	-88.9
OF20	213.37	58.0	-1.9	2795	1583	20.7	-1.2	3	94	867.4	-28.7	3.0	76.3	-83.5
OF21	225.37	58.6	-1.5	2795	1583	21.0	-1.0	2	94	809.4	-26.8	2.6	66.2	-78.1
OF22	237.37	59.2	-1.3	2795	1583	21.2	-.8	2	94	750.8	-25.2	2.3	56.8	-72.6
OF23	249.37	59.7	-1.2	2795	1583	21.3	-.8	2	94	691.6	-23.9	2.0	48.2	-67.0
OF24	261.37	60.1	-1.1	2795	1583	21.5	-.7	2	94	632.0	-22.7	1.7	40.3	-61.4
OF25	273.37	60.6	-1.1	2795	1583	21.7	-.7	2	94	571.8	-21.6	1.5	33.0	-55.8

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 250

THREE LAKEWAY CENTER, PROJECT #6013
REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
OF26	285.37									511.2	-20.5	1.2	26.5	-50.1
OF27	297.37	60.9	-1.2	2795	1583	21.8	-1.7	2	94	450.2	-19.3	1.0	20.8	-44.4
OF28	309.37	61.0	-1.5	2795	1583	21.8	-1.9	2	93	389.3	-17.8	.8	15.7	-38.7
OF29	321.37	61.0	-1.8	2795	1583	21.8	-1.2	3	93	328.3	-16.0	.6	11.4	-33.0
OF30	333.37	61.0	-2.2	2795	1583	21.8	-1.4	3	92	267.3	-13.8	.4	7.8	-27.4
OF31	345.37	60.0	-2.4	2795	1583	21.5	-1.5	4	93	207.2	-11.4	.2	5.0	-21.8
OF32	357.37	56.4	-3.1	2795	1583	20.2	-2.0	5	98	150.8	-8.3	.1	2.9	-16.2
MEC1	369.37	52.3	-4.3	2795	1583	18.7	-2.7	9	106	98.6	-4.0	.0	1.4	-10.6
MEC2	383.37	57.0	-3.0	3261	1847	17.5	-1.6	6	112	41.6	-1.0	.0	.4	-4.2
TOP	401.37	41.6	-1.0	2985	1355	13.9	-1.7	2	101	0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 260

CONFIGURATION A

THREE LAKEWAY CENTER, PROJECT #6013
REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00	18.1	18.1	5698	3751	3.2	4.8	-25	25	1484.0	-179.6	61.2	338.0	-114.5
PAR2	21.33	8.9	8.9	2583	1701	3.4	5.2	-25	25	1465.9	-197.7	57.2	306.5	-113.6
PAR3	31.00	9.3	9.3	2583	1701	3.6	5.5	-26	26	1457.1	-206.5	55.2	292.4	-113.1
PAR4	40.67	9.7	9.7	2583	1701	3.8	5.7	-26	26	1447.8	-215.8	53.2	278.4	-112.6
PAR5	50.34	10.1	10.1	2583	1701	3.9	6.0	-26	26	1438.0	-225.5	51.1	264.4	-112.1
PAR6	60.01	10.6	10.6	2583	1701	4.1	6.2	-26	26	1427.9	-235.7	48.8	250.6	-111.6
PAR7	69.68	11.0	11.0	2583	1701	4.3	6.5	-26	26	1417.4	-246.2	46.5	236.8	-111.0
PAR8	79.35	11.5	11.4	2583	1700	4.4	6.7	-26	26	1406.4	-257.2	44.1	223.1	-110.5
CLUB	89.02	66.6	-4.6	2945	1733	22.6	-2.7	3	48	1394.9	-268.6	41.5	209.6	-109.9
CLUB	101.02	74.8	-9.1	3443	2029	21.7	-4.5	7	60	1328.3	-264.0	38.3	193.3	-106.6
H011	115.02	41.3	-10.7	2368	1391	17.4	-7.7	21	79	1253.5	-254.8	34.7	175.2	-102.1
H012	124.69	33.3	-9.5	2323	1347	14.3	-7.1	31	109	1212.3	-244.2	32.3	163.3	-98.6
H013	134.36	41.6	-11.1	2264	1287	18.4	-8.6	22	82	1179.0	-234.6	30.0	151.7	-94.6
H014	144.03	46.9	-10.8	2253	1276	20.8	-8.5	17	72	1137.4	-223.5	27.8	140.5	-91.0
H015	153.70	45.5	-9.9	2253	1276	20.2	-7.8	16	74	1090.6	-212.7	25.7	129.7	-87.4
H016	163.37	63.3	-12.8	3261	1847	19.4	-6.9	15	76	1045.1	-202.7	23.6	119.4	-83.9
OF17	177.37	51.9	-9.5	2795	1583	18.6	-6.0	14	79	981.8	-189.9	20.9	105.2	-78.9
OF18	189.37	52.6	-9.5	2795	1583	18.8	-6.0	14	78	929.9	-180.5	18.7	93.7	-74.6
OF19	201.37	53.6	-9.7	2795	1583	19.2	-6.1	14	77	877.3	-171.0	16.6	82.9	-70.4
OF20	213.37	54.6	-9.8	2795	1583	19.5	-6.2	14	76	823.7	-161.3	14.6	72.7	-66.1
OF21	225.37	55.5	-10.0	2795	1583	19.9	-6.3	14	75	769.1	-151.5	12.7	63.1	-61.8
OF22	237.37	56.3	-10.2	2795	1583	20.1	-6.5	14	75	713.6	-141.5	10.9	54.2	-57.5
OF23	249.37	56.7	-10.5	2795	1583	20.3	-6.6	14	74	657.3	-131.3	9.3	46.0	-53.2
OF24	261.37	57.1	-10.8	2795	1583	20.4	-6.8	14	74	600.6	-120.7	7.8	38.5	-48.8
OF25	273.37	57.5	-11.1	2795	1583	20.6	-7.0	14	73	543.5	-109.9	6.4	31.6	-44.5

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 260

THREE LAKEWAY CENTER . PROJECT #6013
REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
OF26	285.37	57.8	-11.4	2795	1583	20.7	-7.2	14	73	486.0	-98.8	5.2	25.4	-40.1
OF27	297.37	57.9	-11.4	2795	1583	20.7	-7.2	14	73	428.2	-87.4	4.0	19.9	-35.7
OF28	309.37	57.9	-11.5	2795	1583	20.7	-7.3	14	73	370.3	-75.9	3.1	15.2	-31.3
OF29	321.37	58.0	-11.6	2795	1583	20.8	-7.3	14	73	312.4	-64.4	2.2	11.1	-27.0
OF30	333.37	56.6	-11.5	2795	1583	20.3	-7.3	15	74	254.4	-52.8	1.5	7.7	-22.6
OF31	345.37	52.1	-11.4	2795	1583	18.6	-7.2	18	81	197.7	-41.4	.9	4.9	-18.2
OF32	357.37	47.2	-11.8	2795	1583	16.9	-7.4	22	90	145.6	-29.9	.5	2.9	-13.8
MEC1	369.37	52.6	-11.8	3261	1847	16.1	-6.4	22	96	98.4	-18.2	.2	1.4	-9.3
MEC2	383.37	45.7	-6.4	2985	1355	15.3	-4.7	12	84	45.7	-6.4	.1	.4	-3.9
TOP	401.37									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 270

THREE LANEWAY CENTER
CONFIGURATION A

PROJECT #6013
REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									1504.1	-302.7	92.0	347.1	-90.6
PAR2	21.33	15.7	15.7	5698	3751	2.8	4.2	-25	25	1488.4	-318.4	85.4	315.2	-89.9
PAR3	31.00	8.0	8.0	2583	1701	3.1	4.7	-25	25	1480.3	-326.5	82.3	300.9	-89.5
PAR4	40.67	8.6	8.6	2583	1701	3.3	5.0	-25	25	1471.8	-335.0	79.1	286.6	-89.0
PAR5	50.34	9.1	9.1	2583	1701	3.5	5.4	-25	25	1462.7	-344.1	75.8	272.4	-88.6
PAR6	60.01	9.7	9.7	2583	1701	3.7	5.7	-26	26	1453.0	-353.8	72.4	258.3	-88.1
PAR7	69.68	10.2	10.2	2583	1701	4.0	6.0	-26	26	1442.8	-364.0	69.0	244.3	-87.5
PAR8	79.35	10.8	10.8	2583	1701	4.2	6.3	-26	26	1432.0	-374.8	65.4	230.4	-87.0
CLUB	89.02	11.4	11.3	2583	1700	4.4	6.6	-26	26	1420.6	-386.1	61.7	216.6	-86.4
CLUB	101.02	61.7	-9.6	2945	1733	20.9	-5.6	7	46	1358.9	-376.5	57.1	199.9	-83.5
H011	115.02	71.6	-13.6	3443	2029	20.8	-6.7	10	55	1287.3	-362.8	52.0	181.4	-79.4
H012	124.69	39.8	-12.8	2368	1391	16.8	-9.2	21	67	1247.6	-350.0	48.5	169.2	-76.5
H013	134.36	32.9	-10.7	2323	1347	14.2	-7.9	29	89	1214.7	-339.3	45.2	157.3	-73.2
H014	144.03	42.5	-12.5	2264	1287	18.8	-9.7	19	66	1172.2	-326.8	42.0	145.7	-70.2
H015	153.70	48.4	-12.6	2253	1276	21.5	-9.9	15	58	1123.8	-314.1	38.9	134.6	-67.2
H016	163.37	46.6	-12.2	2253	1276	20.7	-9.5	15	59	1077.2	-302.0	35.9	124.0	-64.3
OF17	177.37	64.3	-16.8	3261	1847	19.7	-9.1	15	59	1012.9	-285.2	31.8	109.3	-60.2
OF18	189.37	52.1	-13.6	2795	1583	18.6	-8.6	16	60	960.8	-271.5	28.4	97.5	-56.9
OF19	201.37	53.1	-13.8	2795	1583	19.0	-8.7	15	59	907.7	-257.7	25.3	86.3	-53.5
OF20	213.37	54.4	-14.1	2795	1583	19.5	-8.9	15	57	853.3	-243.6	22.2	75.7	-50.2
OF21	225.37	55.7	-14.4	2795	1583	19.9	-9.1	14	56	797.6	-229.2	19.4	65.8	-46.9
OF22	237.37	57.0	-14.7	2795	1583	20.4	-9.3	14	55	740.6	-214.5	16.7	56.6	-43.5
OF23	249.37	58.0	-15.0	2795	1583	20.7	-9.5	14	54	682.6	-199.5	14.3	48.1	-40.2
OF24	261.37	58.4	-15.5	2795	1583	20.9	-9.8	14	53	624.1	-184.0	12.0	40.2	-36.9
OF25	273.37	58.9	-16.0	2795	1583	21.1	-10.1	14	52	565.2	-168.0	9.9	33.1	-33.6
		59.4	-16.5	2795	1583	21.2	-10.4	14	52					

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 270

THREE LAKEWAY CENTER, PROJECT #6013
CONFIGURATION A
REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
DF26	285.37									505.9	-151.5	7.9	26.6	-30.3
DF27	297.37	59.7	-16.9	2795	1583	21.4	-10.7	14	51	446.2	-134.6	6.2	20.9	-27.0
DF28	309.37	59.9	-17.3	2795	1583	21.4	-10.9	15	50	386.2	-117.3	4.7	15.9	-23.7
DF29	321.37	60.1	-17.6	2795	1583	21.5	-11.1	15	50	326.1	-99.7	3.4	11.7	-20.5
DF30	333.37	60.3	-18.0	2795	1583	21.6	-11.4	15	49	265.8	-81.7	2.3	8.1	-17.2
DF31	345.37	59.0	-17.9	2795	1583	21.1	-11.3	15	50	206.8	-63.8	1.4	5.3	-14.0
DF32	357.37	52.8	-18.6	2795	1583	18.9	-11.8	19	53	154.0	-45.2	.8	3.1	-10.8
MEC1	369.37	47.9	-18.2	2795	1583	17.1	-11.5	23	60	106.2	-26.9	.4	1.6	-7.5
MEC2	383.37	55.6	-16.4	3261	1847	17.0	-8.9	20	68	50.6	-10.5	.1	.5	-3.4
TOP	401.37	50.6	-10.5	2985	1355	17.0	-7.8	13	64	0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 280

THREE LAKEWAY CENTER, PROJECT #6013
CONFIGURATION A REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									1418.4	-369.4	107.9	322.5	-74.1
PAR2	21.33	17.1	17.1	5698	3751	3.0	4.6	-25	25	1401.3	-386.4	99.8	292.4	-73.2
PAR3	31.00	8.7	8.7	2583	1701	3.4	5.1	-26	26	1392.6	-395.2	96.0	278.9	-72.8
PAR4	40.67	9.3	9.3	2583	1701	3.6	5.5	-26	26	1383.3	-404.5	92.2	265.5	-72.3
PAR5	50.34	9.9	9.9	2583	1701	3.8	5.8	-27	27	1373.4	-414.4	88.2	252.2	-71.8
PAR6	60.01	10.5	10.5	2583	1701	4.1	6.2	-27	27	1362.9	-424.9	84.2	238.9	-71.2
PAR7	69.68	11.1	11.1	2583	1701	4.3	6.5	-27	27	1351.8	-436.0	80.0	225.8	-70.6
PAR8	79.35	11.7	11.7	2583	1701	4.5	6.9	-27	27	1340.1	-447.7	75.7	212.8	-70.0
CLUB	89.02	12.3	12.3	2583	1700	4.8	7.2	-28	28	1327.7	-460.0	71.3	199.9	-69.3
CLUB	101.02	56.0	-15.7	2945	1733	19.0	-9.1	13	45	1271.8	-444.2	65.9	184.3	-66.6
HO11	115.02	67.9	-20.2	3443	2029	19.7	-10.0	15	49	1203.8	-424.0	59.8	167.0	-62.9
HO12	124.69	38.8	-17.7	2368	1391	16.4	-12.7	23	51	1165.0	-406.3	55.8	155.5	-60.5
HO13	134.36	33.2	-15.5	2323	1347	14.3	-11.5	29	62	1131.8	-390.9	52.0	144.4	-58.0
HO14	144.03	42.2	-15.3	2264	1287	18.6	-11.9	19	52	1089.6	-375.5	48.3	133.7	-55.6
HO15	153.70	47.2	-14.8	2253	1276	20.9	-11.6	15	49	1042.5	-360.7	44.7	123.4	-53.0
HO16	163.37	45.2	-14.1	2253	1276	20.1	-11.1	16	50	997.3	-346.6	41.3	113.5	-50.6
OF17	177.37	61.9	-19.2	3261	1847	19.0	-10.4	16	51	935.4	-327.4	36.6	100.0	-47.1
OF18	189.37	49.8	-15.3	2795	1583	17.8	-9.7	16	53	885.6	-312.1	32.7	89.0	-44.2
OF19	201.37	50.5	-15.6	2795	1583	18.1	-9.8	16	52	835.1	-296.5	29.1	78.7	-41.3
OF20	213.37	51.5	-16.0	2795	1583	18.4	-10.1	16	50	783.6	-280.5	25.6	69.0	-38.5
OF21	225.37	52.5	-16.4	2795	1583	18.8	-10.3	15	49	731.1	-264.2	22.3	59.9	-35.6
OF22	237.37	53.5	-16.8	2795	1583	19.1	-10.6	15	48	677.7	-247.4	19.3	51.5	-32.8
OF23	249.37	54.1	-17.3	2795	1583	19.4	-10.9	15	46	623.5	-230.1	16.4	43.7	-30.1
OF24	261.37	54.4	-17.9	2795	1583	19.5	-11.3	15	45	569.1	-212.2	13.7	36.5	-27.4
OF25	273.37	54.7	-18.6	2795	1583	19.6	-11.7	15	43	514.4	-193.6	11.3	30.0	-24.8
		55.0	-19.2	2795	1583	19.7	-12.2	14	41					

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 280

THREE LAKEWAY CENTER, PROJECT #6013
CONFIGURATION A
REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
OF26	285.37	55.0	-19.8	2795	1583	19.7	-12.5	14	40	459.4	-174.3	9.1	24.2	-22.2
OF27	297.37	54.7	-20.0	2795	1583	19.6	-12.7	15	40	404.4	-154.6	7.1	19.0	-19.7
OF28	309.37	54.4	-20.3	2795	1583	19.5	-12.8	15	39	349.7	-134.5	5.4	14.5	-17.3
OF29	321.37	54.1	-20.6	2795	1583	19.4	-13.0	15	39	295.2	-114.2	3.9	10.6	-14.8
OF30	333.37	52.9	-20.3	2795	1583	18.9	-12.9	15	39	241.1	-93.6	2.7	7.4	-12.4
OF31	345.37	47.4	-21.5	2795	1583	17.0	-13.6	17	38	188.2	-73.3	1.7	4.8	-10.0
OF32	357.37	43.8	-20.8	2795	1583	15.7	-13.2	19	40	140.7	-51.7	.9	2.8	-7.9
MEC1	369.37	52.1	-18.9	3261	1847	16.0	-10.2	18	51	97.0	-30.9	.4	1.4	-5.7
MEC2	383.37	44.9	-12.0	2985	1355	15.1	-8.9	15	57	44.9	-12.0	.1	.4	-2.7
TOP	401.37									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 290

THREE LAKEWAY CENTER . PROJECT #6013
REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									1314.1	-142.8	57.0	318.0	-82.5
PAR2	21.33	12.3	12.3	5698	3751	2.2	3.3	-26	26	1301.8	-155.2	53.9	290.1	-81.9
PAR3	31.00	5.8	5.8	2583	1701	2.2	3.4	-26	26	1296.0	-161.0	52.3	277.6	-81.6
PAR4	40.67	5.9	5.9	2583	1701	2.3	3.5	-26	26	1290.1	-166.9	50.8	265.1	-81.3
PAR5	50.34	6.1	6.1	2583	1701	2.4	3.6	-25	25	1284.0	-173.0	49.1	252.6	-80.9
PAR6	60.01	6.2	6.2	2583	1701	2.4	3.6	-25	25	1277.8	-179.2	47.4	240.2	-80.6
PAR7	69.68	6.3	6.3	2583	1701	2.5	3.7	-25	25	1271.4	-185.5	45.6	227.9	-80.3
PAR8	79.35	6.5	6.5	2583	1701	2.5	3.8	-25	25	1265.0	-192.0	43.8	215.6	-80.0
CLUB	89.02	6.6	6.6	2583	1700	2.6	3.9	-25	26	1258.3	-198.6	41.9	203.4	-79.6
CLUB	101.02	49.2	.1	2945	1733	13.6	.1	-0	75	1218.1	-198.7	39.5	188.6	-76.6
HO11	115.02	46.8	-3.8	3443	2029	13.6	-1.9	7	85	1171.3	-194.9	36.8	171.9	-72.6
HO12	124.69	25.6	-4.7	2366	1391	10.8	-3.4	20	108	1145.7	-190.2	34.9	160.7	-69.7
HO13	134.36	19.4	-5.3	2323	1347	8.3	-3.9	38	140	1126.4	-184.9	33.1	149.7	-66.8
HO14	144.03	30.5	-5.6	2264	1287	13.5	-4.3	17	95	1095.9	-179.4	31.4	138.9	-63.8
HO15	153.70	37.5	-4.6	2253	1276	16.6	-3.6	10	82	1058.4	-174.7	29.6	128.5	-60.7
HO16	163.37	37.3	-3.6	2253	1276	16.6	-2.8	8	81	1021.0	-171.1	28.0	118.5	-57.7
OF17	177.37	53.8	-3.4	3261	1847	16.5	-1.8	5	81	967.3	-167.7	25.6	104.5	-53.3
OF18	189.37	45.8	-1.1	2795	1583	16.4	-.7	2	80	921.4	-166.6	23.6	93.2	-49.6
OF19	201.37	47.8	-1.2	2795	1583	17.1	-.7	2	76	873.6	-165.4	21.6	82.4	-46.0
OF20	213.37	50.0	-1.3	2795	1583	17.9	-.8	2	73	823.6	-164.1	19.6	72.3	-42.3
OF21	225.37	52.2	-1.5	2795	1583	18.7	-.9	2	70	771.5	-162.6	17.7	62.7	-38.7
OF22	237.37	54.3	-1.7	2795	1583	19.4	-1.1	2	67	717.1	-160.9	15.7	53.8	-35.0
OF23	249.37	56.1	-2.5	2795	1583	20.1	-1.6	3	64	661.0	-158.4	13.8	45.5	-31.4
OF24	261.37	57.4	-4.2	2795	1583	20.5	-2.7	4	61	603.7	-154.2	11.9	37.9	-27.9
OF25	273.37	58.7	-6.0	2795	1583	21.0	-3.8	6	57	545.0	-148.2	10.1	31.0	-24.5
		59.9	-7.7	2795	1583	21.4	-4.9	7	54					

TABLE 7. SHEAR AND MOMENT DIAGRAMS : THREE LAKEWAY CENTER, PROJECT #6013														
WIND DIRECTION 290		CONFIGURATION A				REFERENCE PRESSURE 38.0 PSF				GUST FACTOR 1.32				
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
OF26	285.37									485.0	-140.5	8.4	24.8	-21.2
		60.6	-9.5	2795	1583	21.7	-6.0	8	51					
OF27	297.37									424.5	-131.0	6.8	19.4	-18.0
		60.1	-11.2	2795	1583	21.5	-7.0	9	48					
OF28	309.37									364.4	-119.8	5.2	14.6	-15.1
		59.6	-12.9	2795	1583	21.3	-8.1	10	45					
OF29	321.37									304.8	-107.0	3.9	10.6	-12.3
		59.1	-14.6	2795	1583	21.2	-9.2	10	42					
OF30	333.37									245.7	-92.4	2.7	7.3	-9.6
		58.1	-15.4	2795	1583	20.8	-9.7	10	40					
OF31	345.37									187.5	-77.1	1.7	4.7	-7.1
		49.5	-21.1	2795	1583	17.7	-13.3	13	30					
OF32	357.37									138.0	-56.0	.9	2.8	-5.4
		41.6	-26.1	2795	1583	14.9	-16.5	12	19					
MEC1	369.37									96.4	-29.9	.4	1.4	-4.3
		53.8	-20.4	3261	1847	16.5	-11.0	12	32					
MEC2	383.37									42.6	-9.5	.1	.4	-2.4
		42.6	-9.5	2985	1355	14.3	-7.0	12	53					
TOP	401.37									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 300

THREE LAKEWAY CENTER PROJECT #6013
REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									477.0	-472.1	133.1	124.6	-21.5
PAR2	21.33	9.7	8.7	5698	3751	1.5	2.3	-28	28	468.3	-480.8	122.9	114.5	-21.0
PAR3	31.00	4.5	4.5	2583	1701	1.7	2.6	-28	28	463.8	-485.3	118.2	110.0	-20.8
PAR4	40.67	4.8	4.8	2583	1701	1.9	2.8	-27	27	459.0	-490.1	113.5	105.5	-20.5
PAR5	50.34	5.2	5.2	2583	1701	2.0	3.0	-27	27	453.8	-495.2	108.8	101.1	-20.2
PAR6	60.01	5.5	5.5	2583	1701	2.1	3.2	-27	27	448.3	-500.7	103.9	96.7	-19.9
PAR7	69.68	5.8	5.8	2583	1701	2.3	3.4	-27	27	442.5	-506.6	99.1	92.4	-19.6
PAR8	79.35	6.2	6.2	2583	1701	2.4	3.6	-27	27	436.3	-512.7	94.1	88.2	-19.3
CLUB	89.02	6.5	6.5	2583	1700	2.5	3.8	-27	27	429.8	-519.2	89.2	84.0	-18.9
CLUB	101.02	9.8	-12.3	2945	1733	3.3	-7.1	98	78	420.1	-506.9	83.0	78.9	-17.0
H011	115.02	11.7	-17.0	3443	2029	3.4	-8.4	95	65	408.3	-489.9	76.0	73.1	-14.6
H012	124.69	4.1	-16.8	2368	1391	1.7	-12.1	67	16	404.3	-473.1	71.4	69.2	-13.4
H013	134.36	.5	-18.0	2323	1347	.2	-13.3	44	1	403.8	-455.1	66.9	65.2	-12.6
H014	144.03	3.2	-17.1	2264	1287	1.4	-13.3	37	7	400.6	-438.0	62.6	61.4	-12.0
H015	153.70	5.7	-16.1	2253	1276	2.5	-12.6	37	13	394.9	-421.9	58.4	57.5	-11.3
H016	163.37	5.5	-15.1	2253	1276	2.4	-11.8	39	14	389.4	-406.9	54.4	53.7	-10.6
OF17	177.37	7.6	-19.9	3261	1847	2.3	-10.8	42	16	381.8	-386.9	48.8	48.3	-9.7
OF18	189.37	6.2	-15.3	2795	1583	2.2	-9.7	45	18	375.6	-371.6	44.3	43.8	-8.9
OF19	201.37	9.4	-14.9	2795	1583	3.0	-9.4	44	25	367.2	-356.8	39.9	39.3	-8.0
OF20	213.37	10.9	-14.5	2795	1583	3.9	-9.1	41	30	356.3	-342.3	35.7	35.0	-7.1
OF21	225.37	13.3	-14.1	2795	1583	4.8	-8.9	37	35	343.0	-328.2	31.7	30.8	-6.1
OF22	237.37	15.7	-13.7	2795	1583	5.6	-8.7	33	37	327.3	-314.4	27.8	26.8	-5.1
OF23	249.37	18.0	-14.1	2795	1583	6.4	-8.9	28	36	309.3	-300.3	24.2	22.9	-4.0
OF24	261.37	20.1	-15.6	2795	1583	7.2	-9.8	23	30	289.2	-284.7	20.6	19.4	-3.1
OF25	273.37	22.2	-17.0	2795	1583	7.9	-10.7	19	25	267.0	-267.7	17.3	16.0	-2.2
		24.3	-18.4	2795	1583	8.7	-11.6	16	21					

TABLE 7. SHEAR AND MOMENT DIAGRAMS : THREE LAKEWAY CENTER . PROJECT #6013														
WIND DIRECTION 300		CONFIGURATION A				REFERENCE PRESSURE 38.0 PSF				GUST FACTOR 1.32				
FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
OF26	285.37	25.9	-20.2	2795	1583	9.3	-12.8	13	17	242.7	-249.3	14.2	13.0	-1.4
OF27	297.37	26.9	-22.5	2795	1583	9.6	-14.2	10	11	216.8	-229.1	11.4	10.2	-.7
OF28	309.37	27.8	-24.8	2795	1583	9.9	-15.7	6	7	189.9	-206.6	8.7	7.8	-.2
OF29	321.37	28.7	-27.1	2795	1583	10.3	-17.1	3	3	162.2	-181.8	6.4	5.6	.2
OF30	333.37	32.0	-27.1	2795	1583	11.5	-17.1	4	5	133.5	-154.7	4.4	3.9	.4
OF31	345.37	28.7	-34.0	2795	1583	10.3	-21.5	-2	-2	101.5	-127.6	2.7	2.5	.7
OF32	357.37	20.6	-45.7	2795	1583	7.4	-28.9	-20	-9	72.8	-93.6	1.4	1.4	.5
MEC1	369.37	33.5	-35.8	3261	1847	10.3	-19.4	-6	-6	52.2	-47.9	.5	.7	-1.5
MEC2	383.37	18.8	-12.1	2985	1355	6.3	-9.0	23	36	18.8	-12.1	.1	.2	-.9
TOP	401.37									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 310

THREE LAKEWAY CENTER, PROJECT #6013
CONFIGURATION A
REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									-122.5	-789.9	216.9	-41.0	41.5
PAR2	21.33	13.2	13.2	5698	3751	2.3	3.5	-27	27	-135.8	-803.1	200.0	-38.3	42.2
PAR3	31.00	6.9	6.9	2583	1701	2.7	4.0	-26	26	-142.6	-810.0	192.2	-36.9	42.6
PAR4	40.67	7.4	7.4	2583	1701	2.9	4.4	-25	25	-150.1	-817.4	184.3	-35.5	43.0
PAR5	50.34	8.0	8.0	2583	1701	3.1	4.7	-25	25	-158.1	-825.4	176.3	-34.0	43.4
PAR6	60.01	8.5	8.5	2583	1701	3.3	5.0	-24	24	-166.6	-833.9	168.3	-32.5	43.8
PAR7	69.68	9.1	9.1	2583	1701	3.5	5.3	-24	24	-175.7	-843.0	160.2	-30.8	44.2
PAR8	79.35	9.6	9.6	2583	1701	3.7	5.7	-24	24	-185.3	-852.7	152.0	-29.1	44.7
CLUB	89.02	10.2	10.1	2583	1700	3.9	6.0	-24	24	-195.5	-862.8	143.7	-27.2	45.2
CLUB	101.02	-9.3	-19.1	2945	1733	-3.2	-11.0	59	-29	-186.2	-843.7	133.5	-24.9	46.6
H011	115.02	-4.1	-23.8	3443	2029	-1.2	-11.7	55	-9	-182.1	-819.9	121.8	-22.3	47.9
H012	124.69	-4.1	-24.0	2368	1391	-1.7	-17.3	2	-0	-178.0	-795.9	114.0	-20.6	48.0
H013	134.36	-7.9	-24.9	2323	1347	-3.4	-18.5	-33	10	-170.1	-771.0	106.4	-18.9	47.1
H014	144.03	-10.7	-23.9	2264	1287	-4.7	-18.5	-47	21	-159.4	-747.1	99.1	-17.3	45.7
H015	153.70	-9.9	-23.7	2253	1276	-4.4	-18.5	-51	21	-149.5	-723.5	92.0	-15.8	44.3
H016	163.37	-8.1	-23.6	2253	1276	-3.6	-18.5	-50	17	-141.4	-699.9	85.1	-14.4	43.0
OF17	177.37	-8.6	-34.0	3261	1847	-2.6	-18.4	-49	12	-132.7	-665.9	75.6	-12.5	41.2
OF18	189.37	-4.5	-29.0	2795	1583	-1.6	-18.3	-46	7	-128.3	-637.0	67.7	-10.9	39.8
OF19	201.37	-5.7	-30.0	2795	1583	-2.0	-18.9	-47	9	-122.6	-607.0	60.3	-9.4	38.4
OF20	213.37	-7.3	-31.0	2795	1583	-2.6	-19.6	-49	11	-115.3	-576.0	53.2	-8.0	36.8
OF21	225.37	-8.8	-32.1	2795	1583	-3.2	-20.3	-50	14	-106.5	-543.9	46.5	-6.7	35.0
OF22	237.37	-10.4	-33.2	2795	1583	-3.7	-21.0	-51	16	-96.1	-510.7	40.1	-5.5	33.1
OF23	249.37	-11.3	-34.4	2795	1583	-4.0	-21.8	-53	17	-84.8	-476.2	34.2	-4.4	31.1
OF24	261.37	-11.3	-35.9	2795	1583	-4.0	-22.7	-56	18	-73.5	-440.4	28.7	-3.4	28.9
OF25	273.37	-11.3	-37.3	2795	1583	-4.0	-23.6	-60	18	-62.2	-403.0	23.6	-2.6	26.5
		-11.3	-38.8	2795	1583	-4.0	-24.5	-62	18					

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 310

THREE LAKEWAY CENTER, PROJECT #6013
CONFIGURATION A
REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
DF26	285.37	-10.8	-40.0	2795	1583	-3.9	-25.2	-64	17	-51.0	-364.3	19.0	-1.9	23.8
DF27	297.37	-9.5	-40.8	2795	1583	-3.4	-25.8	-65	15	-40.2	-324.3	14.9	-1.4	21.1
DF28	309.37	-8.3	-41.6	2795	1583	-3.0	-26.3	-66	13	-30.7	-283.5	11.3	-1.0	18.3
DF29	321.37	-7.1	-42.4	2795	1583	-2.5	-26.8	-67	11	-22.4	-241.9	8.1	-.7	15.4
DF30	333.37	-3.2	-41.3	2795	1583	-1.2	-26.1	-66	5	-15.3	-199.6	5.5	-.4	12.5
DF31	345.37	-2.9	-45.2	2795	1583	-1.0	-28.6	-65	4	-12.1	-158.2	3.3	-.3	9.8
DF32	357.37	-6.8	-53.3	2795	1583	-2.4	-33.7	-67	8	-9.2	-113.0	1.7	-.1	6.8
MEC1	369.37	.5	-45.0	3261	1847	.1	-24.3	-60	-1	-2.4	-59.7	.7	-.1	3.2
MEC2	383.37	-2.9	-14.7	2985	1355	-1.0	-10.9	-34	7	-2.9	-14.7	.1	-.0	.5
TOP	401.37									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 320

THREE LAKEWAY CENTER, PROJECT #6013
REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									-453.0	-719.3	207.8	-129.2	40.4
PAR2	21.33	13.9	13.9	5698	3751	2.4	3.7	-27	27	-466.9	-733.2	192.3	-119.4	41.1
PAR3	31.00	7.5	7.5	2583	1701	2.9	4.4	-26	26	-474.4	-740.7	185.2	-114.9	41.5
PAR4	40.67	8.3	8.3	2583	1701	3.2	4.9	-25	25	-482.7	-749.0	178.0	-110.2	41.9
PAR5	50.34	9.0	9.0	2583	1701	3.5	5.3	-25	25	-491.7	-758.0	170.7	-105.5	42.4
PAR6	60.01	9.8	9.8	2583	1701	3.8	5.7	-24	24	-501.5	-767.8	163.3	-100.7	42.8
PAR7	69.68	10.5	10.5	2583	1701	4.1	6.2	-24	24	-512.0	-778.3	155.8	-95.8	43.3
PAR8	79.35	11.3	11.3	2583	1701	4.4	6.6	-24	24	-523.2	-789.5	148.3	-90.8	43.9
CLUB	89.02	12.0	12.0	2583	1700	4.6	7.0	-23	23	-535.2	-801.5	140.6	-85.7	44.4
CLUB	101.02	-15.2	-11.7	2945	1733	-5.2	-6.7	41	-53	-519.9	-789.8	131.0	-79.4	45.7
H011	115.02	-13.4	-12.9	3443	2029	-3.9	-6.3	43	-44	-506.5	-776.9	120.0	-72.2	46.8
H012	124.69	-11.7	-14.1	2368	1391	-4.9	-10.2	-2	2	-494.8	-762.8	112.6	-67.3	46.8
H013	134.36	-17.5	-16.8	2323	1347	-7.5	-12.5	-31	33	-477.3	-746.0	105.3	-62.6	45.7
H014	144.03	-24.0	-18.4	2264	1287	-10.6	-14.3	-37	48	-453.3	-727.6	98.2	-58.1	43.9
H015	153.70	-24.7	-19.0	2253	1276	-11.0	-14.9	-39	50	-428.7	-708.6	91.2	-53.9	41.9
H016	163.37	-22.2	-19.4	2253	1276	-9.8	-15.2	-40	46	-406.5	-689.2	84.5	-49.8	40.1
OF17	177.37	-27.7	-28.7	3261	1847	-8.5	-15.5	-41	39	-378.8	-660.6	75.0	-44.3	37.9
OF18	189.37	-19.6	-25.2	2795	1583	-7.0	-15.9	-40	31	-359.2	-635.4	67.3	-39.9	36.2
OF19	201.37	-19.1	-27.3	2795	1583	-6.8	-17.3	-41	29	-340.1	-608.1	59.8	-35.7	34.6
OF20	213.37	-19.0	-29.6	2795	1583	-6.8	-18.7	-41	27	-321.1	-578.5	52.7	-31.7	32.8
OF21	225.37	-18.8	-31.9	2795	1583	-6.7	-20.1	-42	25	-302.2	-546.6	45.9	-28.0	31.0
OF22	237.37	-18.7	-34.1	2795	1583	-6.7	-21.6	-42	23	-283.6	-512.5	39.6	-24.5	29.2
OF23	249.37	-18.5	-36.0	2795	1583	-6.6	-22.8	-42	22	-265.0	-476.5	33.6	-21.2	27.3
OF24	261.37	-18.5	-37.4	2795	1583	-6.6	-23.6	-44	22	-246.6	-439.0	28.1	-18.1	25.2
OF25	273.37	-18.4	-38.8	2795	1583	-6.6	-24.5	-46	22	-228.2	-400.2	23.1	-15.3	23.0
		-18.3	-40.3	2795	1583	-6.5	-25.4	-47	21					

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 320

THREE LAKEWAY CENTER, PROJECT #6013
CONFIGURATION A
REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
OF26	285.37									-210.0	-359.9	18.5	-12.7	20.8
OF27	297.37	-18.3	-41.3	2795	1583	-6.5	-26.1	-48	21	-191.7	-318.7	14.5	-10.2	18.4
OF28	309.37	-18.5	-41.6	2795	1583	-6.6	-26.3	-48	21	-173.2	-277.0	10.9	-8.1	16.0
OF29	321.37	-18.6	-42.0	2795	1583	-6.7	-26.5	-48	21	-154.6	-235.0	7.8	-6.1	13.6
OF30	333.37	-18.8	-42.4	2795	1583	-6.7	-26.8	-48	22	-135.7	-192.6	5.3	-4.3	11.1
OF31	345.37	-19.8	-41.6	2795	1583	-7.1	-26.3	-47	22	-116.0	-151.1	3.2	-2.8	8.8
OF32	357.37	-27.1	-43.6	2795	1583	-9.7	-27.5	-42	26	-88.8	-107.5	1.7	-1.6	6.2
MEC1	369.37	-37.2	-48.3	2795	1583	-13.3	-30.5	-38	30	-51.6	-59.2	.7	-.8	3.3
MEC2	383.37	-26.4	-44.4	3261	1847	-8.1	-24.0	-39	23	-25.3	-14.8	.1	-.2	.9
TOP	401.37	-25.3	-14.8	2985	1355	-8.5	-10.9	-16	27	0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 330

THREE LAKEWAY CENTER, PROJECT #6013
CONFIGURATION A
REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									-973.4	-1042.4	286.8	-241.5	35.0
PAR2	21.33	4.2	4.2	5698	3751	.7	1.1	-40	40	-977.7	-1046.6	264.5	-220.7	35.3
PAR3	31.00	4.2	4.2	2583	1701	1.6	2.5	-32	32	-981.9	-1050.8	254.3	-211.2	35.6
PAR4	40.67	5.6	5.6	2583	1701	2.2	3.3	-30	30	-987.5	-1056.4	244.2	-201.7	35.9
PAR5	50.34	7.0	7.0	2583	1701	2.7	4.1	-29	29	-994.5	-1063.4	233.9	-192.1	36.3
PAR6	60.01	8.4	8.4	2583	1701	3.3	5.0	-29	29	-1002.9	-1071.9	223.6	-182.5	36.8
PAR7	69.68	9.9	9.9	2583	1701	3.8	5.8	-28	28	-1012.8	-1081.7	213.2	-172.7	37.4
PAR8	79.35	11.3	11.3	2583	1701	4.4	6.6	-28	28	-1024.0	-1093.0	202.7	-162.9	38.0
CLUB	89.02	12.6	12.6	2583	1700	4.9	7.4	-28	28	-1036.6	-1105.6	192.0	-152.9	38.7
CLUB	101.02	-30.3	-18.4	2945	1733	-10.3	-10.6	14	-23	-1006.4	-1087.2	178.9	-140.7	39.6
HO11	115.02	-25.7	-11.8	3443	2029	-7.5	-5.8	25	-54	-980.6	-1075.4	163.7	-126.8	41.3
HO12	124.69	-26.5	-16.7	2368	1391	-11.2	-12.0	-1	1	-954.2	-1058.7	153.4	-117.4	41.3
HO13	134.36	-36.3	-24.4	2323	1347	-15.6	-18.1	-18	26	-917.9	-1034.3	143.3	-108.4	39.9
HO14	144.03	-43.0	-26.6	2264	1287	-19.0	-20.7	-20	32	-874.9	-1007.7	133.4	-99.7	38.0
HO15	153.70	-44.4	-27.7	2253	1276	-19.7	-21.7	-20	32	-830.4	-980.0	123.8	-91.4	36.0
HO16	163.37	-43.1	-28.3	2253	1276	-19.1	-22.2	-19	29	-787.3	-951.7	114.5	-83.6	34.2
OF17	177.37	-60.0	-42.0	3261	1847	-18.4	-22.7	-18	25	-727.3	-909.7	101.4	-73.0	32.0
OF18	189.37	-49.3	-37.0	2795	1583	-17.6	-23.3	-16	21	-678.0	-872.7	90.7	-64.6	30.4
OF19	201.37	-47.9	-39.9	2795	1583	-17.1	-25.2	-17	20	-630.1	-832.8	80.5	-56.7	28.7
OF20	213.37	-46.6	-43.0	2795	1583	-16.7	-27.1	-18	20	-583.5	-789.9	70.8	-49.5	27.0
OF21	225.37	-45.3	-46.0	2795	1583	-16.2	-29.1	-20	19	-538.2	-743.8	61.6	-42.7	25.2
OF22	237.37	-44.0	-49.1	2795	1583	-15.7	-31.0	-21	19	-494.2	-694.7	52.9	-36.5	23.4
OF23	249.37	-43.0	-51.5	2795	1583	-15.4	-32.5	-22	18	-451.2	-643.2	44.9	-30.9	21.5
OF24	261.37	-42.4	-52.9	2795	1583	-15.2	-33.4	-22	18	-408.8	-590.4	37.5	-25.7	19.6
OF25	273.37	-41.8	-54.3	2795	1583	-14.9	-34.3	-22	17	-367.0	-536.1	30.8	-21.0	17.6
		-41.1	-55.7	2795	1583	-14.7	-35.2	-23	17					

TABLE 7. SHEAR AND MOMENT DIAGRAMS
WIND DIRECTION 330

CONFIGURATION A

THREE LAKEWAY CENTER

PROJECT #6013

REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
OF26	285.37	-40.3	-56.6	2795	1583	-14.4	-35.7	-23	16	-325.9	-480.4	24.7	-16.9	15.7
OF27	297.37	-39.1	-56.7	2795	1583	-14.0	-35.8	-23	16	-285.6	-423.8	19.2	-13.2	13.7
OF28	309.37	-37.8	-56.8	2795	1583	-13.5	-35.9	-23	15	-246.5	-367.1	14.5	-10.0	11.8
OF29	321.37	-36.6	-56.9	2795	1583	-13.1	-35.9	-23	15	-208.7	-310.3	10.4	-7.3	9.9
OF30	333.37	-35.6	-56.2	2795	1583	-12.7	-35.5	-22	14	-172.1	-253.5	7.0	-5.0	8.1
OF31	345.37	-36.7	-56.1	2795	1583	-13.1	-35.4	-23	15	-136.5	-197.3	4.3	-3.2	6.3
OF32	357.37	-39.5	-57.5	2795	1583	-14.1	-36.3	-24	16	-99.8	-141.2	2.3	-1.7	4.5
MEC1	369.37	-38.0	-60.9	3261	1847	-11.7	-32.9	-19	12	-60.3	-83.7	1.0	-.8	2.5
MEC2	383.37	-22.2	-22.8	2985	1355	-7.5	-16.8	-22	21	-22.2	-22.8	.2	-.2	1.0
TOP	401.37									0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 340

THREE LAKEWAY CENTER, PROJECT #6013
REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									-1250.2	-1252.8	326.8	-303.7	19.3
PAR2	21.33	-1.9	-1.9	5698	3751	-1.2	-1.2	18	-18	-1249.2	-1251.9	300.0	-277.0	19.3
PAR3	31.00	1.9	1.9	2583	1701	.8	1.1	-35	35	-1251.2	-1253.8	287.9	-265.0	19.4
PAR4	40.67	3.4	3.4	2583	1701	1.3	2.0	-31	31	-1254.6	-1257.3	275.8	-252.8	19.7
PAR5	50.34	4.9	4.9	2583	1701	1.9	2.9	-29	29	-1259.5	-1262.1	263.6	-240.7	19.9
PAR6	60.01	6.3	6.3	2583	1701	2.5	3.7	-28	28	-1265.8	-1268.5	251.4	-228.5	20.3
PAR7	69.68	7.8	7.8	2583	1701	3.0	4.6	-28	28	-1273.6	-1276.3	239.1	-216.2	20.7
PAR8	79.35	9.3	9.3	2583	1701	3.6	5.5	-27	27	-1282.9	-1285.6	226.7	-203.8	21.2
CLUB	89.02	10.7	10.7	2583	1700	4.1	6.3	-27	27	-1293.6	-1296.2	214.2	-191.4	21.8
CLUB	101.02	-44.6	-32.5	2945	1733	-15.2	-18.8	13	-18	-1248.9	-1263.7	198.8	-176.1	23.0
HO11	115.02	-40.1	-25.6	3443	2029	-11.6	-12.6	27	-42	-1208.8	-1238.1	181.3	-158.9	25.4
HO12	124.69	-37.2	-27.4	2368	1391	-15.7	-19.7	5	-6	-1171.6	-1210.7	169.5	-147.4	25.8
HO13	134.36	-43.5	-32.9	2323	1347	-18.7	-24.4	-7	9	-1128.1	-1177.8	157.9	-136.3	25.1
HO14	144.03	-48.4	-34.1	2264	1287	-21.4	-26.5	-9	12	-1079.7	-1143.7	146.7	-125.6	24.3
HO15	153.70	-49.7	-35.2	2253	1276	-22.1	-27.6	-9	12	-1030.0	-1108.5	135.8	-115.4	23.3
HO16	163.37	-48.7	-36.1	2253	1276	-21.6	-28.3	-8	11	-981.2	-1072.4	125.3	-105.7	22.5
OF17	177.37	-68.9	-53.9	3261	1847	-21.1	-29.2	-8	10	-912.4	-1018.5	110.6	-92.4	21.4
OF18	189.37	-57.4	-47.7	2795	1583	-20.5	-30.1	-7	8	-854.9	-970.7	98.7	-81.8	20.6
OF19	201.37	-56.4	-50.0	2795	1583	-20.2	-31.6	-8	9	-798.6	-920.7	87.4	-71.9	19.6
OF20	213.37	-55.3	-52.3	2795	1583	-19.8	-33.0	-9	10	-743.2	-868.4	76.6	-62.7	18.6
OF21	225.37	-54.3	-54.6	2795	1583	-19.4	-34.5	-10	10	-688.9	-813.8	66.5	-54.1	17.5
OF22	237.37	-53.3	-56.9	2795	1583	-19.1	-36.0	-11	11	-635.6	-756.9	57.1	-46.1	16.3
OF23	249.37	-52.7	-58.6	2795	1583	-18.8	-37.0	-12	11	-582.9	-698.2	48.4	-38.8	15.0
OF24	261.37	-52.7	-59.5	2795	1583	-18.8	-37.6	-13	11	-530.3	-638.7	40.3	-32.1	13.7
OF25	273.37	-52.6	-60.4	2795	1583	-18.8	-38.1	-13	11	-477.6	-578.4	33.0	-26.1	12.3
		-52.6	-61.2	2795	1583	-18.8	-38.7	-13	11					

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 340

CONFIGURATION A

THREE LAKEWAY CENTER, PROJECT #6013
REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
OF26	285.37									-425.0	-517.1	26.5	-20.7	10.9
OF27	297.37	-52.7	-61.7	2795	1583	-18.8	-39.0	-13	11	-372.4	-455.4	20.6	-15.9	9.5
OF28	309.37	-52.8	-61.5	2795	1583	-18.9	-38.9	-13	11	-319.6	-393.9	15.5	-11.7	8.0
OF29	321.37	-53.0	-61.4	2795	1583	-18.9	-38.8	-13	11	-266.6	-332.5	11.2	-8.2	6.6
OF30	333.37	-53.1	-61.3	2795	1583	-19.0	-38.7	-13	11	-213.5	-271.2	7.6	-5.3	5.2
OF31	345.37	-52.7	-60.7	2795	1583	-18.8	-38.3	-13	11	-160.8	-210.6	4.7	-3.1	3.9
OF32	357.37	-51.5	-59.7	2795	1583	-18.4	-37.7	-13	11	-109.4	-150.8	2.5	-1.5	2.6
MEC1	369.37	-51.1	-59.6	2795	1583	-18.3	-37.6	-13	11	-58.3	-91.2	1.0	-.5	1.2
MEC2	383.37	-55.2	-65.6	3261	1847	-16.9	-35.5	-10	9	-3.1	-25.7	.2	-.0	.1
TOP	401.37	-3.1	-25.7	2985	1355	-1.0	-18.9	-4	0	0.0	0.0	0.0	0.0	0.0

TABLE 7. SHEAR AND MOMENT DIAGRAMS
WIND DIRECTION 350

THREE LAKEWAY CENTER, PROJECT #6013
REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
GRND	0.00									-1759.2	-1252.8	323.3	-431.1	11.0
PAR2	21.33	-1.3	-1.3	5698	3751	-1.2	-1.3	-7	7	-1757.9	-1251.5	296.6	-393.6	11.0
PAR3	31.00	1.1	1.1	2583	1701	.4	.6	-37	37	-1759.0	-1252.6	284.5	-376.6	11.1
PAR4	40.67	2.2	2.2	2583	1701	.8	1.3	-32	32	-1761.2	-1254.7	272.4	-359.6	11.2
PAR5	50.34	3.2	3.2	2583	1701	1.2	1.9	-30	30	-1764.4	-1258.0	260.2	-342.5	11.4
PAR6	60.01	4.3	4.3	2583	1701	1.7	2.5	-30	30	-1768.7	-1262.3	248.0	-325.5	11.7
PAR7	69.68	5.3	5.3	2583	1701	2.1	3.1	-29	29	-1774.0	-1267.6	235.8	-308.3	12.0
PAR8	79.35	6.4	6.4	2583	1701	2.5	3.8	-29	29	-1780.4	-1274.0	223.5	-291.2	12.3
CLUB	89.02	7.3	7.4	2583	1700	2.8	4.3	-29	29	-1787.7	-1281.4	211.1	-273.9	12.8
CLUB	101.02	-61.0	-31.6	2945	1733	-20.7	-18.2	11	-21	-1726.8	-1249.8	196.0	-252.8	14.4
H011	115.02	-60.2	-25.2	3443	2029	-17.5	-12.4	15	-36	-1666.5	-1224.6	178.6	-229.1	16.9
H012	124.69	-49.1	-26.8	2368	1391	-20.7	-19.3	6	-11	-1617.4	-1197.8	166.9	-213.2	17.6
H013	134.36	-56.1	-34.0	2323	1347	-24.2	-25.3	-2	3	-1561.2	-1163.8	155.5	-197.8	17.4
H014	144.03	-57.8	-35.3	2264	1287	-25.5	-27.4	-2	4	-1503.5	-1128.5	144.4	-183.0	17.1
H015	153.70	-57.9	-35.9	2253	1276	-25.7	-28.1	-2	4	-1445.6	-1092.6	133.7	-168.7	16.8
H016	163.37	-57.4	-36.4	2253	1276	-25.5	-28.5	-2	3	-1388.1	-1056.2	123.3	-155.0	16.5
OF17	177.37	-82.3	-53.5	3261	1847	-25.2	-29.0	-2	3	-1305.8	-1002.7	108.9	-136.2	16.2
OF18	189.37	-69.8	-46.7	2795	1583	-25.0	-29.5	-2	2	-1236.0	-956.0	97.1	-120.9	16.0
OF19	201.37	-70.8	-48.9	2795	1583	-25.3	-30.9	-3	4	-1165.3	-907.1	85.9	-106.5	15.6
OF20	213.37	-71.9	-51.2	2795	1583	-25.7	-32.4	-4	5	-1093.3	-855.9	75.4	-93.0	15.0
OF21	225.37	-73.1	-53.6	2795	1583	-26.1	-33.8	-5	6	-1020.3	-802.3	65.4	-80.3	14.3
OF22	237.37	-74.2	-55.9	2795	1583	-26.5	-35.3	-6	7	-946.1	-746.4	56.1	-68.5	13.5
OF23	249.37	-75.4	-57.7	2795	1583	-27.0	-36.4	-6	8	-870.7	-688.7	47.5	-57.6	12.5
OF24	261.37	-76.6	-58.7	2795	1583	-27.4	-37.1	-7	9	-794.1	-630.0	39.6	-47.6	11.4
OF25	273.37	-77.8	-59.6	2795	1583	-27.8	-37.7	-7	9	-716.3	-570.4	32.4	-38.5	10.3
		-79.0	-60.6	2795	1583	-28.3	-38.3	-7	10					

TABLE 7. SHEAR AND MOMENT DIAGRAMS :
WIND DIRECTION 350

THREE LAKEMAN CENTER, PROJECT #6013
REFERENCE PRESSURE 38.0 PSF

GUST FACTOR 1.32

FLOOR	HEIGHT	FORCE (KIPS)		AREA (SQ FT)		PRESSURE (PSF)		ECCEN (FT)		SHEAR (KIPS)		MOMENT (1000-FT-KIPS)		
		X	Y	X	Y	X	Y	X	Y	X	Y	X	Y	Z
OF26	285.37	-80.0	-61.2	2795	1583	-28.6	-38.7	-8	10	-637.3	-509.8	25.9	-30.4	9.1
OF27	297.37	-80.4	-61.2	2795	1583	-28.8	-38.6	-7	10	-557.3	-448.6	20.2	-23.2	7.9
OF28	309.37	-80.9	-61.2	2795	1583	-28.9	-38.6	-7	10	-476.9	-387.4	15.2	-17.0	6.6
OF29	321.37	-81.4	-61.1	2795	1583	-29.1	-38.6	-7	10	-396.0	-326.2	10.9	-11.8	5.4
OF30	333.37	-80.7	-60.5	2795	1583	-28.9	-38.2	-7	10	-314.7	-265.1	7.3	-7.5	4.1
OF31	345.37	-78.0	-58.7	2795	1583	-27.9	-37.1	-7	9	-234.0	-204.6	4.5	-4.2	2.9
OF32	357.37	-76.6	-58.1	2795	1583	-27.4	-36.7	-7	9	-155.9	-145.9	2.4	-1.9	1.8
MEC1	369.37	-83.3	-63.3	3261	1847	-25.5	-34.3	-6	8	-79.4	-87.7	1.0	-.5	.7
MEC2	383.37	3.9	-24.4	2985	1355	1.3	-18.0	15	2	3.9	-24.4	.2	.0	-.4
TOP	401.37									0.0	0.0	0.0	0.0	0.0